



CONSULTANT



3C ENGINEERING
SANTA ROSA, CALIFORNIA

BY 3C ENGINEERING, INC. ALL COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS RESERVE. THIS DOCUMENT IS UNPUBLISHED WORK PRODUCT. THE WORK SHALL NOT BE REPRODUCED, COPIED, DISCLOSED OR USED IN CONNECTION WITH ANY WORK OR PROJECT OTHER THAN THE SPECIFIC PROJECT FOR WHICH IT WAS PREPARED. FOR SHALL BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESS WRITTEN CONSENT OF 3C ENGINEERING, INC. THE DOCUMENT SHALL CONSTITUTE CONCLUSIVE EVIDENCE OF ACCEPTANCE OF THESE RESTRICTIONS.

AGENCY



KEY NOTES	
APPLICABLE TO THIS SHEET ONLY	
①	TYPICAL VOLUME DAMPER. REFER TO DETAIL 11M-004.
HVAC GENERAL NOTES	
APPLICABLE TO THIS SHEET ONLY	
1	VERIFY FINAL THERMOSTAT LOCATIONS WITH OWNER PRIOR TO INSTALLATION. IF OWNER INTENDS TO CHANGE LOCATION OF THERMOSTAT, CONTACT ENGINEER OF RECORD PRIOR TO FINALIZING LOCATION.
2	PROVIDE MANUAL VOLUME DAMPERS IN ALL BRANCH DUCTS TO AIR OUTLETS/INLETS. VOLUME DAMPERS ABOVE HARD LID CEILING TO BE CABLE OPERATED UNLESS NOTED OTHERWISE. CABLE TO BE ACCESSED THRU THE FACE OF GRILLE AFTER BALANCING TUCK CABLE INTO DIFFUSER SO THAT IT IS NOT VISIBLE.

PASSIVE MAKE-UP AIR SCHEDULE		
ROOM	DOOR LOUVER MINIMUM FREE AREA FT ²	DOOR UNDER CUT
LOBBY RR 1 C105	NA	1"
LOBBY RR 2 C104	NA	1"
IT CLOSET C102A	0.8	NA
LOBBY RR 3 C112	NA	1"
STAFF RR C120	NA	1"
STAFF RR C122	NA	1"
JANITOR C126	NA	1"



