

Issue List

- AC-2 LOW FLOW PULLY CHANGE REQUIRED
- AC-3 LENNOX CORE BOARD NOT OPERATIONAL UNABLE TO SET OA
- HD-4 CAPTURE JET POTENTIOMETER NOT OPERATIONAL



Chick-Fil-A (Redding, CA)

Project Issue Information

Issue Name : AC-2 LOW FLOW PULLY CHANGE REQUIRED
Description : AC-2 has low air flow 4911 CFM out of a design 5600 CFM. unit was balanced proportionally low. recommended to have pully change preformed.
Created By : National TAB **Assigned To :** National TAB - Zack Eismin
Status : Open
Priority : High **Asset Tag :**
Originated Date : 11/20/2024 - Zack Eismin - National TAB



Chick-Fil-A (Redding, CA)

Project Issue Information

Issue Name : AC-3 LENNOX CORE BOARD NOT OPERATIONAL UNABLE TO SET OA
Description : AC-3 LENNOX CORE board is not operational. OA is unable to be set. Recommend to have serviced.

Created By : National TAB **Assigned To :** National TAB - Zack Eismin
Status : Open
Priority : High **Asset Tag :**
Originated Date : 11/20/2024 - Zack Eismin - National TAB

Project Issue File Details



11/20/2024



Chick-Fil-A (Redding, CA)

Project Issue Information

Issue Name : HD-4 CAPTURE JET POTENTIOMETER NOT OPERATIONAL
Description : Capture jets for HD-4 cannot be adjusted due to faulty potentiometer. Jets are currently set at 0.21" sp.
Created By : National TAB **Assigned To :** National TAB - Zack Eismin
Status : Open
Priority : High **Asset Tag :**
Originated Date : 11/19/2024 - Zack Eismin - National TAB

Project Issue File Details



11/19/2024



11/19/2024