



### AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	750	784	750	784				
RTU-2	BOH	1350	1350	0	0				
EF-1	RESTROOMS					300	0	300	0
EF-2	KITCHEN HD					1350	1310	0	0
EF-3	COMBI-OVEN					150	0	150	0
<b>TOTALS</b>		<b>2100</b>	<b>2134</b>	<b>750</b>	<b>784</b>	<b>1800</b>	<b>1310</b>	<b>450</b>	<b>0</b>

### HOODS ON

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2100	2134
TOTAL EXHAUST	1800	1310
<b>NET AIRFLOW</b>	<b>300</b>	<b>824</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.015"
SIDE	N/A
REAR	N/A
<b>AVERAGE</b>	<b>0.015"</b>

### HOODS OFF

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	750	784
TOTAL EXHAUST	450	0
<b>NET AIRFLOW</b>	<b>300</b>	<b>784</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.11"
SIDE	N/A
REAR	N/A
<b>AVERAGE</b>	<b>0.11"</b>

NOTES: