





**SHEET NOTES**

- 1. A/C FOR RETIRED SIGNAL DETECTOR IN MAIN SUPPLY AND RETURN OF EACH ROOF TOP UNIT.
- 2. INSTALL ROOF MOUNTED EXHAUST FAN PER DETAIL ON SHEET. INDICATE EXACT LOCATION OF PENETRATION WITH ANTI-ELECTRICAL ROOF FLASH TRANSITION GALVANIZED DUCT WORK AS NECESSARY FROM FAN INTO CLEARCOAT SPACE. SEE 20487 1/2" FOR CONTINUATION.
- 3. PROVIDE ALL JUNCTION CONNECTIONS BETWEEN ALL DUCT WORK AND MECHANICAL UNITS.
- 4. ROUTE ROOF PVC CONDENSATE DRAIN PIPING ALONG ROOF SUPPORTS PER DETAIL ON SHEET 2047.
- 5. VERIFY 18" MINIMUM CLEARANCE BETWEEN OUTSIDE AIR INTAKE AND EXHAUST TERMINATIONS ON ROOF.
- 6. REFER TO RETIRED DRAWING FOR ADDITIONAL INFORMATION.
- 7. PROVIDE CONDENSER PANEL IN LOCATION SHOWN. LOCATION SHOULD BE RECORDED BY THE OTHER TRADES. MAINTENANCE PROCEDURES IN EQUIPMENT MAINTENANCE AND OPERATING CLEARANCES REFER TO STRUCTURAL DRAWINGS FOR ROOFING PANEL OR LUMEN TRUSS SYSTEMS.

**GENERAL NOTES**

ALL WORK SHALL BE IN ACCORDANCE WITH ALL APPLICABLE CODES AND REGULATIONS. REFER TO STRUCTURAL DRAWINGS FOR ROOFING PANEL OR LUMEN TRUSS SYSTEMS.

**HVAC ROOF PLAN**

**AECOM**

AECOM Services Corporation  
300 BROADWAY DRIVE, SUITE 250  
LEWISTOWN, PA 17641  
TEL: 717.850.5000 FAX: 717.850.5001  
http://www.aecom.com

---

**WAWA INC.**

CLIENT NAME  
WAWA INC.  
1000 W. MARKET STREET  
WAWA, PA 17601

---

**WAWA STORE #8245**

PROJECT NAME  
WAWA STORE #8245  
1000 W. MARKET STREET  
WAWA, PA 17601

---

**HVAC ROOF PLAN**

SHEET TITLE

---

DATE	DESCRIPTION

---

PROJECT NO.	DATE	DRAWN BY	CHECKED BY

---

**8245**

LEWISTOWN, PA

**Wawa**

**M2.0**