

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: AHU-1

Area: FIRST FLOOR

Supply Side

Unit Data

Manufacturer	YORK
Model Number	YCI-84X126
Serial Number	TEMM191090
Configuration	VERTICAL
No. Pre Filters / Size	15 / 20X20X2
No. Pre Filters / Size	3 / 20X16X2
No. Pre Filters / Size	5 / 16X20X2
No. Primary Filters / Size	15 / 20X20X4
No. Primary Filters / Size	3 / 20X16X4
No. Primary Filters / Size	5 / 16X20X4

Return Side

Unit Data

Manufacturer	YORK
Model Number	YCI-84X126
Serial Number	TEMM191090
Configuration	VERTICAL

Motor Data X 4

Motor MFG / Frame	BALDOR / 215T
Horsepower / RPM	10 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	12.5 / 1.15

Motor Data X 4

Motor MFG / Frame	BALDOR / 215T
Horsepower / RPM	10 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	12.5 / 1.15

Test Data

	Design	Actual
Total CFM	22600	22478
Min OA CFM	4600	4830
Fan RPM	2553	2463
VFD Speed	85.1	82.1
RL Voltage	460	472
RL Amperage	12.5	8.7
Motor B.H.P.	7.78	6.96

Test Data

	Design	Actual
Total CFM	22600	22128
Relief CFM		4480
Fan RPM	2196	2196
VFD Speed	73	73
RL Voltage	460	472
RL Amperage	12.5	6.1
Motor B.H.P.	3.90	4.88

Performance Data

	Design	Actual
Suction S.P.		-3.33
Discharge S.P.		1.38"
Total SP	6.05	4.71"
CW Coil P.D.	0.68	0.46"
HW Coil P.D.	0.03	0.85" *
Pre Filters P.D.*	0.20	* combined
Final Filters P.D.	0.42	* combined
Total ESP	3.00	3.39"
System Set Point		0.8"

Performance Data

	Design	Actual
Suction S.P.		-3.17"
Discharge S.P.		0.27"
Total SP	2.69	3.44"
SF GAIN:		1.385
OA GAIN:		1.043
RA GAIN:		1.058

CONNECTD LOAD 37425

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 1 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
111-1	1800	D	8	160	200	165	1.03
111-2	1800	D	8	160	191	158	0.99
111-3	1800	D	8	160	184	152	0.95
111-4	1800	D	8	160	206	170	1.06
111-5	1800	D	8	160	202	167	1.04
111-6	1800	D	8	160	203	168	1.05
111-7	1800	D	8	160	194	160	1.00
111-8	1800	D	8	160	197	163	1.02
VAV-1-11				1280		1303	1.02
112-1	1051	D	8	200	219	202	1.01
112-2	1051	D	8	225	278	227	1.01
112-3	1051	D	8	225	316	228	1.01
VAV-1-12				650		657	1.01
113-1	1051	B	8	150	194	149	0.99
113-2	1051	L	8	200	217	201	1.01
113-3	1051	B	8	150	262	149	0.99
113-4	1051	L	8	200	0	207	1.04
113-5	1051	L	8	200	93	198	0.99
113-6	1051	B	8	200	261	205	1.03
VAV-1-13				1100		1109	1.01
114-1	ELEV LOBBY	A	6	100	143	101	1.01
114-2	1058	B	8	125	114	121	0.97
114-3	COOR	B	8	125	125	122	0.98
114-4	COOR	B	8	150	218	150	1.00
VAV-1-14				500		494	0.99

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 1 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
123-1	1203	B	8	140	73	130	0.93
123-2	1200	B	8	175	127	168	0.96
123-3	1203	B	8	140	75	144	1.03
123-4	1203	B	8	140	72	143	1.02
123-5	1203	B	8	140	75	134	0.96
123-6	1203	B	8	140	75	140	1.00
123-7	1201	B	8	75	151	77	1.03
123-8	203	B	8	140	78	141	1.01
123-9	1203	B	8	140	78	146	1.04
VAV-1-23				1230		1223	0.99
124-1	1803	M	12X12	500	533	502	1.00
VAV-1-24				500		502	1.00
125-1	1524	A	8	140	120	145	1.04
125-2	1500	A	8	100	121	96	0.96
125-3	1522	A	8	130	113	131	1.01
125-4	1520	A	8	140	116	135	0.96
VAV-1-25				510		507	0.99
126-1	1500	A	8	100	122	98	0.98
126-2	1509	F	6	50	147	51	1.02
126-3	1514	A	8	130	140	124	0.95
126-4	1516	A	8	130	126	124	0.95
126-5	1512	A	8	130	126	124	0.95
VAV-1-26				540		521	0.96
127-1	1525	B	8	130	93	129	0.99
127-2	1523	B	8	145	147	141	0.97
127-3	1521	B	8	130	89	130	1.00
VAV-1-27				405		400	0.99

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 1 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
149-1	1051	L	10	300	335	321	1.07
149-2	1051	L	10	300	341	309	1.03
149-3	1051	L	10	300	319	301	1.00
149-4	1051	L	10	300	305	288	0.96
149-5	1051	L	10	300	350	306	1.02
149-6	1051	L	10	300	346	314	1.05
149-7	1051	L	10	300	322	317	1.06
149-8	1051	L	10	300	289	311	1.04
149-9	1051	L	10	300	270	306	1.02
149-10	1051	L	10	300	390	311	1.04
VAV-1-49				3000		3084	1.03
150-1	1000A	L	12	375	461	391	1.04
150-2	1000A	L	12	375	451	382	1.02
150-3	1000A	L	12	375	457	387	1.03
150-4	1000A	L	12	375	460	390	1.04
150-5	1000A	L	12	375	454	385	1.03
150-6	1000A	L	12	375	457	387	1.03
VAV-1-50				2250		2322	1.03
151-1	1000B	L	10	300	354	309	1.03
151-2	1000B	L	10	300	320	321	1.07
151-3	1000B	L	10	300	378	289	0.96
151-4	1000B	L	10	300	367	302	1.01
151-5	1000B	L	10	300	349	313	1.04
151-6	1000B	L	10	300	351	307	1.02
151-7	1000B	L	10	300	330	279	0.93
151-8	1000B	L	10	300	359	300	1.00
151-9	1000B	L	10	300	367	315	1.05
VAV-1-51				2700		2735	1.01

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: AHU-2

Area: SECOND FLOOR

Supply Side

Unit Data

Manufacturer	YORK
Model Number	YCI-84X120
Serial Number	TEMM191100
Configuration	VERTICAL
No. Pre Filters / Size	9 / 24X24X2
No. Pre Filters / Size	6 / 24X20X2
No. Primary Filters / Size	9 / 24X20X4
No. Primary Filters / Size	6 / 24X20X4

Motor Data X 4

Motor MFG / Frame	BALDOR / 215T
Horsepower / RPM	10 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	12.50 / 1.15

Test Data

	Design	Actual
Total CFM	21600	22105
Min OA CFM	3700	3734
Fan RPM	2505	2376
VFD Speed	83.5	79.2
RL Voltage	460	472
RL Amperage	12.50	8.3
Motor B.H.P.	7.31	6.64

Performance Data

	Design	Actual
Suction S.P.		-2.62"
Discharge S.P.		2.10"
Total SP	5.92	4.72"
CW Coil P.D.	0.68	0.38"
HW Coil P.D.	0.03	1.01" *
Pre Filters P.D.*	0.20	* combined
Final Filters P.D.	0.43	* combined
Total ESP	3.00	3.33"
System Set Point		1.0"

Return Side

Unit Data

Manufacturer	YORK
Model Number	YCI-84X120
Serial Number	TEMM191100
Configuration	VERTICAL

Motor Data X 4

Motor MFG / Frame	BALDOR / 213T
Horsepower / RPM	7.5 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	9.50 / 1.15

Test Data

	Design	Actual
Total CFM	21600	20673
Relief CFM		2302
Fan RPM	2112	1560
VFD Speed	70.4	52 Hz
RL Voltage	460	472
RL Amperage	9.50	3.82
Motor B.H.P.	3.50	3.02

Performance Data

	Design	Actual
Suction S.P.		-0.48"
Discharge S.P.		0.20"
Total SP	2.55	0.68"
SF GAIN:		1.356
OA GAIN:		1.063
RA GAIN:		1.258

Asset: VAV's Floor 2

Asset	Area Served	Type	Size	Design Max CFM	Actual Max CFM	Design Min CFM	Actual Min CFM	Design Heat CFM	Actual Heat CFM	Ak (max)
VAV-2-01A	2053	REHEAT	10	750	756	750	759	750	754	0.698
VAV-2-01B	2051	REHEAT	8	700	688	210	207	500	491	0.680
VAV-2-01C	2004	REHEAT	10	1275	1259	315	315	630	651	0.712
VAV-2-01D	2004	REHEAT	10	1100	1105	330	320	660	682	0.641
VAV-2-02	2152	REHEAT	8	750	760	165	171	330	325	0.711
VAV-2-03	2304	REHEAT	8	640	639	190	189	385	378	0.647
VAV-2-04	2803	REHEAT	8	775	757	235	245	465	473	0.625
VAV-2-05	2801	REHEAT	8	430	431	130	133	260	256	0.629
VAV-2-06	2800	REHEAT	12	1760	1699	530	544	1055	1077	0.722
VAV-2-07A	2000	REHEAT	14	2700	2673	810	841	1620	1644	0.702
VAV-2-07B	2000	REHEAT	14	2625	2632	790	828	2565	2589	0.752
VAV-2-08	2111	REHEAT	8	475	460	145	152	285	289	0.678
VAV-2-09	2112	REHEAT	8	550	530	165	160	330	325	0.630
VAV-2-10	2004	REHEAT	10	1050	1084	315	323	630	642	0.733
VAV-2-11	2003	REHEAT	8	600	601	180	180	360	360	0.681
VAV-2-12	2113	REHEAT	6	200	196	60	59	120	119	0.677
VAV-2-13	2200	REHEAT	8	525	516	160	168	315	323	0.578
VAV-2-14	2503	REHEAT	10	600	599	180	180	360	370	0.696
VAV-2-15	2522	REHEAT	6	340	330	100	97	205	210	0.662
VAV-2-16	2514	REHEAT	6	340	337	100	103	205	210	0.665
VAV-2-17	2529	REHEAT	6	350	340	105	106	210	211	0.560
VAV-2-18	2515	REHEAT	6	340	338	100	97	205	212	0.686
VAV-2-19	2501	REHEAT	8	600	589	180	178	360	357	0.675
VAV-2-20	2505	REHEAT	6	400	407	120	117	240	246	0.665
VAV-2-21	2807	REHEAT	8	700	692	210	222	420	422	0.647
VAV-2-22	2505	REHEAT	6	240	236	70	68	145	143	0.594
VAV-2-23	2614	REHEAT	6	375	380	115	121	225	232	0.589
VAV-2-24	2654	REHEAT	6	300	303	90	91	180	180	0.594
VAV-2-25	2724	REHEAT	8	500	494	150	147	300	297	0.726
VAV-2-26	2714	REHEAT	8	555	556	165	166	335	336	0.701
VAV-2-27	2602	REHEAT	10	800	785	240	235	480	470	0.676
VAV-2-28	2740	REHEAT	8	560	555	170	177	335	340	0.771
VAV-2-29	2703	REHEAT	6	300	302	90	87	180	188	0.629
VAV-2-30	2717	REHEAT	8	545	555	150	159	295	299	0.707
VAV-2-31	2704	REHEAT	8	715	711	210	215	425	421	0.714
VAV-2-32	2743	REHEAT	6	260	256	80	84	155	159	0.678
VAV-2-33	2733	REHEAT	8	550	542	165	120	330	233	0.723

NOTES:	VAV 2-01A connected load 750 scheduled cool 1000. decreased max value
	VAV 2-02: connected load 750 scheduled cool 550. Increased cool max value
	VAV 2-31: connected load 715 scheduled cool 705. Increased cool max value

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 2 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
207A-1	2000	L	10	300	330	298	0.99
207A-2	2000	L	10	300	340	290	0.97
207A-3	2000	L	10	300	298	310	1.03
207A-4	2000	L	10	300	309	302	1.01
207A-5	2000	L	10	300	333	288	0.96
207A-6	2000	L	10	300	344	280	0.93
207A-7	2000	L	10	300	321	290	0.97
207A-8	2000	L	10	300	300	304	1.01
207A-9	2000	L	10	300	321	311	1.04
VAV-2-07A				2700		2673	0.99
207B-1	2000	L	10	375	423	381	1.02
207B-2	2000	L	10	375	431	388	1.03
207B-3	2000	L	10	375	408	368	0.98
207B-4	2000	L	10	375	421	379	1.01
207B-5	2000	L	10	375	400	360	0.96
207B-6	2000	L	10	375	413	372	0.99
207B-7	2000	L	10	375	426	384	1.02
VAV-2-07B				2625		2632	1.00
208-1	2111	B	8	150	228	147	0.98
208-2	2110	A	6	125	109	120	0.96
208-3	2140	A	6	100	86	98	0.98
208-4	2140	A	6	100	87	95	0.95
VAV-2-08				475		460	0.97
209-1	2112	B	8	150	104	145	0.97
209-2	2112	B	8	150	131	145	0.97
209-3	2112	B	8	150	119	147	0.98
209-4	2112	A	6	100	56	93	0.93
VAV-2-09				550		530	0.96

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 2 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
220-1	2504	B	6	150	190	153	1.02
220-2	2504	A	6	125	101	126	1.01
220-3	2504	A	6	125	81	128	1.02
VAV-2-20				400		407	1.02
221-1	2802	A	6	75	80	79	1.05
221-2	2802	A	6	75	88	76	1.01
221-3	2805	F	6	50	136	48	0.96
221-4	2807	D	8	175	164	174	0.99
221-5	2806	D	8	150	162	157	1.05
221-6	2807	D	8	150	156	158	1.05
VAV-2-21				675		692	1.03
222-1	2618	A	8	120	170	114	0.95
222-2	2616	A	8	120	91	122	1.02
VAV-2-22				240		236	0.98
223-1	2610	B	8	150	38	154	1.03
223-2	2612	A	6	110	173	114	1.04
223-3	2614	A	6	115	193	112	0.97
VAV-2-23				375		380	1.01
224-1	2660	B	10	150	158	158	1.05
224-2	2660	B	10	150	157	145	0.97
VAV-2-24				300		303	1.01
225-1	2738	A	8	130	118	129	0.99
225-2	2734	A	8	120	125	121	1.01
225-3	2730	A	8	125	161	124	0.99
225-4	2724	A	8	125	136	120	0.96
VAV-2-25				500		494	0.99

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 2 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
226-1	2712	A	8	125	110	125	1.00
226-2	2722	A	8	130	96	131	1.01
226-3	2716	B	8	145	201	145	1.00
226-4	2714	B	8	155	205	155	1.00
VAV-2-26				555		556	1.00
227-1	2602	B	8	200	159	197	0.99
227-2	2602	B	8	150	233	147	0.98
227-3	2602	B	8	150	245	147	0.98
227-4	2601	B	8	200	200	196	0.98
227-5	2617	A	6	100	110	98	0.98
VAV-2-27				800		785	0.98
228-1	2700	A	6	135	97	135	1.00
228-2	2735	A	6	100	82	101	1.01
228-3	2740	A	6	100	81	100	1.00
228-4	2742	A	6	75	91	75	1.00
228-5	2740	A	6	100	153	96	0.96
228-6	2741	A	6	50	96	48	0.96
VAV-2-28				560		555	0.99
229-1	2703	B	8	250	246	249	1.00
229-2	2720	A	6	50	85	53	1.06
VAV-2-29				300		302	1.01
230-1	2728	A	6	80	79	83	1.04
230-2	2718	A	6	80	61	83	1.04
230-3	2727	A	6	80	86	85	1.06
230-4	2717	A	6	125	82	125	1.00
230-5	2701	A	6	80	83	82	1.03
230-6	2726	A	6	50	92	49	0.98
230-7	2725	F	6	50	129	48	0.96
VAV-2-30				545		555	1.02

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 2 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
231-1	2704	A	6	140	107	138	0.99
231-2	2710	B	8	150	200	148	0.99
231-3	2704	A	6	140	126	138	0.99
231-4	2710	B	8	150	257	149	0.99
231-5	2700	A	6	135	123	133	0.99
VAV-2-31				715		706	0.99
232-1	2748	A	10	130	140	125	0.96
232-2	2737	A	10	130	140	131	1.01
VAV-2-32				260		256	0.98
233-1	2721	A	10	140	124	146	1.04
233-2	2723	B	10	150	251	148	0.99
233-3	2729	A	10	130	122	132	1.02
233-4	2733	A	10	130	107	130	1.00
VAV-2-33				550		556	1.01
234-1	2713	A	10	120	97	116	0.97
234-2	2711	B	10	145	179	148	1.02
VAV-2-34				265		264	1.00
235-1	2802	A	6	100	105	94	0.94
235-2	2808	D	8	150	150	137	0.91
235-3	2809	F	6	50	117	50	1.00
235-4	2808	D	8	175	153	172	0.98
VAV-2-35				475		453	0.95
236-1	2202	A	6	100	72	98	0.98
236-2	2201	E	8	150	140	154	1.03
236-3	2201	E	8	150	185	158	1.05
VAV-2-36				400		410	1.03

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: AHU-3

Area: THIRD FLOOR

Supply Side

Unit Data

Manufacturer	YORK
Model Number	YCI-96X108
Serial Number	TEMM191110
Configuration	VERTICAL
No. Pre Filters / Size	12 / 24X24X2
No. Pre Filters / Size	4 / 12X24X2
No. Primary Filters / Size	12 / 24X24X4
No. Primary Filters / Size	4 / 12X24X4

Motor Data X 4

Motor MFG / Frame	BALDOR / 254T
Horsepower / RPM	15 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	18.1 / 1.15

Test Data

	Design	Actual
Total CFM	27000	26453
Min OA CFM	4500	4672
Fan RPM	2517	2442
VFD Speed	83.9	81.4
RL Voltage	460	469 VFD
RL Amperage	18.1	10.9 VFD
Motor B.H.P.	10.21	9.03

Performance Data

	Design	Actual
Suction S.P.		-3.11"
Discharge S.P.		2.17"
Total SP	6.74	5.28"
CW Coil P.D.	0.97	0.93"
HW Coil P.D.	0.05	1.03" *
Pre Filters P.D.*	0.28	* combined
Final Filters P.D.	0.67	* combined
Total ESP	3.00	3.32"
System Set Point		1.0"

Return Side

Unit Data

Manufacturer	YORK
Model Number	YCI-96X108
Serial Number	TEMM191110
Configuration	VERTICAL

Motor Data X 4

Motor MFG / Frame	BALDOR / 215T
Horsepower / RPM	10 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	12.5 / 1.15

Test Data

	Design	Actual
Total CFM	27000	27674
Relief CFM		5893
Fan RPM	2498	1703
VFD Speed	83.3	56.8
RL Voltage	460	469 VFD
RL Amperage	12.50	5.2 VFD
Motor B.H.P.	5.42	4.16

Performance Data

	Design	Actual
Suction S.P.		-0.43"
Discharge S.P.		0.25"
Discharge S.P.	2.82	0.68"
SF GAIN:		1.28
OA GAIN:		0.687
RA GAIN:		1.154

Asset: VAV's Floor 3

Asset	Area Served	Type	Size	Design Max CFM	Actual Max CFM	Design Min CFM	Actual Min CFM	Design Heat CFM	Actual Heat CFM	Ak (max)
VAV-3-01A	3061	REHEAT	10	775	797	235	243	465	474	0.69
VAV-3-01B	3060	REHEAT	10	1000	1021	300	313	600	598	0.702
VAV-3-02	3110	REHEAT	8	725	729	220	165	435	326	0.644
VAV-3-03	3120	REHEAT	10	1175	1191	355	360	705	715	0.754
VAV-3-04	3130	REHEAT	6	415	413	75	74	150	149	0.708
VAV-3-05	3350	REHEAT	8	700	714	210	212	420	424	0.682
VAV-3-06	3810	REHEAT	8	670	654	200	210	400	406	0.678
VAV-3-07	3806	REHEAT	8	670	680	200	207	400	409	0.677
VAV-3-08	3801	REHEAT	10	450	448	135	129	270	280	0.713
VAV-3-09	3800	REHEAT	14	1850	1838	555	571	1110	1133	0.762
VAV-3-10A	3000C	REHEAT	14	2700	2812	810	804	1620	1681	0.821
VAV-3-10B	3000	REHEAT	14	2625	2655	790	822	1575	1609	0.754
VAV-3-10C	3000A	REHEAT	14	1000	991	300	289	1000	1029	0.689
VAV-3-10D	3000A	REHEAT	14	1100	1117	330	333	1100	1131	0.723
VAV-3-10E	3000A	REHEAT	6	350	344	105	103	210	206	0.630
VAV-3-10F	3000A	REHEAT	8	750	748	225	232	450	468	0.677
VAV-3-11	3055	REHEAT	10	525	526	105	109	210	211	0.721
VAV-3-12	3054	REHEAT	8	450	445	135	140	270	265	0.731
VAV-3-13	3063	REHEAT	8	525	530	160	161	315	315	0.695
VAV-3-14	3115	REHEAT	8	365	364	110	109	220	219	1.095
VAV-3-15	3101	REHEAT	10	1200	1185	360	356	720	711	0.706
VAV-3-16	ELEV	REHEAT	10	1050	1061	315	323	630	641	0.664
VAV-3-17	3100	REHEAT	10	850	842	255	253	510	505	0.704
VAV-3-18	3210	REHEAT	6	625	633	190	192	375	380	0.630
VAV-3-19	3003	REHEAT	10	600	616	180	185	360	370	0.761
VAV-3-20	3319	REHEAT	6	365	365	110	113	220	223	0.649
VAV-3-21	3313	REHEAT	6	225	231	70	72	135	139	0.679
VAV-3-22	3501	REHEAT	6	355	357	105	109	215	210	0.625
VAV-3-23	3512	REHEAT	6	340	334	100	98	205	201	0.647
VAV-3-24	3521	REHEAT	6	355	360	105	108	215	217	0.65
VAV-3-25	3513	REHEAT	8	470	465	140	144	280	267	0.688
VAV-3-26	3802	REHEAT	8	550	552	165	167	330	332	0.718
VAV-3-27	3503	REHEAT	6	225	226	70	74	135	139	0.636
VAV-3-28	3508	REHEAT	10	475	477	115	121	225	227	0.693
VAV-3-29	3620	REHEAT	6	415	403	125	121	250	244	0.702
VAV-3-30	3612	REHEAT	6	370	380	110	119	220	222	0.646

NOTES:

VAV 3-04: connected load 415 scheduled 250 max. Increased max value

VAV 3-11: connected load 525 scheduled 350 max. Increased max value

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 3 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
301A-1	3060F	A	8	125	178	124	0.99
301A-2	3060F	A	8	125	187	125	1.00
301A-3	3060F	D	8	175	147	184	1.05
301A-4	3060F	D	8	175	167	184	1.05
301A-5	3060F	D	8	175	163	180	1.03
VAV-3-01A				775		797	1.03
301B-1	3060L	D	8	175	156	174	0.99
301B-2	3060L	A	8	125	257	124	0.99
301B-3	3060L	D	8	175	174	180	1.03
301B-4	3060L	D	8	175	182	178	1.02
301B-5	3060L	D	8	175	169	187	1.07
301B-6	3060L	D	8	175	170	178	1.02
VAV-3-01B				1000		1021	1.02
302-1	3110	D	8	200	110	195	0.98
302-2	3110	D	8	200	128	202	1.01
302-3	3110	D	8	200	115	205	1.03
302-4	3112	B	8	125	185	127	1.02
VAV-3-02				725		729	1.01
303-1	3120	A	6	50	113	50	1.00
303-2	3120	A	8	125	121	124	0.99
303-3	3120	A	8	125	131	131	1.05
303-4	3120	A	8	125	137	135	1.08
303-5	3120	A	8	125	141	125	1.00
303-6	3120	A	8	125	159	126	1.01
303-7	3120	A	8	125	136	130	1.04
303-8	3120	A	8	125	148	121	0.97
303-9	3120	A	8	125	146	125	1.00
303-10	3120	A	8	125	147	124	0.99
VAV-3-03				1175		1191	1.01

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 3 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
341A-1	CORR	B	8	125	180	131	1.05
341A-2	CORR	B	8	125	156	125	1.00
341A-3	CORR	B	8	125	163	118	0.94
341A-4	CORR	B	8	125	33	123	0.98
341A-5	CORR	B	8	125	134	122	0.98
341A-6	3726	F	6	50	93	53	1.06
341A-7	3727	F	6	50	76	51	1.02
341A-8	CORR	B	8	125	128	122	0.98
VAV-3-41A				850		845	0.99
341B-1	3705	A	8	125	130	125	1.00
341B-2	3705	A	8	125	53	124	0.99
341B-3	3705	A	8	125	146	133	1.06
341B-4		A	6	50	65	50	1.00
341B-5	3705	A	8	125	97	135	1.08
341B-6	3705	A	8	125	126	118	0.94
341B-7	CORR	A	8	125	158	123	0.98
341B-8		A	6	50	150	55	1.10
VAV-3-41B				850		863	1.02
342-1	3619	F	6	50	114	48	0.96
342-2	CORR	B	8	130	102	126	0.97
342-3	3709	F	6	50	87	46	0.92
342-4	CORR	B	8	130	97	130	1.00
VAV-3-42				360		350	0.97
343-1	3708	B	8	200	166	199	1.00
343-2	3707	B	8	75	90	78	1.04
VAV-3-43				275		277	1.01

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: AHU-4

Area: FOURTH FLOOR

Supply Side

Unit Data

Manufacturer	YORK
Model Number	YCI-84X126
Serial Number	TFMM191120
Configuration	VERTICAL
No. Pre Filters / Size	12 / 24X24X2
No. Pre Filters / Size	3 / 24X20X2
No. Primary Filters / Size	12 / 24X24X4
No. Primary Filters / Size	3 / 24X20X4

Motor Data X 4

Motor MFG / Frame	BALDOR / 215T
Horsepower / RPM	10.0 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	12.50 / 1.15

Test Data

	Design	Actual
Total CFM	23600	23643
Min OA CFM	3600	3636
Fan RPM	2333	2111
VFD Speed	77.8	70.4
RL Voltage	460	469 VFD
RL Amperage	12.50	7.9 VFD
Motor B.H.P.	8.07	6.32

Performance Data

	Design	Actual
Suction S.P.		-2.36"
Discharge S.P.		1.78"
Total SP	6.07	4.14"
CW Coil P.D.	0.72	0.56"
HW Coil P.D.	0.03	1.30" *
Pre Filters P.D.*	0.20	* combined
Primary Filters P.D.	0.50	* combined
Total ESP	3.00	2.28"
System Set Point		1.30"

Return Side

Unit Data

Manufacturer	YORK
Model Number	YCI-84X126
Serial Number	TFMM191120
Configuration	VERTICAL

Motor Data X 4

Motor MFG / Frame	BALDOR / 215T
Horsepower / RPM	10.0 / 1800
Rated Volts / Phase	460 / 3
Rated Amperage / SF	12.50 / 1.15

Test Data

	Design	Actual
Total CFM	23600	23843
Relief CFM		3836
Fan RPM	2591	1976
VFD Speed	86.4	65.9
RL Voltage	460	469 VFD
RL Amperage	12.50	5.2 VFD
Motor B.H.P.	4.30	4.16

Performance Data

	Design	Actual
Suction S.P.		-0.65"
Discharge S.P.		0.18"
Total SP	2.60	0.83"
SF GAIN:		0.985
OA GAIN:		0.827
RA GAIN:		0.932

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FLOOR 4 SUPPLY

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
401-1	4006	A	8	130	149	136	1.05
401-2	4008	E	10	250	316	252	1.01
401-3	4009	D	8	195	231	191	0.98
401-4	4006	D	8	200	175	209	1.05
401-5	4009	D	8	195	196	182	0.93
VAV-4-01				970		970	1.00
402-1	4012	D	10	225	214	226	1.00
402-2	4012	D	10	225	235	233	1.04
402-3	4012	D	10	225	249	231	1.03
VAV-4-02				675		690	1.02
403-1	4013	D	8	225	170	231	1.03
403-2	4013	D	8	225	166	229	1.02
403-3	4013	D	8	225	173	229	1.02
403-4	4013	D	8	150	164	141	0.94
403-5	4013	D	8	150	193	141	0.94
VAV-4-03				975		971	1.00
404A-1	4016	D	10	125	128	123	0.98
404A-2	4016	D	10	125	130	126	1.01
VAV-4-04A				250		249	1.00
404B-1	4017	D	10	175	128	172	0.98
404B-2	4017	D	10	175	134	177	1.01
404B-3	4017	D	10	175	153	179	1.02
VAV-4-04B				525		528	1.01
405A-1	4018	D	10	200	154	200	1.00
405A-2	4018	D	10	200	98	193	0.97
VAV-4-05A				400		393	0.98

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FCU-01

Area: LOADING DOCK 2150

Unit Data	
MFG	TRANE
Model Num	BCHE036
Serial Num	

Motor Data	
Motor MFG	
Horsepower	1
Motor Rpm	
Phase	1
Voltage (rated)	277
Amperage (rated)	6.73

Test Data		
	Design	Actual
SA CFM	600	656
Fan RPM	1672	1558
RA CFM	600	656
RL Voltage	277	285
RL Amperage	3.8	2.9
Suction ESP		0.21
Discharge ESP		0.10
Total ESP	0.5	0.31

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: FCU-02

Area: CHILLER UTILITY 2160

Unit Data	
MFG	TRANE
Model Num	BCHE054DBAOA3CA4
Serial Num	H24E42812

Motor Data	
Motor MFG	TRANE
Horsepower	1
Motor Rpm	1725
Phase	1
Voltage (rated)	277
Amperage (rated)	6.7

Test Data		
	Design	Actual
SA CFM	1800	1756
Fan RPM	1724	1237
RA CFM	1800	1756
RL Voltage	277	285
RL Amperage	6.73	4.6
Suction ESP		ROOM
Discharge ESP		0.19
Total ESP	1	0.19

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: EF-01

Area: GENERAL EXHAUST

Unit Data	
MFG	GREENHECK
Model Num	CUE-200HP-50-VG-1-30-X
Serial Num	24572673
Type	CRE

Motor Data	
Motor MFG	BALDOR RELIANCE
Frame	184T
Horsepower	5
Motor Rpm	1800
Phase	3
Voltage (rated)	460
Amperage (rated)	5.3
Service Factor	1

Test Data		
	Design	Actual
CFM	4855	4744
Fan RPM	1618	9 ON DIAL
RL Voltage	460	471 Avg
RL Amperage	5.3	4.9 Avg
Suction ESP		-2.3"
Total ESP	2.5	2.3"

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: EF-02

Area: GENERAL EXHAUST

Unit Data	
MFG	GREENHECK
Model Num	CUE-140HP-VG
Serial Num	
Type	CRE

Motor Data	
Motor MFG	
Frame	
Horsepower	1
Motor Rpm	2280
Phase	3
Voltage (rated)	460
Amperage (rated)	1.8
Service Factor	

Test Data		
	Design	Actual
CFM	2675	
Fan RPM	2271	
RL Voltage	460	
RL Amperage	1.8	
Suction ESP		
Total ESP	2.271	

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: EF-02 EXHAUST

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
2-1	3609	E1	6	75			0.00
2-2	3607	E1	6	100			0.00
2-3	3620	E4	8	200			0.00
2-4	3807	E1	6	75			0.00
2-5	3519	E1	6	75			0.00
2-6	3805	E3	6	150			0.00
2-7	3619	E1	6	75			0.00
2-8	3709	E1	6	75			0.00
2-9	3707	E1	6	100			0.00
2-10	3719	E1	6	75			0.00
2-11	2739	E6	10X12	100			0.00
2-12	2652	E4	8	150			0.00
2-13	2653	E1	6	75			0.00
2-14	2805	E1	6	75			0.00
2-15	2651	E1	6	75			0.00
2-16	2726	E1	6	75			0.00
2-17	2725	E1	6	75			0.00
2-18	2719	E1	6	75			0.00
2-19	2720	E1	6	75			0.00
2-20	1622	E4	8	200			0.00
2-21	1519	E1	6	75			0.00
2-22	1609	E1	6	75			0.00
2-23	1607	E1	6	100			0.00
2-24	1807	E1	6	75			0.00
2-25	1805	E1	6	75			0.00
2-26	1619	E1	6	75			0.00
2-27	1718	E1	6	75			0.00
2-28	1707	E1	6	75			0.00
2-29	1719	E1	6	75			0.00
				2675			

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: EF-05

Area: CHILLER UTILITY

Unit Data	
MFG	GREENHECK
Model Num	BSQ-160-30-X
Serial Num	24579839
Type	INLINE

Motor Data	
Motor MFG	BALDOR RELIANCE
Frame	182T
Horsepower	3
Motor Rpm	1765
Phase	3
Voltage (rated)	460
Amperage (rated)	4.2
Service Factor	1.15

Drive Data	
Motor Sheave Size	1VP50
Motor Bore Size	1.125
Fan Sheave Size	AK51
Fan Bore Size	1"
Belt CL Distance	20.0"
No of Belts	1
Belt Size	AX55

Test Data		
	Design	Actual
CFM	4000	3952
Fan RPM	1626	1660
RL Voltage	460	465VFD
RL Amperage	4.8	3.05 VFD
Suction ESP		-1.15
Total ESP	1	1.27
Brake Horse Power	1.69	2.18

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: EF-06

Area: ELECTRICAL 2101

Unit Data	
MFG	GREENHECK
Model Num	SQ-95-VG-X
Serial Num	24573944
Type	INLINE

Motor Data	
Motor MFG	VARIGREEN
Frame	56
Horsepower	0.25
Motor Rpm	1800
Phase	1
Voltage (rated)	115
Amperage (rated)	2.85
Service Factor	1.15

Test Data		
	Design	Actual
CFM	750	754
Fan RPM	1154	7.5
RL Voltage	115	123.6
RL Amperage	2.85	0.9
Suction ESP		0
Total ESP	0.3	0.08

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: EF-07

Area: ELECTRICAL 2103

Unit Data	
MFG	GREENHECK
Model Num	SQ-95-VG-X
Serial Num	24573944
Type	INLINE

Motor Data	
Motor MFG	VARIGREEN
Frame	NA
Horsepower	0.17
Motor Rpm	1725
Phase	1
Voltage (rated)	115
Amperage (rated)	2.2
Service Factor	1.15

Test Data		
	Design	Actual
CFM	500	512
Fan RPM	1347	5.5
RL Voltage	115	123.8
RL Amperage	2.2	0.7
Suction ESP		0
Total ESP	0.3	0.02

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CHILLER 1 (WATER COOLED)

UNIT DATA		
Unit Description	CH-1	
Manufacturer	TRANE	
Model Number	CVHE320	
Serial Number	L24D00965	
EVAPORATOR DATA	Design	Actual
Flow GPM	426.6	448.9
Pressure Drop	2.89 ft	3.2 FT
EWT	56	55
LWT	42	42
CONDENSER DATA	Design	Actual
Flow GPM	750	779
Pressure Drop	6.02 ft	6.5 ft
EWT	85	69
LWT	94.42	76

Asset: CHILLER 2

UNIT DATA		
Unit Description	CH-2	
Manufacturer	TRANE	
Model Number	CVHE320	
Serial Number	L24D00964	
EVAPORATOR DATA	Design	Actual
Flow GPM	426.6	434.6
Pressure Drop	2.89 ft	3.0 FT
EWT	56	55
LWT	42	42
CONDENSER DATA	Design	Actual
Flow GPM	750	773.3
Pressure Drop	6.02 ft	6.4 ft
EWT	85	74
LWT	94.42	80



National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CT-1

Unit Data	
Manufacturer	BAC
Model Num	S3E-8518-06L-2
Serial Num	14227-100

Test Data		
	Design	Actual
CW GPM	1500	1544
EWT (F)	95	85
LWT (F)	85	77

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: PCHWP-1

Unit Data	
	Actual
MFG	TACO
Model Num	3009D
Serial Num	Insulated over name plate
Service	Primary Chilled Water
Pump RPM	1760
GPM/Head	430 / 50
Impellar Diameter	7.8

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	215T
Horsepower	10
Motor RPM	1765
Phase	3
Voltage	460
Amperage	12.5
Service Factor	1.15
Efficiency	91.7
Power Factor	82

Test Data			
	Design	Actual	45 HZ
Pump Off Pressure (psi)		28	
Pump Dead Head (ft)		63	
Act. Impellar Dia (in)	7.8	7.8	
Valve Open GPM		604	
Valve Open Diff (ft)		22.8	
Discharge Pressure (ft)		78.5	73.1
Suction Pressure (ft)		55.7	59.2
Total Head Pressure (ft)	50	22.8	13.9
Final GPM	430	604	448.9
Motor Frequency (HZ)	60	60	45.0
RL Voltage	460	469 VFD	469 VFD
RL Amperage	12.5	11.2 VFD	7.53 VFD
BHP		8.96	6.02

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: PCHWP-2

Unit Data	
	Actual
MFG	TACO
Model Num	3009D
Serial Num	Insulated over name plate
Service	Primary Chilled Water
Pump RPM	1760
GPM/Head	430 / 50
Impellar Diameter	7.8

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	215T
Horsepower	10
Motor RPM	1765
Phase	3
Voltage	460
Amperage	12.5
Service Factor	1.15
Efficiency	91.7
Power Factor	82

Test Data			
	Design	Actual	46 HZ
Pump Off Pressure (psi)		28	
Pump Dead Head (ft)		63	
Act. Impellar Dia (in)	7.8	7.8	
Valve Open GPM		577.7	
Valve Open Diff (ft)		20.6	
Discharge Pressure (ft)		78.3	73.6
Suction Pressure (ft)		57.5	60.8
Total Head Pressure (ft)	50	20.6	12.8
Final GPM	430	577.7	434.6
Motor Frequency (HZ)	60	60	46
RL Voltage	460	467 VFD	470 VFD
RL Amperage	12.5	10.9 VFD	7.54 VFD
BHP		8.72	6.03

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: PCHWP-3

Unit Data	
	Actual
MFG	TACO
Model Num	3009D
Serial Num	Insulated over name plate
Service	Primary Chilled Water
Pump RPM	1760
GPM/Head	430 / 50
Impellar Diameter	7.8

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	215T
Horsepower	10
Motor RPM	1765
Phase	3
Voltage	460
Amperage	12.5
Service Factor	1.15
Efficiency	91.7
Power Factor	82

Test Data			
	Design	Actual	44.1 HZ
Pump Off Pressure (psi)		28	
Pump Dead Head (ft)		63	
Act. Impellar Dia (in)	7.8	7.8	
Valve Open GPM		622	
Valve Open Diff (ft)		23.9	
Discharge Pressure (ft)		79.5	74.6
Suction Pressure (ft)		58.0	60.09
Total Head Pressure (ft)	50	21.5	13.7
Final GPM	430	604	457
Motor Frequency (HZ)	60	60	44.1
RL Voltage	460	468 VFD	468 VFD
RL Amperage	12.5	11.1 VFD	7.68 VFD
BHP		8.88	6.14

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

CDWP-2

Unit Data	
	Actual
MFG	TACO
Model Num	4009D
Serial Num	F0446256
Service	Condenser Water
Pump RPM	1750
GPM/Head	750 / 50
Impellar Diameter	8.40

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	254T
Horsepower	15
Motor RPM	1765
Phase	3
Voltage	460
Amperage	18.1
Service Factor	1.15
Efficiency	92.4
Power Factor	83

Test Data		
	Design	Actual
Pump Off Pressure (psi)		6.2
Pump Dead Head (ft)		67
Act. Impellar Dia (in)	8.4	8.4
Valve Open GPM		927.2
Valve Open Diff (ft)		41.54
Discharge Pressure (ft)		27.02
Suction Pressure (ft)		-6.26
Total Head Pressure (ft)	50	33.28
Final GPM	750	779
Motor Frequency (HZ)	60	51.5
RL Voltage	460	496/496/494
RL Amperage	18.1	8.6/8.3/8.7
BHP		7.07

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CDWP-1

Unit Data	
	Actual
MFG	TACO
Model Num	4009D
Serial Num	F0446256
Service	Condenser Water
Pump RPM	1750
GPM/Head	750 / 50
Impellar Diameter	8.40

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	254T
Horsepower	15
Motor RPM	1765
Phase	3
Voltage	460
Amperage	18.1
Service Factor	1.15
Efficiency	92.4
Power Factor	83

Test Data		
	Design	Actual
Pump Off Pressure (psi)		6
Pump Dead Head (ft)		68.2
Act. Impellar Dia (in)	8.4	8.4
Valve Open GPM		927.2
Valve Open Diff (ft)		41.5
Discharge Pressure (ft)		23.4
Suction Pressure (ft)		-6.5
Total Head Pressure (ft)	50	29.9
Final GPM	750	773.4
Motor Frequency (HZ)	60	51.4
RL Voltage	460	471 VFD
RL Amperage	18.1	14.0 VFD
BHP		11.60

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CDWP-3

Unit Data	
	Actual
MFG	TACO
Model Num	4009D
Serial Num	F0446256
Service	Condenser Water
Pump RPM	1760
GPM/Head	750 / 50
Impellar Diameter	8.40

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	254T
Horsepower	15
Motor RPM	1765
Phase	3
Voltage	460
Amperage	18.1
Service Factor	1.15
Efficiency	92.4
Power Factor	83

Test Data		
	Design	Actual
Pump Off Pressure (psi)		6.2
Pump Dead Head (ft)		67
Act. Impellar Dia (in)	8.4	8.4
Valve Open GPM		891.2
Valve Open Diff (ft)		40.88
Discharge Pressure (ft)		27.2
Suction Pressure (ft)		-5.46
Total Head Pressure (ft)	50	32.66
Final GPM	750	765
Motor Frequency (HZ)	60	51.5
RL Voltage	460	496/496/494
RL Amperage	18.1	8.5/8.2/8.4
BHP		6.93

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: SCHWP-1

Unit Data	
	Actual
MFG	TACO
Model Num	3011D
Serial Num	Insulated over name plate
Service	SECONDARY CHILLED WATER
Pump RPM	1760
GPM/Head	500 / 100
Impellar Diameter	10.7

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	256T
Horsepower	20
Motor RPM	1765
Phase	3
Voltage	460
Amperage	24
Service Factor	1.15
Efficiency	93
Power Factor	85

Test Data			
	Design	Actual	48 HZ
Pump Off Pressure (psi)		28	
Pump Dead Head (ft)		130	
Act. Impellar Dia (in)	10.7	10.7	
Valve Open GPM		665	
Valve Open Diff (ft)		124.7	
Discharge Pressure (ft)		121.9	101.8
Suction Pressure (ft)		55.1	59
Total Head Pressure (ft)		66.8	42.8
Final GPM	500	665	502
Motor Frequency (HZ)	60	60	48
System Set Point		16 PSID	10 PSID
RL Voltage	460	464 VFD	466 VFD
RL Amperage	24	24.3 VFD	17.3 VFD
BHP		20.0	14.42

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: SCHWP-2

Unit Data	
	Actual
MFG	TACO
Model Num	3011D
Serial Num	Insulated over name plate
Service	SECONDARY CHILLED WATER
Pump RPM	1760
GPM/Head	500 / 100
Impellar Diameter	10.7

Motor Data	
	Actual
Motor MFG	BALDOR
Frame	256T
Horsepower	20
Motor RPM	1765
Phase	3
Voltage	460
Amperage	24
Service Factor	1.15
Efficiency	93
Power Factor	85

Test Data			
	Design	Actual	48 HZ
Pump Off Pressure (psi)		28	
Pump Dead Head (ft)		130	
Act. Impellar Dia (in)	10.7	10.7	
Valve Open GPM		617	
Valve Open Diff (ft)		64.7	
Discharge Pressure (ft)		120.7	102.4
Suction Pressure (ft)		55.9	59.3
Total Head Pressure (ft)	100	64.7	43.1
Final GPM	500	617	502
Motor Frequency (HZ)	60	60	48
System Set Point		16 PSID	10 PSID
RL Voltage	460	465 VFD	465 VFD
RL Amperage	24	23.4 VFD	16.3 VFD
BHP		19.5	13.58



National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CIRCUIT SETTERS

Service: CW Building Loop

60 hz									
Asset	MFG	Model	Size	Design GPM	Setting	Design Coil P.D. (feet)	Actual Coil P.D. (feet)	Final GPM	% to Design
AHU 1	TACO	ACCU-FLO	2.50	76.35	42	3.10	3.20	77.57	1.02
AHU 1	TACO	ACCU-FLO	2.50	76.35	45	3.10	3.10	76.35	1.00
AHU 2	TACO	ACCU-FLO	2.50	70.60	30	2.60	2.90	74.56	1.06
AHU 2	TACO	ACCU-FLO	2.50	70.60	30	2.60	2.70	71.94	1.02
AHU 3	TACO	ACCU-FLO	2.50	84.55	0	2.90	2.80	83.08	0.98
AHU 3	TACO	ACCU-FLO	2.50	84.55	0	2.90	2.80	83.08	0.98
AHU 4	TACO	ACCU-FLO	2.50	75.20	40	3.00	3.00	75.20	1.00
AHU 4	TACO	ACCU-FLO	2.50	75.20	45	3.00	3.00	75.20	1.00
				613.40				616.99	1.01
48 hz									
Asset	MFG	Model	Size	Design GPM	Setting	Design Coil P.D. (feet)	Actual Coil P.D. (feet)	Final GPM	% to Design
AHU 1	TACO	ACCU-FLO	2.50	76.35	42	3.10	2.11	63.02	0.83
AHU 1	TACO	ACCU-FLO	2.50	76.35	45	3.10	2.05	62.03	0.81
AHU 2	TACO	ACCU-FLO	2.50	70.60	30	2.60	1.91	60.57	0.86
AHU 2	TACO	ACCU-FLO	2.50	70.60	30	2.60	1.78	58.45	0.83
AHU 3	TACO	ACCU-FLO	2.50	84.55	0	2.90	1.85	67.49	0.80
AHU 3	TACO	ACCU-FLO	2.50	84.55	0	2.90	1.85	67.49	0.80
AHU 4	TACO	ACCU-FLO	2.50	75.20	40	3.00	1.98	61.09	0.81
AHU 4	TACO	ACCU-FLO	2.50	75.20	45	3.00	1.98	61.09	0.81
				613.40				501.24	

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: PHWP-1

Service: BOILERS

Unit Data	
	Actual
MFG	TACO
Model Num	FI3007E4DCJ2L0DX
Serial Num	F0446243
Service	BOILER
Pump RPM	1750
GPM/Head	250 / 30
Impellar Diameter	5.85

Motor Data	
	Actual
Motor MFG	BALDOR RELIANCE
Frame	182T
Horsepower	3
Motor RPM	1765
Phase	3
Voltage	460
Amperage	4.2
Service Factor	1.15
Efficiency	89.5
Power Factor	74

Test Data		
	Design	Actual
Pump Off Pressure (psi)		29.89
Pump Dead Head (ft)	32.5	33.5
Act. Impellar Dia (in)		5.85
Valve Open GPM		270.1
Valve Open Diff (ft)		25.7
Discharge Pressure (ft)		88.2
Suction Pressure (ft)		62.5
Total Head Pressure (ft)	30	25.7
Final GPM	250	270.1
RL Voltage	460	470
RL Amperage	4.2	4.11
BHP		3.16

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: PHWP-1

Service: BOILERS

Unit Data	
	Actual
MFG	TACO
Model Num	FI3007E4DCJ2L0DX
Serial Num	F0446243
Service	BOILER
Pump RPM	1750
GPM/Head	250 / 30
Impellar Diameter	5.85

Motor Data	
	Actual
Motor MFG	BALDOR RELIANCE
Frame	182T
Horsepower	3
Motor RPM	1765
Phase	3
Voltage	460
Amperage	4.2
Service Factor	1.15
Efficiency	89.5
Power Factor	74

Test Data		
	Design	Actual
Pump Off Pressure (psi)		29.56
Pump Dead Head (ft)	32.5	32.7
Act. Impellar Dia (in)		5.85
Valve Open GPM		266.5
Valve Open Diff (ft)		26.4
Discharge Pressure (ft)		89.7
Suction Pressure (ft)		63.3
Total Head Pressure (ft)	30	26.4
Final GPM	250	266.5
RL Voltage	460	467
RL Amperage	4.2	4.07
BHP		3.11

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: SHWP-1

Service: Heating

Unit Data	
	Actual
MFG	TACO
Model Num	FI2506EDGCH2L0DX
Serial Num	F0446238
Service	HEATING
Pump RPM	3500
GPM/Head	250 / 130
Impellar Diameter	6.10

Motor Data	
	Actual
Motor MFG	BALDOR RELIANCE
Frame	215T
Horsepower	15
Motor RPM	3500
Phase	3
Voltage	460
Amperage	17.5
Service Factor	1.15
Efficiency	90.2
Power Factor	89

Test Data			
	Design	60 HZ	50 HZ
Pump Off Pressure (psi)		29.40	
Pump Dead Head (ft)	150	151.2	
Act. Impellar Dia (in)		6.10	
Valve Open GPM		326	
Valve Open Diff (ft)		78.4	
Discharge Pressure (ft)		143.1	124.5
Suction Pressure (ft)		64.7	69.1
Total Head Pressure (ft)	130	78.4	55.4
Final GPM	250	326	253
Motor Frequency (HZ)	60	60	50
System Set Point		34	25
RL Voltage	460	467 VFD	468 VFD
RL Amperage	17.5	15.5 VFD	12.1 VFD
BHP		13.85	10.7

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: SHWP-1

Service: Heating

Unit Data	
	Actual
MFG	TACO
Model Num	FI2506EDGCH2L0DX
Serial Num	F0446238
Service	HEATING
Pump RPM	3500
GPM/Head	250 / 130
Impellar Diameter	6.10

Motor Data	
	Actual
Motor MFG	BALDOR RELIANCE
Frame	215T
Horsepower	15
Motor RPM	3500
Phase	3
Voltage	460
Amperage	17.5
Service Factor	1.15
Efficiency	90.2
Power Factor	89

Test Data			
	Design	Actual	50 HZ
Pump Off Pressure (psi)		34	
Pump Dead Head (ft)	150	151.2	
Act. Impellar Dia (in)		6.10	
Valve Open GPM		316	
Valve Open Diff (ft)		74.0	
Discharge Pressure (ft)		144.9	125.8
Suction Pressure (ft)		70.9	73.4
Total Head Pressure (ft)	130	74.0	52.4
Final GPM	250	316	250
Motor Frequency (HZ)	60	60	50
System Set Point		34 PSID	23 PSID
RL Voltage	460	466 VFD	469 VFD
RL Amperage	17.5	15.4 VFD	11.8 VFD
BHP		13.2	10.11

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CIRCUIT SETTERS

Service: Heating System

Asset	MFG	Model	Size	Design GPM	Setting	Design P.D.	Actual P.D.	Final GPM	% to Design
VAV-1-01	TACO	ACCU-FLO	0.75	2.10	55.00	12.25	13.04	2.17	1.03
VAV-1-03	TACO	ACCU-FLO	0.75	1.10	85.00	3.36	3.78	1.17	1.06
VAV-1-04	TACO	ACCU-FLO	0.75	1.00	90.00	2.78	3.01	1.04	1.04
VAV-1-05	TACO	ACCU-FLO	0.75	1.20	80.00	4.00	4.24	1.24	1.03
VAV-1-06	TACO	ACCU-FLO	0.75	0.60	85.00	1.00	1.01	0.60	1.00
VAV-1-07	TACO	ACCU-FLO	0.75	2.90	45.00	23.36	24.57	2.97	1.03
VAV-1-08	TACO	ACCU-FLO	0.75	2.00	55.00	11.11	12.11	2.09	1.04
VAV-1-09	TACO	ACCU-FLO	0.75	0.70	85.00	1.36	1.48	0.73	1.04
VAV-1-10	TACO	ACCU-FLO	0.75	1.20	65.00	4.00	4.63	1.29	1.08
VAV-1-11	TACO	ACCU-FLO	0.75	3.40	40.00	32.11	38.30	3.71	1.09
VAV-1-12	TACO	ACCU-FLO	0.75	1.70	1.00	8.03	7.20	1.61	0.95
VAV-1-13	TACO	ACCU-FLO	0.75	2.90	50.00	23.36	24.55	2.97	1.03
VAV-1-14	TACO	ACCU-FLO	0.75	1.30	70.00	4.69	4.80	1.31	1.01
VAV-1-15	TACO	ACCU-FLO	0.75	1.20	80.00	4.00	4.20	1.23	1.02
VAV-1-16	TACO	ACCU-FLO	0.75	1.20	80.00	4.00	4.44	1.26	1.05
VAV-1-17	TACO	ACCU-FLO	0.75	1.80	65.00	9.00	9.33	1.83	1.02
VAV-1-18	TACO	ACCU-FLO	0.75	1.70	70.00	8.03	8.52	1.75	1.03
VAV-1-19	TACO	ACCU-FLO	0.75	1.50	75.00	6.25	6.39	1.52	1.01
VAV-1-20	TACO	ACCU-FLO	0.75	2.40	45.00	16.00	16.89	2.47	1.03
VAV-1-21	TACO	ACCU-FLO	0.75	1.00	65.00	2.78	3.07	1.05	1.05
VAV-1-22	TACO	ACCU-FLO	0.75	1.20	75.00	4.00	4.16	1.22	1.02
VAV-1-23	TACO	ACCU-FLO	0.75	3.20	50.00	28.44	29.50	3.26	1.02
VAV-1-25	TACO	ACCU-FLO	0.75	1.30	80.00	4.69	4.77	1.31	1.01
VAV-1-26	TACO	ACCU-FLO	0.75	1.40	70.00	5.44	5.69	1.43	1.02
VAV-1-27	TACO	ACCU-FLO	0.75	1.10	80.00	3.36	3.78	1.17	1.06
VAV-1-28	TACO	ACCU-FLO	0.75	1.00	80.00	2.78	2.61	0.97	0.97
VAV-1-29	TACO	ACCU-FLO	0.75	0.30	90.00	0.25	0.27	0.31	1.04
VAV-1-30A	TACO	ACCU-FLO	0.75	2.40	55.00	16.00	16.45	2.43	1.01
VAV-1-30B	TACO	ACCU-FLO	0.75	2.60	55.00	18.78	19.20	2.63	1.01
VAV-1-31	TACO	ACCU-FLO	0.75	1.10	70.00	3.36	3.33	1.09	1.00
VAV-1-32	TACO	ACCU-FLO	0.75	0.90	75.00	2.25	2.34	0.92	1.02
VAV-1-33	TACO	ACCU-FLO	0.75	1.10	80.00	3.36	3.64	1.14	1.04
VAV-1-34	TACO	ACCU-FLO	0.75	1.00	75.00	2.78	2.97	1.03	1.03
VAV-1-35	TACO	ACCU-FLO	0.75	1.10	65.00	3.36	3.88	1.18	1.07
VAV-1-36	TACO	ACCU-FLO	0.75	1.00	70.00	2.78	2.98	1.04	1.04
VAV-1-37	TACO	ACCU-FLO	0.75	0.30	90.00	0.25	0.29	0.32	1.08
VAV-1-38A	TACO	ACCU-FLO	0.75	2.40	25.00	16.00	18.30	2.57	1.07
VAV-1-38B	TACO	ACCU-FLO	0.75	2.60	55.00	18.78	20.28	2.70	1.04

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CIRCUIT SETTERS

Service: Heating System

Asset	MFG	Model	Size	Design GPM	Setting	Design P.D.	Actual P.D.	Final GPM	% to Design
VAV-2-01A	TACO	ACCU-FLO	0.75	4.4	1.00	32.27	29.11	4.18	0.95
VAV-2-01B	TACO	ACCU-FLO	0.75	2.2	1.00	13.44	13.89	2.24	1.02
VAV-2-01C	TACO	ACCU-FLO	0.75	2.8	40.00	21.78	22.13	2.82	1.01
VAV-2-01D	TACO	ACCU-FLO	0.75	2.9	15.00	23.36	24.21	2.95	1.02
VAV-2-02	TACO	ACCU-FLO	0.75	1.4	80.00	5.44	5.43	1.40	1.00
VAV-2-03	TACO	ACCU-FLO	0.75	1.7	60.00	8.03	8.14	1.71	1.01
VAV-2-04	TACO	ACCU-FLO	0.75	2.0	50.00	11.11	11.55	2.04	1.02
VAV-2-05	TACO	ACCU-FLO	0.75	1.1	65.00	3.36	3.12	1.06	0.96
VAV-2-06	TACO	ACCU-FLO	1.00	4.6	40.00	12.70	13.18	4.69	1.02
VAV-2-07A	TACO	ACCU-FLO	1.00	7.1	1.00	30.25	30.90	7.18	1.01
VAV-2-07B	TACO	ACCU-FLO	1.00	11.5	1.00	79.35	70.12	10.81	0.94
VAV-2-08	TACO	ACCU-FLO	0.75	1.2	70.00	4.00	4.20	1.23	1.02
VAV-2-09	TACO	ACCU-FLO	0.75	1.4	75.00	5.44	5.80	1.44	1.03
VAV-2-10	TACO	ACCU-FLO	0.75	2.8	55.00	21.78	20.99	2.75	0.98
VAV-2-11	TACO	ACCU-FLO	0.75	1.6	70.00	7.11	7.54	1.65	1.03
VAV-2-12	TACO	ACCU-FLO	0.75	0.5	90.00	0.69	0.66	0.49	0.97
VAV-2-13	TACO	ACCU-FLO	0.75	1.4	75.00	5.44	5.74	1.44	1.03
VAV-2-14	TACO	ACCU-FLO	0.75	1.6	1.00	7.11	6.80	1.56	0.98
VAV-2-15	TACO	ACCU-FLO	0.75	0.9	65.00	2.25	2.31	0.91	1.01
VAV-2-16	TACO	ACCU-FLO	0.75	0.9	1.00	2.25	2.34	0.92	1.02
VAV-2-17	TACO	ACCU-FLO	0.75	0.9	70.00	2.25	2.10	0.87	0.97
VAV-2-18	TACO	ACCU-FLO	0.75	0.9	70.00	2.25	2.45	0.94	1.04
VAV-2-19	TACO	ACCU-FLO	0.75	1.6	55.00	7.11	7.44	1.64	1.02
VAV-2-20	TACO	ACCU-FLO	0.75	1.0	65.00	2.78	2.80	1.00	1.00
VAV-2-21	TACO	ACCU-FLO	0.75	1.8	65.00	9.00	9.22	1.82	1.01
VAV-2-22	TACO	ACCU-FLO	0.75	0.6	80.00	1.00	1.20	0.66	1.10
VAV-2-23	TACO	ACCU-FLO	0.75	1.0	80.00	2.78	3.11	1.06	1.06
VAV-2-24	TACO	ACCU-FLO	0.75	0.8	75.00	1.78	1.86	0.82	1.02
VAV-2-25	TACO	ACCU-FLO	0.75	1.3	60.00	4.69	4.72	1.30	1.00
VAV-2-26	TACO	ACCU-FLO	0.75	1.5	60.00	6.25	6.44	1.52	1.02
VAV-2-27	TACO	ACCU-FLO	0.75	2.1	45.00	12.25	13.40	2.20	1.05
VAV-2-28	TACO	ACCU-FLO	0.75	1.5	45.00	6.25	6.84	1.57	1.05
VAV-2-29	TACO	ACCU-FLO	0.75	0.8	75.00	1.78	1.70	0.78	0.98
VAV-2-30	TACO	ACCU-FLO	0.75	1.4	40.00	5.44	5.82	1.45	1.03
VAV-2-31	TACO	ACCU-FLO	0.75	1.8	20.00	9.00	9.17	1.82	1.01
VAV-2-32	TACO	ACCU-FLO	0.75	0.7	50.00	1.36	1.61	0.76	1.09
VAV-2-33	TACO	ACCU-FLO	0.75	1.4	15.00	5.44	5.67	1.43	1.02
VAV-2-34	TACO	ACCU-FLO	0.75	0.7	45.00	1.36	1.39	0.71	1.01

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CIRCUIT SETTERS

Service: Heating System

Asset	MFG	Model	Size	Design GPM	Setting	Design P.D.	Actual P.D.	Final GPM	% to Design
VAV-3-01A	TACO	ACCU-FLO	0.75	2.00	10.00	11.11	9.76	1.87	0.94
VAV-3-01B	TACO	ACCU-FLO	0.75	2.60	30.00	18.78	17.76	2.53	0.97
VAV-3-02	TACO	ACCU-FLO	0.75	1.90	55.00	10.03	10.31	1.93	1.01
VAV-3-03	TACO	ACCU-FLO	0.75	3.10	10.00	26.69	27.30	3.13	1.01
VAV-3-04	TACO	ACCU-FLO	0.75	0.70	75.00	1.36	1.28	0.68	0.97
VAV-3-05	TACO	ACCU-FLO	0.75	1.80	55.00	9.00	9.14	1.81	1.01
VAV-3-06	TACO	ACCU-FLO	0.75	1.80	50.00	9.00	8.46	1.75	0.97
VAV-3-07	TACO	ACCU-FLO	0.75	1.80	50.00	9.00	10.00	1.90	1.05
VAV-3-08	TACO	ACCU-FLO	0.75	1.20	55.00	4.00	4.24	1.24	1.03
VAV-3-09	TACO	ACCU-FLO	1.00	4.90	45.00	14.41	15.10	5.02	1.02
VAV-3-10A	TACO	ACCU-FLO	1.00	7.10	1.00	30.25	24.59	6.40	0.90
VAV-3-10B	TACO	ACCU-FLO	1.00	6.90	1.00	28.57	24.40	6.38	0.92
VAV-3-10C	TACO	ACCU-FLO	1.00	4.40	45.00	11.62	11.89	4.45	1.01
VAV-3-10D	TACO	ACCU-FLO	1.00	4.80	55.00	13.82	14.40	4.90	1.02
VAV-3-10E	TACO	ACCU-FLO	0.75	0.90	45.00	2.25	2.64	0.97	1.08
VAV-3-10F	TACO	ACCU-FLO	0.75	2.00	30.00	11.11	12.52	2.12	1.06
VAV-3-11	TACO	ACCU-FLO	0.75	0.90	85.00	2.25	2.60	0.97	1.07
VAV-3-12	TACO	ACCU-FLO	0.75	1.20	70.00	4.00	4.22	1.23	1.03
VAV-3-13	TACO	ACCU-FLO	0.75	1.40	65.00	5.44	5.66	1.43	1.02
VAV-3-14	TACO	ACCU-FLO	0.75	1.00	80.00	2.78	2.88	1.02	1.02
VAV-3-15	TACO	ACCU-FLO	0.75	3.10	15.00	26.69	25.88	3.05	0.98
VAV-3-16	TACO	ACCU-FLO	0.75	2.80	20.00	21.78	21.30	2.77	0.99
VAV-3-17	TACO	ACCU-FLO	0.75	2.20	30.00	13.44	12.75	2.14	0.97
VAV-3-18	TACO	ACCU-FLO	0.75	1.60	40.00	7.11	7.32	1.62	1.01
VAV-3-19	TACO	ACCU-FLO	0.75	1.60	45.00	7.11	7.46	1.64	1.02
VAV-3-20	TACO	ACCU-FLO	0.75	1.00	75.00	2.78	2.69	0.98	0.98
VAV-3-21	TACO	ACCU-FLO	0.75	0.60	60.00	1.00	0.94	0.58	0.97
VAV-3-22	TACO	ACCU-FLO	0.75	0.90	80.00	2.25	2.01	0.85	0.95
VAV-3-23	TACO	ACCU-FLO	0.75	0.90	60.00	2.25	2.55	0.96	1.06
VAV-3-24	TACO	ACCU-FLO	0.75	0.90	60.00	2.25	2.18	0.89	0.98
VAV-3-25	TACO	ACCU-FLO	0.75	1.20	55.00	4.00	4.32	1.25	1.04
VAV-3-26	TACO	ACCU-FLO	0.75	1.40	50.00	5.44	5.33	1.39	0.99
VAV-3-27	TACO	ACCU-FLO	0.75	0.60	1.00	1.00	1.11	0.63	1.05
VAV-3-28	TACO	ACCU-FLO	0.75	1.00	70.00	2.78	2.89	1.02	1.02
VAV-3-29	TACO	ACCU-FLO	0.75	1.10	75.00	3.36	3.44	1.11	1.01
VAV-3-30	TACO	ACCU-FLO	0.75	1.00	55.00	2.78	3.10	1.06	1.06
VAV-3-31	TACO	ACCU-FLO	0.75	1.00	80.00	2.78	2.69	0.98	0.98
VAV-3-32	TACO	ACCU-FLO	0.75	1.30	75.00	4.69	5.10	1.35	1.04

National TAB

Project: Wake County Public Health
Address: 200 Swinburne Road Raleigh, NC 27610

Asset: CIRCUIT SETTERS

Service: Heating System

Asset	MFG	Model	Size	Design GPM	Setting	Design P.D.	Actual P.D.	Final GPM	% to Design
VAV-4-01	TACO	ACCU-FLO	0.75	2.50	50.00	17.36	17.77	2.53	1.01
VAV-4-02	TACO	ACCU-FLO	0.75	1.80	65.00	9.00	10.04	1.90	1.06
VAV-4-03	TACO	ACCU-FLO	0.75	2.60	55.00	18.78	18.89	2.61	1.00
VAV-4-04A	TACO	ACCU-FLO	0.75	0.70	90.00	1.36	1.56	0.75	1.07
VAV-4-04B	TACO	ACCU-FLO	0.75	1.40	80.00	5.44	6.02	1.47	1.05
VAV-4-05A	TACO	ACCU-FLO	0.75	1.00	85.00	2.78	2.89	1.02	1.02
VAV-4-05B	TACO	ACCU-FLO	0.75	0.70	90.00	1.36	1.44	0.72	1.03
VAV-4-06A	TACO	ACCU-FLO	0.75	2.00	50.00	11.11	12.48	2.12	1.06
VAV-4-06B	TACO	ACCU-FLO	0.75	2.50	55.00	17.36	18.34	2.57	1.03
VAV-4-06C	TACO	ACCU-FLO	0.75	2.00	55.00	11.11	12.24	2.10	1.05
VAV-4-07	TACO	ACCU-FLO	0.75	2.50	20.00	17.36	18.20	2.56	1.02
VAV--4-08A	TACO	ACCU-FLO	1.00	4.00	40.00	9.60	10.56	4.20	1.05
VAV--4-08B	TACO	ACCU-FLO	1.00	4.00	15.00	9.60	9.89	4.06	1.01
VAV-4-09A	TACO	ACCU-FLO	1.00	5.20	45.00	16.22	17.42	5.39	1.04
VAV-4-09B	TACO	ACCU-FLO	1.00	3.10	55.00	5.77	6.10	3.19	1.03
VAV-4-09C	TACO	ACCU-FLO	1.00	3.10	65.00	5.77	6.21	3.22	1.04
VAV-4-09D	TACO	ACCU-FLO	0.75	2.50	55.00	17.36	18.62	2.59	1.04
VAV-4-10	TACO	ACCU-FLO	1.00	3.60	50.00	7.78	7.94	3.64	1.01
VAV-4-11	TACO	ACCU-FLO	0.75	2.00	55.00	11.11	11.36	2.02	1.01
VAV-4-12	TACO	ACCU-FLO	0.75	0.60	90.00	1.00	1.11	0.63	1.05
VAV-4-13	TACO	ACCU-FLO	0.75	2.40	65.00	16.00	16.20	2.41	1.01
VAV-4-14	TACO	ACCU-FLO	0.75	1.80	70.00	9.00	8.90	1.79	0.99
VAV-4-15	TACO	ACCU-FLO	0.75	1.80	70.00	9.00	9.89	1.89	1.05
VAV-4-16	TACO	ACCU-FLO	0.75	2.80	50.00	21.78	20.02	2.68	0.96
VAV--4-17	TACO	ACCU-FLO	0.75	0.60	1.00	1.00	1.06	0.62	1.03
VAV--4-18A	TACO	ACCU-FLO	0.75	2.60	45.00	18.78	20.12	2.69	1.04
VAV--4-18B	TACO	ACCU-FLO	0.75	2.10	45.00	12.25	13.55	2.21	1.05
VAV--4-19	TACO	ACCU-FLO	0.75	1.90	60.00	10.03	11.21	2.01	1.06
VAV--4-20	TACO	ACCU-FLO	0.75	2.20	40.00	13.44	13.89	2.24	1.02
VAV--4-21	TACO	ACCU-FLO	0.75	0.90	65.00	2.25	2.66	0.98	1.09
VAV--4-22	TACO	ACCU-FLO	0.75	2.20	45.00	13.44	14.43	2.28	1.04
VAV--4-23	TACO	ACCU-FLO	0.75	1.20	65.00	4.00	4.19	1.23	1.02

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Discharge Air Temp
VAV-1-01	1054	480	488	49.70%	91.0
VAV-1-03	1104	250	255	95.70%	88.3
VAV-1-04	1141	220	231	98.8%	87.5
VAV-1-05	1160	275	288	100.00%	86.8
VAV-1-06	1815	145	150	49.70%	92.6
VAV-1-07	1810	670	699	58.40%	91.1
VAV-1-08	1806	460	461	79.90%	90.3
VAV-1-09	1056	150	154	32.10%	91.3
VAV-1-10	1801	280	288	53.70%	91.0
VAV-1-11	1800	770	795	59.20%	90.7
VAV-1-12	1051	390	401	100.00%	80.4
VAV-1-13	1051	660	672	52.20%	91.3
VAV-1-14	1058	300	302	100.00%	87.0
VAV-1-15	1150	275	282	100.00%	87.2
VAV-1-16	1145	285	289	47.00%	89.4
VAV-1-17	1112	420	421	61.70%	90.4
VAV-1-18	1153	390	396	60.90%	90.6
VAV-1-19	1121	345	354	69.40%	91.3
VAV-1-20	1004	540	557	66.10%	91.7
VAV-1-21	1003	240	245	62.90%	91.8
VAV-1-22	1206	270	268	96.60%	88.2
VAV-1-23	1203	740	743	42.80%	89.3
VAV-1-25	1520	305	309	55.80%	91.3
VAV-1-26	1512	325	332	78.40%	91.1
VAV-1-27	1521	245	257	83.70%	90.8
VAV-1-28	1513	240	247	73.20%	91.9
VAV-1-29	1503	75	81	96.60%	89.7

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Actual LAT
VAV-1-30a	1501	545	556	71%	91.7
VAV-1-30b	1501	585	603	43.9%	92.3
VAV-1-31	1508	245	255	96.6%	88.1
VAV-1-32	CORR	210	213	63.7%	93.1
VAV-1-33	1622	245	253	94.6%	88.8
VAV-1-34	1614	220	234	67.0%	92.4
VAV-1-35	1623	245	252	60.4%	92.3
VAV-1-36	1611	235	244	63.1%	92.7
VAV-1-37	1603	75	78	47.4%	89.3
VAV-1-38a	1601	545	522	64.5%	93.0
VAV-1-38b	1602	585	608	31.3%	91.3
VAV-1-39	1608	260	269	60.0%	91.5
VAV-1-40	1700	240	237	72.7%	92.1
VAV-1-41	1724	245	250	68.3%	91.3
VAV-1-42	1710	235	249	50.3%	90.6
VAV-1-43	1723	245	255	77.5%	91.6
VAV-1-44	1713	225	232	93.4%	88.9
VAV-1-45	1703	75	104	53.8%	91.1
VAV-1-46a	1701	530	551	69.6%	89.4
VAV-1-46b	1701	565	578	55.6%	91.8
VAV-1-47	1708	335	350	62.9%	90.4
VAV-1-48	1140	150	156	55.6%	92.0
VAV-1-49	1051	1800	1868	71.7%	91.8
VAV-1-50	1506	1350	1365	31.0%	90.2
VAV-1-51	1000B	1620	1689	35.0%	89.6
VAV-1-52	1051	420			
VAV-1-53	1401	110	113	50.8%	91.2
VAV-1-54	1053	90	90	47.0%	90.0

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Actual LAT
VAV-2-01A	2053	750	758	42.8%	91.2
VAV-2-01B	2051	500	512	58.9%	89.8
VAV-2-01C	2004	630	647	57.0%	90.1
VAV-2-01D	2004	660	656	50.4%	89.9
VAV-2-02	2152	330	229	100.0%	75.4
VAV-2-03	2304	385	224	81.0%	90.2
VAV-2-04	2803	465	485	72.8%	90.7
VAV-2-05	2801	260	271	52.2%	91.5
VAV-2-06	2800	1055	1091	40.2%	91.7
VAV-2-07A	2000	1620	1674	51.9%	91.3
VAV-2-07B	2000	2565	2631	54.1%	91.2
VAV-2-08	2111	285	298	94.4%	88.8
VAV-2-09	2112	330	220	100.0%	84.3
VAV-2-10	2004	630	650	45.9%	90.2
VAV-2-11	2003	360	361	54.1%	90.8
VAV-2-12	2113	120	122	100.0%	77.3
VAV-2-13	2200	315	322	64.1%	92.2
VAV-2-14	2503	360	364	60.7%	89.3
VAV-2-15	2522	205	212	99.3%	66.6
VAV-2-16	2514	205	209	44.6%	89.9
VAV-2-17	2529	210	205	57.7%	93.3
VAV-2-18	2515	205	214	41.7%	91.5
VAV-2-19	2501	360	371	57.4%	90.4
VAV-2-20	2505	240	250	55.3%	91.3
VAV-2-21	2807	420	432	771.0%	92.0
VAV-2-22	2505	145	155	64.8%	93.3

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Actual LAT
VAV-2-23	2614	225	232	58.40%	92.7
VAV-2-24	2654	180	175	62.80%	92.8
VAV-2-25	2724	300	314	58.20%	90.4
VAV-2-26	2714	335	337	69.30%	90.6
VAV-2-27	2602	480	489	71.50%	90.5
VAV-2-28	2740	335	339	56.40%	90.5
VAV-2-29	2703	180	190	41.50%	90.4
VAV-2-30	2717	295	295	55.20%	90.9
VAV-2-31	2704	425	438	72.00%	90.5
VAV-2-32	2743	155	157	52.90%	90.5
VAV-2-33	2733	330	340	66.50%	90.2
VAV-2-34	2721	160	164	51.50%	91.7
VAV-2-35	2808	285	287	33.20%	89.9
VAV-2-36	2201	240	240	52.90%	91.6
VAV-2-37	2620	165	166	59.40%	91.0
VAV-2-38	2600	600	613	56.90%	90.7
VAV-2-39	2517	90	92	53.50%	89.4
VAV-2-40	2115	135	140	39.30%	90.1
VAV-2-41	2653	200	204	55.20%	94.6
VAV-2-42	2619	235	244	77.30%	91.9
VAV-2-43	2407	660	670	49.00%	90.2
VAV-2-44	2731	180	179	51.00%	92.8
VAV-2-45	2505	260	257	45.10%	90.4
VAV-2-46	2301	120	127	45.40%	90.1

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Actual LAT
VAV-3-01A	3061	465	458	51.40%	89.3
VAV-3-01B	3060	600	583	51.30%	89.5
VAV-3-02	3110	435	416	58.60%	90.2
VAV-3-03	3120	705	682	47.10%	89.5
VAV-3-04	3130	150	143	38.70%	90.1
VAV-3-05	3350	420	414	65.30%	90.2
VAV-3-06	3810	400	384	61.80%	90.4
VAV-3-07	3806	400	388	100.00%	85.5
VAV-3-08	3801	270	261	42.20%	89.6
VAV-3-09	3800	1110	1080	53.90%	90.4
VAV-3-10A	3000C	1620	1574	49.60%	90.6
VAV-3-10B	3000	1575	1513	49.60%	92.9
VAV-3-10C	3000A	1000	1004	30.10%	90.1
VAV-3-10D	3000A	1100	1112	31.70%	89.8
VAV-3-10E	3000A	210	204	67.10%	90.2
VAV-3-10F	3000A	450	438	67.30%	90.0
VAV-3-11	3055	210	208	100.00%	86.4
VAV-3-12	3054	270	268	47.10%	90.2
VAV-3-13	3063	315	309	58.30%	91.3
VAV-3-14	3115	220	211	99.20%	83.0
VAV-3-15	3101	720	694	60.90%	89.8
VAV-3-16	ELEV	630	613	46.50%	89.9
VAV-3-17	3100	510	507	51.10%	89.1
VAV-3-18	3210	375	356	63.70%	90.2
VAV-3-19	3003	360	354	84.10%	85.9
VAV-3-20	3319	220	215	43.00%	90.9
VAV-3-21	3313	135	133	85.40%	87.8
VAV-3-22	3501	215	212	100.00%	86.3
VAV-3-23	3512	205	193	43.50%	89.7

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Actual LAT
VAV-3-24	3521	215	202	52.80%	93.0
VAV-3-25	3513	280	278	59.10%	89.9
VAV-3-26	3802	330	314	99.60%	85.0
VAV-3-27	3503	135	127	42.20%	90.2
VAV-3-28	3508	225	219	46.20%	89.3
VAV-3-29	3620	250	240	47.10%	89.4
VAV-3-30	3612	220	215	88.20%	88.1
VAV-3-31	3621	240	228	88.30%	89.7
VAV-3-32	3611	295	290	72.10%	92.0
VAV-3-33	3603	135	127	48.00%	89.2
VAV-3-34A	CORR 3601	450	426	59.40%	92.5
VAV-3-34B	CORR 3601	450	439	63.30%	89.3
VAV-3-35	CORR 3600	220	210	79.10%	91.6
VAV-3-36	3720	245	239	50.20%	89.3
VAV-3-37	3712	230	220	66.60%	92.5
VAV-3-38	3721	245	233	93.60%	87.3
VAV-3-39	3711	310	294	56.00%	90.5
VAV-3-40	3703	135	126	48.20%	89.5
VAV-3-41A	CORR 3701	510	487	58.40%	89.5
VAV-3-41B	3705	510	505	70.90%	87.7
VAV-3-42	CORR 0700	215	203	66.50%	92.8
VAV-3-43	3708	165	171	68.30%	90.5
VAV-3-44	3608	150	138	80.40%	91.3
VAV-3-45	3808	330	322	44.50%	90.0
VAV-3-46	CORR 3501	340	330	50.70%	90.0
VAV-3-47	3321	90	86	38.60%	88.2
VAV-3-50	3804	175	173	43.60%	90.1

Boiler set point 160

VAV supply air temp is being limited to 90 °F

VAV	Area Served	Design Heat CFM	Actual Heat CFM	Valve Positon	Actual LAT
VAV-4-01	4009	580	536	52.70%	90.1
VAV-4-02	4012	405	379	60.40%	89.7
VAV-4-03	4013	585	553	42.40%	89.7
VAV-4-04A	4016	150	141	48.80%	88.7
VAV-4-04B	4017	315	301	100.00%	86.1
VAV-4-05A	4018	240	226	44.50%	89.7
VAV-4-05B	4019	150	142	37.30%	90.6
VAV-4-06A	4600	455	429	52.50%	88.7
VAV-4-06B	4600	575	550	54.00%	90.2
VAV-4-06C	OPEN	460	432	55.80%	89.2
VAV-4-07	OPEN	570	551	62.00%	89.1
VAV-4-08A	4800	920	863	33.00%	90.4
VAV-4-08B	4800	920	882	47.00%	91.3
VAV-4-09A	4400	1200	1150	46.90%	90.5
VAV-4-09B	4400	720	675	47.40%	89.3
VAV-4-09C	4400	720	684	99.30%	82.1
VAV-4-09D	4400	575			
VAV-4-10	4101	875	825	69.90%	92.3
VAV-4-11	4012	450	428	47.60%	88.7
VAV-4-12	4007	130	127	33.50%	88.2
VAV-4-13	4014A	550	517	68.20%	92.0
VAV-4-14	4014B	420	396	52.50%	89.2
VAV-4-15	4020A	410	386	58.10%	91.0

