

National TAB

Project: IBP 6275 - Chicago School (Plano, TX)
Address: 6275 West Plano Parkway Plano, TX 75093

Asset: SUPPLY, EXHAUST, or RETURN

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
F1-1	120	G3	16X6	235	[1]	[1]	#VALUE!
F1-2	120	G3	16X6	235	[1]	[1]	#VALUE!
F1-3	120	G3	16X6	235	[1]	[1]	#VALUE!
F1-4	120	G3	16X6	235	[1]	[1]	#VALUE!
F1-5	120	G3	16X6	235	[1]	[1]	#VALUE!
F1-6	120	G3	16X6	235	[1]	[1]	#VALUE!
FPB-1N-1				1410	1800	1377	0.98
F2-1	183	C3	10	240	150	240	1.00
F2-2	183	C3	10	240	120	233	0.97
F2-3	183	S4	10	100	188	95	0.95
F2-4	183	C3	10	240	240	216	0.90
F2-5	183	C3	10	240	187	223	0.93
F2-6	125	C3	10	310	168	318	1.03
FPB-1N-2				1370	1053	1325	0.97
F3-1	182	C3	10	240	284	241	1.00
F3-2	182	S4	10	100	282	105	1.05
F3-3	182	C3	10	240	309	262	1.09
F3-4	182	C3	10	240	341	259	1.08
F3-5	182	C3	10	240	355	250	1.04
FPB-1N-3				1060	1571	1117	1.05
F4-1	181	C3	10	240	169	231	0.96
F4-2	181	S4	10	100	124	96	0.96
F4-3	181	C3	10	240	534	234	0.98
F4-4	181	C3	10	240	329	233	0.97
FPB-1N-4				820	1156	794	0.97

NOTES:

[1] UNABLE TO READ INDIVIDUAL DIFFUSERS DUE TO FURNITURE BELOW DUCT. ALL DIFFUSERS SERVE MAIN RECEPTION AREA.

UNIT WAS CALIBRATED AND TOTAL WAS BALANCED FOR TOTAL CFM BY TRAVERSE.

National TAB

Project: IBP 6275 - Chicago School (Plano, TX)

Address: 6275 West Plano Parkway Plano, TX 75093

Asset: SUPPLY, EXHAUST, or RETURN

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
V7-1	133	A1	10	250	277	245	0.98
VAV-1N-7				250	277	245	0.98
V8-1	128	A1	8	100	103	97	0.97
V8-2	124	G3	10X10	150	147	139	0.93
V8-3	128	A1	8	100	114	108	1.08
VAV-1N-8				350	364	344	0.98
V9-1	122	S1	8	80	158	82	1.03
V9-2	123	S1	8	80	156	81	1.01
V9-3	121	G3	10X10	200	409	212	1.06
V9-4	121	G3	10X10	200	370	192	0.96
V9-5	121A	G3	10X10	75	156	81	1.08
VAV-1N-9				635	1249	648	1.02
V10-1	135	A1	8	65	62	60	0.92
V10-2	134	A1	8	65	81	71	1.09
VAV-1N-10				130	143	131	1.01
V11-1	145	A1	8	250	274	251	1.00
VAV-1N-11				250	274	251	1.00
V12-1	138	G3	10X10	200	133	204	1.02
V12-1	138	G3	10X10	200	261	206	1.03
VAV-1N-12				400	394	410	1.03
V13-1	136	S4	10	135	113	131	0.97
V13-2	136	S4	10	135	77	123	0.91
V13-3	136	S4	10	135	131	133	0.99
V13-4	136	S4	10	135	113	135	1.00
VAV-1N-13				540	434	522	0.97

