

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: Punchlist
Function: Test, Adjust, & Balance
Date: 01/14/2026
Completed By: National TAB

PROJECT
01-12-26 WAWA #6610 AYLETT, VA

12065 KING WILLIAM ROAD

AYLETT , VA 23009

Client

Wawa
260 West Baltimore Pike

Wawa, PA 19063

National TAB

Project: 01-12-26 WAWA #6610 AYLETT, VA

Table Of Contents

Section	Page #
Remarks	3

Issue List

- Duct Dampers EF-2
- RTU-1 Alarm



01-12-26 WAWA #6610 AYLETT, VA

Project Issue Information

Issue Name : Duct Dampers EF-2
Description : There are no duct dampers for the exhausts of EF-2, serving Food Service and BOH. Currently balanced out to total airflow.
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Open
Priority : Medium **Asset Tag :**
Originated Date : 01/14/2026 - John Barresi - National TAB



01-12-26 WAWA #6610 AYLETT, VA

Project Issue Information

Issue Name : RTU-1 Alarm
Description : Unit giving Alarm 91.
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Open
Priority : Low **Asset Tag :**
Originated Date : 01/14/2026 - John Barresi - National TAB

Project Issue File Details

