

SEAL PENETRATIONS IN DRAFTSTOPPING CURTAIN AIR-TIGHT. REFER TO ARCH DRAWINGS FOR LOCATION AND CONSTRUCTION OF DRAFTSTOPPING CURTAIN.
MEAL DELIVERY CANOPY. SEE ARCHITECTURAL.
KITCHEN
COOLER
FREEZER
SERVICE
FLEX
PHYSICAL PLAY
TECH CLOSET
TEAM MEMBER ROOM
WOMENS
MENS
VESTIBULE
SERVING
ENTRY VEST
TO AC#3 SENSOR #1. SEE 2/M-501.
TO AC#3 SENSOR #2. SEE 2/M-701.
AIR CURTAIN MOUNTED ABOVE CEILING, CENTERED ON DOOR. SEE SHEET M-301.
TYPE 'FF' FILTERED RETURN GRILLE LOCATED IN LAY-IN CEILING ADJACENT TO AD#2. GRILLE IS NOT DUCTED.
PROVIDE WITH FACTORY MAGNETIC DOOR SWITCH CONTROL. LOCATE MAGNETIC CONTACT TYPE DOOR SWITCH IN DOOR FRAME ON STRIKE SIDE