

**GENERAL NOTES**

A. REFER TO SHEET M0.1 FOR LEGENDS, ABBREVIATIONS, AND GENERAL NOTES.

**KEY NOTES**

- 1 EXISTING TO REMAIN.
- 2 NEW LOCATION OF RELOCATED AIR DEVICE. FIELD VERIFY EXACT LOCATION. DUCT ROUTING RECONNECT WITH SAME SIZE DUCT. INSULATE TO MATCH EXISTING. COORDINATE WITH EXISTING CONDITIONS. REBALANCE EXISTING AIR DEVICES TO SPECIFIED CFM.
- 3 FIELD VERIFY EXACT ROUTING OF REFRIGERANT LINES. ROOFTOP CONDENSING UNIT TO BE LOCATED 10' MINIMUM FROM ROOF EDGE.
- 4 ROUTE PVC CONDENSATE TO CONNECT TO APPROVED DRAIN - SEE PLUMBING PLANS.
- 5 PROVIDE 36x18 DYNAMIC STYLE FIRE DAMPER WITH MESH SCREEN ON EXTERIOR SIDE OF WALL.
- 6 NEW EXHAUST FAN - FIELD COORDINATE EXACT LOCATION WITH EXISTING CONDITIONS AND OTHER TRADES. FINAL LOCATION TO BE COORDINATED WITH STRUCTURAL REINFORCING. LOCATE MINIMUM 10' FROM ROOF EDGE PER CODE.
- 7 EXISTING TO REMAIN AIR DEVICE TO BE REBALANCED TO NEWLY SPECIFIED CFM.
- 8 NOT USED
- 9 NOT USED
- 10 DUCT UP TO NEW EXHAUST FAN ON ROOF. CONNECT TO NEW HOOD. WRAP DUCT WITH FIRE RATED ENCLOSURE TO REDUCE CLEARANCE TO COMBUSTIBLES. LOCATE FAN 10' MINIMUM FROM ROOF EDGE.
- 11 COORDINATE NEW LOCATION FOR HOOD SUPPRESSION SYSTEM AND EMERGENCY SHUT OFF SWITCH WITH FIELD CONDITIONS. SWITCH SHALL NOT BE LOCATED ON SALES FLOOR. BUT SHOULD BE LOCATED NEAR THE HOODS AT 48" A.F.F. VERIFY EXACT LOCATION WITH KITCHEN EQUIPMENT SUPPLIER.
- 12 FIELD COORDINATE ROUTING WITH EXISTING CONDITIONS. LOCATE DUCT TIGHT TO BOTTOM OF STEEL. TYPICAL FOR ALL DUCTS IN OPEN CEILING UNLESS OTHERWISE NOTED.
- 13 NOT USED
- 14 NOT USED
- 15 PROVIDE 12x12 LOUVER STYLE TRANSFER GRILLE ON EACH SIDE OF WALL EQUAL TO TITUS 350FL. INSTALL GRILLES WITH LOUVERS IN UP POSITION.
- 16-41 NOT USED
- 42 CONNECT TO EXISTING DUCT AS REQUIRED. FIELD VERIFY EXISTING DUCT AND PROVIDE TRANSITIONS AS REQUIRED.
- 43-50 NOT USED
- 51 HOOD ANSUL PULL STATION LOCATION FOR HOOD H2. PULL STATION SHOULD BE 42-48" ABOVE THE FINISHED FLOOR IN THE MAIN PATH OF EGRESS. A MINIMUM OF 10 FEET FROM THE HOOD AND A MAXIMUM OF 20 FEET. COORDINATE FINAL LOCATION WITH OWNER. PROVIDE NAMEPLATE AT STATION WITH HOOD NUMBER AND LOCATIONS.
- 52 HOOD ANSUL PULL STATION FOR HOOD H1A AND H1B TO UTILIZE COMBINED ANSUL FIRE SUPPRESSION SYSTEM AND CONTROLS. PULL STATION SHOULD BE 42-48" ABOVE THE FINISHED FLOOR IN THE MAIN PATH OF EGRESS. A MINIMUM OF 10 FEET FROM THE HOOD AND A MAXIMUM OF 20 FEET. COORDINATE FINAL LOCATION WITH OWNER. PROVIDE NAMEPLATE AT STATION WITH HOOD NUMBER AND LOCATIONS.



EXECUTED BY: VAF  
 REVIEWED BY: BR

OWNER:  
 KRUGER  
 1511 EXECUTIVE PARKWAY WESTERVILLE, OHIO 43081  
 DALLAS  
 MINNEAPOLIS  
 SEATTLE

CREATING EXTRAORDINARY SPACES  
 www.cr-architects.com  
 800.469.4949

CONSULTANTS

OWNER

FACILITY ENGINEERING  
 1111 EXECUTIVE PARKWAY WESTERVILLE, OHIO 43081  
 WWW.KROGER.COM

ISSUE/REVISION

05/01/2018	90% KROGER REVIEW
06/04/2018	BID/PERMIT
06/14/2018	ADDENDUM NO. 2
07/31/2018	BULLETIN NO. 1
10/02/2018	BULLETIN NO. 3
01/30/2019	BULLETIN NO. 5

PROJECT TITLE  
 REMODEL

**N-881**

5161 HAMPSTEAD VILLAGE W.  
 NEW ALBANY, OH 43054

COMMISSION NO. 518304  
 ISSUE DATE 5/31/2018

SHEET TITLE  
 HVAC  
 PLAN

SHEET NO.  
**M1.1**

© 2015 Cole+Russell Architects, Inc.

THIS DOCUMENT IS THE PROPERTY OF COLE+RUSSELL ARCHITECTS, INC. NEITHER THE DOCUMENT NOR THE INFORMATION CONTAINED HEREIN IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF COLE+RUSSELL ARCHITECTS, INC.  
 PROJECT: NEW ALBANY, OHIO  
 DATE: JANUARY 15, 2018 10:28 AM