

PlanGrid Task Report - Jul 11, 2025

Prepared by Will Turnbough

Jul 11, 2025

Description

2 tasks in this report.

Contents

#615 [REFG 508] [NEW] WIC/WIF panel penetrations.....	2
#605 [CNTL 999] [NEW] RTU Tempering Kits.....	4

#615 [REFG 508] [NEW] WIC/WIF panel penetrations.

Status

Open

Created

Oct 3, 2024 12:38 PM
will@nationaltab.com

Type

Planned Work

Last Updated

Jul 11, 2025 2:19 PM

List

TAB Punch List

Description

WIF/WIC penetrations are not sealed inside with silicone and above ceiling panel with 2 layers of ¼" foam tape 12" above panel at time of inspection.

Comments

Item sent to NORLAKE-Not a Prairie item

Prairie Office Mar 6, 2025

This is in reference to all the conduits coming into and out of the boxes... it is a Prairie item

Mark Schutt Mar 11, 2025

Brian stated these were done at the time of his recent visit. We have requested a photo confirming.

Prairie Office Apr 11, 2025

Please post pictures showing the conduit and refrigeration lines exiting the WIC/WIF.

Stephen Tassinaro May 8, 2025

This has been confirmed complete. No issues have been sent to the call center. additional photos from another pending visit to follow.

Prairie Office May 12, 2025

No silicone caulk or foam tape is present.

Will Turnbough Jul 11, 2025

Photos



20250501_161708_photo

Prairie Office

May 1, 2025 3:17 PM



20250501_161650_photo

Prairie Office

May 1, 2025 3:16 PM



20250501_161620_photo
Prairie Office
May 1, 2025 3:16 PM



20250501_161542_photo
Prairie Office
May 1, 2025 3:15 PM

#605 [CNTL 999] [NEW] RTU Tempering Kits

Status

Open

Start Date

Sep 25, 2024

Type

Planned Work

Created

Sep 25, 2024 3:37 PM
will@nationaltab.com

List

TAB Punch List

Last Updated

Jul 11, 2025 2:19 PM

Description

Tempering kits are installed but not wired as they are intended for Lennox units. TRANE units installed.

Loose wires in controls
compartments as result.

Comments

Waiting on Trane to find a fix

Steve Gosch Sep 30, 2024

This issue is confirmed to be ongoing between Chick-fil-A and Scott Rowley from TRANE- This is not a mechanical contractor issue

Prairie Office Oct 23, 2024

Documentation will need to be uploaded if this issue is to be closed.

Stephen Tassinaro May 8, 2025

HVAC contractor, Prairie Contractors not sure what documentation National TAB re-opened this item for. HVAC contractor will reach out to Scott Rowley to see what this is and why we are still being held up for an item that had to do with Trane and CFA. Any possible documentation will be uploaded if available at that time

Prairie Office May 12, 2025

Follow up sent to see if HVAC has been able to get any kind of answer on this from Trane.

Prairie Office May 12, 2025
