

Engineering Report and Calculation Package

Prepared by: VC Engineering, LLC

Email: vcinfo@vceng.biz

Phone: 312-206-2896

REI – Rooftop Unit Replacement Project

Store No. 017

2962 El Camino Real

Tustin, CA 92782

Date: March 14, 2022

Table of Contents

Engineering Report	3
Structural Drawings	14
Gravity Calculations	18
Anchorage Calculations	43
New Unit Specifications	64

VC ENGINEERING, LLC

Structural Engineering Consulting

Cameron Young, P.E.
Wittler Young Co. Inc. (WYHVAC)
2400 Forney Street
Los Angeles, CA 90031

RE: REI Store #017
Structural Analysis of Roof Structure for Replacement Mechanical Equipment
VC Engineering Project #22036

Dear Mr. Young,

VC Engineering is pleased to present this report of our structural analysis of the existing roof structure to support new replacement mechanical rooftop units on the at the store address indicated on the cover page. This report includes a summary of the services we have provided, a discussion of relevant data gathered, calculations and our conclusions regarding the structural capacity of the existing roof structure.

BACKGROUND

WYHVAC indicated to VC Engineering that they intend to remove and replace (13) existing mechanical rooftop units. VC Engineering was contacted to perform a structural analysis of the existing roof structural members to support the new loads imposed from the removal and replacement of the rooftop units.

OBSERVATIONS AND DISCUSSION

VC Engineering performed a site visit to the building to observe the existing structural framing and observed a total of (13) mechanical units on the roof. Based on email correspondence from WYHVAC, VC Engineering understands that all RTU's are intended to be replaced with new units installed at the same location as the existing units. VC Engineering will rely on the accuracy of our field measurements and structural data collected in order to perform our structural analysis. All units are screened by the existing parapet walls in every direction.

The existing roof construction appeared to be panelized and consisted of $\frac{3}{4}$ " plywood deck spanning to 2x4 sub purlins spaced at 24" on center. The sub purlins are supported by glulam beams and girders that span to HSS8x8 steel columns. Supplemental 4x4 beams are located at the edges of the RTU's for additional support. Refer to the existing framing plan on the structural drawings for additional information. The local governing 2019 California Building Code with local amendments is used to determine the code prescribed loads on the roof structure.

Existing Unit Information		New Unit Information				
RTU	Total Operating Weight (lbs)	Lennox Model #	Operating Weight (lbs)	Curb Adapter Weight (lbs)	Total Operating Weight (lbs)	Total Weight Difference (lbs)
1	1200	KHB122H4E	1401	235	1636	436
2	1200	KHB122H4E	1401	235	1636	436
3	1200	KHB122H4E	1401	235	1636	436
4	1200	KHB122H4E	1401	235	1636	436
5	1200	KHB122H4E	1401	235	1636	436
6	1200	KHB122H4E	1401	235	1636	436
7	1200	KHB122H4E	1401	235	1636	436
8	1200	KHB122H4E	1401	235	1636	436
9	1200	KHB122H4E	1401	235	1636	436
10	1200	KHB122H4E	1401	235	1636	436
11	1200	KHB122H4E	1401	235	1636	436
12	535	KHB060H4E	867	215	1082	547
13	750	KHB074S4T	890	0	890	140

Reference the table above for new unit information. New Lennox units are proposed to be installed at the same location as the existing units indicated above. The operating weights indicated above include all accessories and operating weights of the unit as provided to VC Engineering in an email correspondence from WYHVAC.

CONCLUSION

VC Engineering performed a structural analysis of the existing framing to support the code prescribed loads as well as the loads imposed by the new mechanical units and determined that the existing structural framing is adequate. See attached gravity and anchorage calculations in this report for additional information. This analysis is based on the new units located in the same location as the existing units to be removed.

Please feel free to contact me with any questions.

Sincerely,



Kali Dickerson P.E.
VC Engineering, LLC





Photograph 1 – Aerial view of store via Google Maps



Photograph 2 – Overall view of store from parking lot



Photograph 3 – Overall view typical exposed structural framing



Photograph 4 – Overall view typical exposed structural framing



Photograph 5 – Overall view at underside of typical RTU



Photograph 6 – Overall view of units on roof. Screened in all directions by existing parapet walls



Photograph 7 – Overall photo of existing parapet wall



Photograph 8 – RTU #1-11





Photograph 9 – RTU #12. (RTU 13 Not Pictured)

Structural Drawings



Gravity Calculations







Typical 6.75x21 GLB and 6.75x24 GLB

Mar 14, 2022 at 12:35 PM
untitled.r2d





Member Shapes

Mar 14, 2022 at 12:34 PM
untitled.r2d



Material

Mar 14, 2022 at 12:35 PM
untitled.r2d



Loads: BLC 2, DLsu

Dead Load Superimposed = $12 \text{ psf} \times 40 \text{ ft} = 480 \text{ plf}$

Mar 14, 2022 at 12:32 PM

untitled.r2d





Loads: BLC 3, DLrtu

Dead Load RTU & Curb = $1636 + 150 = 1786$ lb

Mar 14, 2022 at 12:37 PM

untitled.r2d



Loads: BLC 4, RLL

Roof Live Load = 12 psf x 40 ft = 480 plf

Mar 14, 2022 at 12:34 PM

untitled.r2d

Beam: **M2**

Shape: **6.75X21FS**

Material: **24F-1.8E DF Balanced**

Length: **28 ft**


I Joint: **N5**

J Joint: **N6**

Envelope

Code Check: **0.879 (LC 2)**

Report Based On 100 Sections



AWC NDS-12: ASD Code Check

Max Bending Check **0.879 (LC 2)** Max Shear Check **0.445 (LC 2)** Max Defl Ratio **L/229**
 Location **14.141 ft** Location **28 ft** Location **14.141 ft**
 Equation **3.9-3** Span **1**

CD **1.25** RB **12.444** CL **0.962** CV **0.894**
 Cr **1** Cfu **1.07** CP **0.138**

	(ksi)	Cm	Ct	CF
Fc'	0.276	1	1	1
Ft'	1.375	1	1	1
Fb'	2.681	1	1	1
Fv'	0.331	1	1	
E'	1800	1	1	

Out In
 Lb **28 ft** **28 ft**
 le/d **49.778** **16**
 Sway **No** **No**
 Le-Bending Top **28 ft**
 Le-Bending Bot **28 ft**

Beam: **M1**

Shape: **6.75X24FS**

Material: **24F-1.8E DF Balanced**

Length: **52 ft**


I Joint: **N1**

J Joint: **N4**

Envelope

Code Check: **0.773 (LC 2)**

Report Based On 100 Sections




AWC NDS-12: ASD Code Check

Max Bending Check **0.773 (LC 2)** Max Shear Check **0.600 (LC 2)** Max Defl Ratio **L/335**
 Location **46.222 ft** Location **46.222 ft** Location **25.737 ft**
 Equation **3.9-3** Span **2**

CD **1.25** RB **2.514** CL **0.999** CV **0.829**
 Cr **1** Cfu **1.07** CP **0.999**


	(ksi)	Cm	Ct	CF
Fc'	1.998	1	1	1
Ft'	1.375	1	1	1
Fb'	2.487	1	1	1
Fv'	0.331	1	1	
E'	1800	1	1	

Lb **1 ft** In **1 ft**
 le/d **1.778** **0.5**
 Sway **No** **No**
 Le-Bending Top **1 ft**
 Le-Bending Bot **1 ft**




Loads: BLC 1, DLsw

		Mar 14, 2022 at 12:56 PM
	Typical 3.125x21 GLB	Typical GLB Beam.r2d




Member Shape

Mar 14, 2022 at 1:02 PM
Typical GLB Beam.r2d



		Mar 14, 2022 at 1:03 PM
	Material	Typical GLB Beam.r2d



Loads: BLC 2, DLsu

		Mar 14, 2022 at 12:59 PM
	Dead Load Superimposed = $10 \text{ psf} \times 8 \text{ ft} = 80 \text{ plf}$	Typical GLB Beam.r2d



Dead Load RTU 11

RTU = 1,636 lb

Curb = 150 lb

Total = 1,786 lb

Length = 10 ft

Load = $1786 / 2 / 10 \text{ ft} = 178 \text{ plf}$

Dead Load RTU 12

RTU = 1,082 lb

Curb = 150 lb


Total = 1,232 lb

Tributary to GLB 3.125x21 = 1/3 Weight

Load = $1232 / 3 = 407 \text{ lb}$

Loads: BLC 3, DLrtu

		Mar 17, 2022 at 3:28 PM
	Dead Load RTU 11 = 178 plf Dead Load RTU 12 = 407 lb	Typical GLB Beam.r2d



Loads: BLC 4, RLL

		Mar 14, 2022 at 1:01 PM
	Roof Live Load = $17.6 \text{ psf} \times 8 \text{ ft} = 141 \text{ plf}$	Typical GLB Beam.r2d

Beam: **M1**

Shape: **3.125X21FS**

Material: **24F-1.8E DF Balanced**

Length: **40 ft**


I Joint: **N2**

J Joint: **N3**

Envelope

Code Check: **0.978 (LC 2)**

Report Based On 100 Sections



AWC NDS-12: ASD Code Check

Max Bending Check **0.978 (LC 2)** Max Shear Check **0.436 (LC 2)** Max Defl Ratio **L/139**
 Location **18.99 ft** Location **0 ft** Location **19.798 ft**
 Equation **3.9-3** Span **1**

CD **1.25** RB **5.08** CL **0.996** CV **0.932**
 Cr **1** Cfu **1.16** CP **0.996**

	(ksi)	Cm	Ct	CF
Fc'	1.991	1	1	1
Ft'	1.375	1	1	1
Fb'	2.795	1	1	1
Fv'	0.331	1	1	
E'	1800	1	1	

Lb **1 ft** In **1 ft**
 le/d **3.84** **0.571**
 Sway **No** **No**
 Le-Bending Top **1 ft**
 Le-Bending Bot **1 ft**

Deflection Calculation

Code: CBC Table 1604.3 Serviceability

Date: 3/16/2022

Project: REI 017

Member

Size	3.125x21		
Span	40.00	ft	
L/240	2.000	in	RLL Limit
L/180	2.667	in	DL+RLL Limit

Load Case

Deflection


DL	1.616	in	Dead Load Deflection
0.5 x DL	0.808	in	Dead Load Deflection due to Creep per CBC Table 1604.3 Note D
RLL	1.843	in	Short Term Live Load Deflection

0.5DL+RLL	2.651	in	
L/180	2.667	in	

Check **Ok** **2.651 in < 2.667 in**


RLL	1.843	in	
L/240	2.000	in	

Check **Ok** **1.843 in < 2.000 in**




Typical 4x4 Joist

Mar 14, 2022 at 1:11 PM
Typical 4x4 Joist.r2d




Member Shape

Mar 14, 2022 at 1:12 PM
Typical 4x4 Joist.r2d




Material

Mar 14, 2022 at 1:12 PM
Typical 4x4 Joist.r2d




Loads: BLC 2, DLsu

		Mar 14, 2022 at 1:11 PM
	Dead Load Superimposed = 10 psf x 2 ft = 20 plf	Typical 4x4 Joist.r2d



Loads: BLC 3, DLrtu

		Mar 14, 2022 at 1:10 PM
	Dead Load RTU & Curb = $1636 + 150 / 2 \text{ Sides} / 10 \text{ ft} = \dots$	Typical 4x4 Joist.r2d



Loads: BLC 4, RLL

		Mar 14, 2022 at 1:10 PM
	Roof Live Load = 20 psf x 2 ft = 40 plf	Typical 4x4 Joist.r2d

Beam: **M1**

Shape: **4X4**

Material: **DF (E) 1000 Fb**

Length: **8 ft**


I Joint: **N2**

J Joint: **N3**

Envelope

Code Check: **0.842 (LC 2)**

Report Based On 100 Sections



AWC NDS-12: ASD Code Check

Max Bending Check **0.842 (LC 2)** Max Shear Check **0.312 (LC 1)** Max Defl Ratio **L/167**
 Location **4.202 ft** Location **8 ft** Location **4.04 ft**
 Equation **3.9-3** Span **1**

CD **1.25** RB **1.852** CL **1**
 Cr **1.15** Cfu **1** CP **0.99**

	(ksi)	Cm	Ct	CF
Fc'	2.134	1	1	1.15
Ft'	1.266	1	1	1.5
Fb'	2.156	1	1	1.5
Fv'	0.162	1	1	
E'	1700	1	1	

Out In
 Lb **1 ft** **1 ft**
 le/d **3.429** **3.429**
 Sway **No** **No**
 Le-Bending Top **1 ft**
 Le-Bending Bot **1 ft**

Deflection Calculation

Code: CBC Table 1604.3 Serviceability

Date: 3/16/2022

Project: REI 017

Member

Size	4x4		
Span	8.00	ft	
L/240	0.400	in	RLL Limit
L/180	0.533	in	DL+RLL Limit

Load Case

Deflection

DL	0.401	in	Dead Load Deflection
0.5 x DL	0.201	in	Dead Load Deflection due to Creep per CBC Table 1604.3 Note D
RLL	0.173	in	Short Term Live Load Deflection

0.5DL+RLL	0.374	in	
L/180	0.533	in	

Check **Ok** **0.374 in < 0.533 in**

RLL	0.173	in	
L/240	0.400	in	

Check **Ok** **0.73 in < 0.400 in**

Anchorage Calculations



ATC Hazards by Location

Search Information

Address:	El Camino Real, Tustin, CA, USA
Coordinates:	33.7251061, -117.8034263
Elevation:	81 ft
Timestamp:	2022-03-13T23:00:32.031Z
Hazard Type:	Seismic
Reference Document:	ASCE7-16
Risk Category:	II
Site Class:	D-default



Basic Parameters

Name	Value	Description
S_S	1.275	MCE_R ground motion (period=0.2s)
S_1	0.456	MCE_R ground motion (period=1.0s)
S_{MS}	1.53	Site-modified spectral acceleration value
S_{M1}	* null	Site-modified spectral acceleration value
S_{DS}	1.02	Numeric seismic design value at 0.2s SA
S_{D1}	* null	Numeric seismic design value at 1.0s SA

* See Section 11.4.8

▼Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F_a	1.2	Site amplification factor at 0.2s
F_v	* null	Site amplification factor at 1.0s
CR_S	0.938	Coefficient of risk (0.2s)
CR_1	0.93	Coefficient of risk (1.0s)
PGA	0.532	MCE_G peak ground acceleration
F_{PGA}	1.2	Site amplification factor at PGA
PGA_M	0.639	Site modified peak ground acceleration

T _L	8	Long-period transition period (s)
SsRT	1.275	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.36	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	1.505	Factored deterministic acceleration value (0.2s)
S1RT	0.456	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.49	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGAd	0.615	Factored deterministic acceleration value (PGA)

* See Section 11.4.8

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.

ATC Hazards by Location

Search Information

Address: El Camino Real, Tustin, CA, USA
Coordinates: 33.7251061, -117.8034263
Elevation: 81 ft
Timestamp: 2022-03-13T23:00:04.855Z
Hazard Type: Wind



ASCE 7-16

MRI 10-Year 66 mph
 MRI 25-Year 71 mph
 MRI 50-Year 77 mph
 MRI 100-Year 81 mph
 Risk Category I 89 mph
 Risk Category II 95 mph
 Risk Category III 102 mph
 Risk Category IV 106 mph

ASCE 7-10

MRI 10-Year 72 mph
 MRI 25-Year 79 mph
 MRI 50-Year 85 mph
 MRI 100-Year 91 mph
 Risk Category I 100 mph
 Risk Category II 110 mph
 Risk Category III-IV 115 mph

ASCE 7-05

ASCE 7-05 Wind Speed 85 mph

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are interpolated from data provided in ASCE 7 and rounded up to the nearest whole integer. Per ASCE 7, islands and coastal areas outside the last contour should use the last wind speed contour of the coastal area – in some cases, this website will extrapolate past the last wind speed contour and therefore, provide a wind speed that is slightly higher. NOTE: For queries near wind-borne debris region boundaries, the resulting determination is sensitive to rounding which may affect whether or not it is considered to be within a wind-borne debris region.

Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the [https://hazards.atcouncil.org/#!/wind?lat=33.7251061&lng=-117.8034263&address=El Camino Real%2C Tustin%2C CA%2C USA](https://hazards.atcouncil.org/#!/wind?lat=33.7251061&lng=-117.8034263&address=El%20Camino%20Real%20Tustin%20CA%20USA)

This website does not imply approval by the governing banking code bodies responsible for banking code approval and interpretation for the building site described by latitude/longitude location in the report.

Seismic Force Minimum Anchorage Calculation

New Mechanical Unit Input

Lennox			Brand
KHB122H4E			Model Number
Wp	1176	lb	Wp - Operating Weight (Includes all accessories)
Lx	124	in	Long Dimension of New Unit
Ly	60	in	Short Dimension of New Unit
H	47	in	Height of New Unit

New Mechanical Unit Curb Adapter Input

Lx_ca	97	in	Long Dimension of Curb Adapter
Ly_ca	56	in	Short Dimension of Curb Adapter
Weight	235	lb	Weight of Curb Adapter

Seismic Parameters

Sds	1.020	g	Short Period Spectral Acceleration
ap	2.5		Air-Side HVAC - Component Amplification Factor
Rp	6.0		Air-Side HVAC - Component Response Modification Factor
Wp	1176	lb	Component Operating Weight
Ip	1.0		Component Importance Factor
z/h	1.0		Height of Structure/Unit Ratio


Seismic Force Calculation

Fpmin	360	lb
Fp	600	lb
Fpmax	1919	lb

Existing Curb and Adaptor Curb Information

h1	12	in
h2	17	in
h3	23.5	in
h4	52.5	in


Seismic Force, Fp 600 lb



Seismic Force Minimum Anchorage Calculation

New Mechanical Equipment Anchorage

Axy	1	ea	Anchors at Each Corner
Ax	4	ea	Add'l Anchors Long Dimension
Ay	2	ea	Add'l Anchors Short Dimension
At	16	ea	Total Anchors



Anchor Coordinates		
Location	x (in)	y (in)
1	0.0	0.0
2	19.4	0.0
3	38.8	0.0
4	58.2	0.0
5	77.6	0.0
6	97.0	0.0
7	0.0	56.0
8	19.4	56.0
9	38.8	56.0
10	58.2	56.0
11	77.6	56.0
12	97.0	56.0
13	0.0	18.7
14	0.0	37.3
15	0.0	56.0
16	97.0	18.7
17	97.0	37.3
18	97.0	56.0

Unit COG	
x (in)	y (in)
48.5	28.0

Anchor COG	
x (in)	y (in)
48.5	28.0

Structural Forces Acting at Unit COG			
Eh	600	lb	Eh = Qe
Ev	240	lb	Ev = (0.2 x Sds x D)

Load Combination - 0.6D+0.7E = 0.6D+0.7(Eh-Ev)
Produces maximum uplift and shear

Seismic Force Minimum Anchorage Calculation

2. Curb Adapter to Existing Curb Check

Anchorage Selection

Select Screw	#10-16 HWH		
Spacing	8	in	
Screws Long Side (Interior)	11	total	
Screws Short Side (Interior)	6	total	
Screws at Edge Group	4	each corner, each side	
Top Sheet Thickness	0.048 (18ga)	in	Design for 18ga
Bottom Sheet Thickness	0.048 (18ga)	in	Design for 18ga
Allowable Shear per screw	331	lb	(Note: Pullover does not govern capacity)

Resolve Horizontal and Vertical Forces

E _h	600	lb	Strength Level Seismic Force
V _a	420	lb	Service Level Seismic Force
Force Each Side	210	lb	V _a /2
Screws Each Side	14	total	Refer to structural drawings
Horiz Force per Screw	31	lb	

Resolve Vertical Forces

Vertical CG of Force	40.5	in	(h ₂ +h ₃) - See Diagram on Page 1
Service Level EQ Force	420	lb	Service Level Seismic Force, V _a
Moment	17,003	lb-in	Moment = V _a x (h ₂ +h ₃)
Lever Arm btw Edge Groups	44	in	Lever Arm = L _{y_ca} - 6in - 6in
Vertical Force from Moment per Edge Group	386	lb	Moment/Lever Arm
Vertical Force from Moment per Screw	97	lb	

Total Force	101	lb	$\sqrt{H^2 + V^2} + E_v$
Ratio	31%	Passes	

Seismic Force Minimum Anchorage Calculation

3. Existing Curb to Base Structure

T_{Ω}	62	lb	Strength Level Tension
T_a	43	lb	Service Level Tension = $T_{\Omega} \times 0.7$
V_{Ω}	38	lb	Strength Level Shear
V_a	27	lb	Service Level Shear = $V_{\Omega} \times 0.7$

Analysis of Existing Anchors

Select Anchor Type	1/4"		Lag Screw at Corners and Middle
Select Depth of Embed	2	in	Assume 8d Minimum Embed
Select Side Member Thickness	> 3 1/2	in	
Select Species	DF		
Specific Gravity, G	0.50		
Withdrawal Capacity per inch	225	lb/in	NDS Table 11.2A
Shear Capacity	120	lb	NDS Table 11J

W	450	lb	Nominal Withdrawl (Tension) Capacity
Cd	1.6		Load Duration for EQ Load
$W' = W \times Cd$	720	lb	Allowable Tension for Single Anchor

Z_{\perp}	120	lb	Nominal Shear Capacity
Cd	1.6		Load Duration for EQ Load
$Z' = Z_{\perp} \times Cd$	192	lb	Allowable Shear for Single Anchor

T_a/W'	6%		Tension Ratio
V_a/Z'	14%		Shear Ratio

$T_a/W' + V_a/Z'$	20%	<	70%	Passes
Combined Tension and Shear Ratio				

Bolt Pattern Force Distribution

Results Summary

A summary of the results is shown below.

Bolt Force Summary

The resultant axial and shear forces on each bolted joint are given below:

Bolt #	Ptrn #	Ptrn Type	Axial Force	Shear Force
1	1	Rectangle	-119.5 lbf	37.5 lbf
2	1	Rectangle	-59.3 lbf	37.5 lbf
3	1	Rectangle	1.0 lbf	37.5 lbf
4	1	Rectangle	61.3 lbf	37.5 lbf
5	1	Rectangle	-119.5 lbf	37.5 lbf
6	1	Rectangle	61.3 lbf	37.5 lbf
7	1	Rectangle	-119.5 lbf	37.5 lbf
8	1	Rectangle	61.3 lbf	37.5 lbf
9	1	Rectangle	-119.5 lbf	37.5 lbf
10	1	Rectangle	61.3 lbf	37.5 lbf
11	1	Rectangle	-119.5 lbf	37.5 lbf
12	1	Rectangle	61.3 lbf	37.5 lbf
13	1	Rectangle	-119.5 lbf	37.5 lbf
14	1	Rectangle	-59.3 lbf	37.5 lbf
15	1	Rectangle	1.0 lbf	37.5 lbf
16	1	Rectangle	61.3 lbf	37.5 lbf

Forces and Moments at Pattern Centroid

The applied forces and moments are translated to the centroid of the pattern.

The forces at the centroid are simply the sum of the applied forces:

$F_{c,x} = 0$ lbf sum of the forces in the X-direction

$F_{c,y} = 600$ lbf sum of the forces in the Y-direction

$F_{c,z} = -466$ lbf sum of the forces in the Z-direction

The moments at the centroid are:

$M_{c,x} = -31,500$ in*lbf moments at centroid about X-axis

$M_{c,y} = 0$ in*lbf moments at centroid about Y-axis

$M_{c,z} = 0$ in*lbf moments at centroid about Z-axis

Pattern Properties Summary

The properties of the pattern are detailed below:

$A_{cmb} = 1.24 \text{ in}^2$ combined area of bolts in the pattern

$x_c = 48.5 \text{ in}$ X-coordinate of the pattern centroid

$y_c = 28.0 \text{ in}$ Y-coordinate of the pattern centroid

$I_{c,x} = 756.022 \text{ in}^4$ centroidal moment of inertia about X-axis

$I_{c,y} = 1,749.838 \text{ in}^4$ centroidal moment of inertia about Y-axis

$I_{c,p} = 2,505.86 \text{ in}^4$ centroidal polar moment of inertia


Pattern Properties

This section details the properties of the bolt pattern. These pattern properties determine how the applied forces distribute among the individual bolts.

Bolt Pattern Geometry

The pattern properties are determined based on the pattern geometry. The specified bolt sizes and locations are shown in the table below, as well the distances of the bolts from the pattern centroid:

Bolt #	Thread	Area [in ²]	x [in]	y [in]	r.x [in]	r.y [in]	r.xy [in]
1	3/8-16	0.0775	0.0	56.0	-48.5	28.0	56.002
2	3/8-16	0.0775	0.0	37.333	-48.5	9.333	49.39
3	3/8-16	0.0775	0.0	18.667	-48.5	-9.333	49.39
4	3/8-16	0.0775	0.0	0.0	-48.5	-28.0	56.002
5	3/8-16	0.0775	19.4	56.0	-29.1	28.0	40.383
6	3/8-16	0.0775	19.4	0.0	-29.1	-28.0	40.383
7	3/8-16	0.0775	38.8	56.0	-9.7	28.0	29.633
8	3/8-16	0.0775	38.8	0.0	-9.7	-28.0	29.633
9	3/8-16	0.0775	58.2	56.0	9.7	28.0	29.633
10	3/8-16	0.0775	58.2	0.0	9.7	-28.0	29.633
11	3/8-16	0.0775	77.6	56.0	29.1	28.0	40.383
12	3/8-16	0.0775	77.6	0.0	29.1	-28.0	40.383
13	3/8-16	0.0775	97.0	56.0	48.5	28.0	56.002
14	3/8-16	0.0775	97.0	37.333	48.5	9.333	49.39
15	3/8-16	0.0775	97.0	18.667	48.5	-9.333	49.39
16	3/8-16	0.0775	97.0	0.0	48.5	-28.0	56.002



Pattern Properties Summary

The properties of the pattern were calculated based on the areas and locations of the bolts:

$A_{cmb} = 1.24 \text{ in}^2$ combined area of bolts in the pattern

$x_c = 48.5 \text{ in}$ X-coordinate of the pattern centroid

$y_c = 28.0 \text{ in}$ Y-coordinate of the pattern centroid

$I_{c,x} = 756.022 \text{ in}^4$ centroidal moment of inertia about X-axis

$I_{c,y} = 1,749.838 \text{ in}^4$ centroidal moment of inertia about Y-axis

$I_{c,p} = 2,505.86 \text{ in}^4$ centroidal polar moment of inertia

Bolt Pattern Centroid

Applied forces and moments are translated to the pattern centroid before distributing forces among individual bolts. The bolt pattern is treated as if it were a beam, where the centroid of the pattern is like the neutral axis of the beam.

The pattern centroid is calculated as:

$$x_c = \frac{\sum_i x_i A_i}{\sum_i A_i} = 48.5 \text{ in} \qquad y_c = \frac{\sum_i y_i A_i}{\sum_i A_i} = 28.0 \text{ in}$$

where A_i is the bolt area and x_i and y_i are the x- and y- bolt locations, respectively.

Bolt Pattern Moment of Inertia

The moments of inertia of the pattern about the x- and y- axes are calculated as:

$$I_{c.x} = \sum_i r_{c.y,i}^2 A_i = 756.022 \text{ in}^4 \quad I_{c.y} = \sum_i r_{c.x,i}^2 A_i = 1,749.838 \text{ in}^4$$

where A_i is the bolt area and $r_{c.x,i}$ and $r_{c.y,i}$ are the x- and y- distances of the bolt from the centroid, respectively.

The polar moment of inertia of the pattern about the centroid is calculated as:

$$I_{c.p} = \sum_i r_{c.xy,i}^2 A_i = \sum_i (r_{c.x,i}^2 + r_{c.y,i}^2) A_i = I_{c.x} + I_{c.y} = 2,505.86 \text{ in}^4$$

It should be noted that these calculations are directly analogous to the calculation of the centroid of a cross section, moment of inertia of a cross section, and polar moment of inertia of a cross section.

Forces and Moments at Centroid

The applied forces and moments are translated to the centroid of the bolt pattern. Once forces and moments at the centroid are calculated, they can be used to calculate the forces acting on individual bolted joints.

Applied Forces and Moments




The applied forces are listed below:

Force #	Fx	Fy	Fz	Lx	Ly	Lz
1	0.0 lbf	600.0 lbf	0.0 lbf	48.5 in	28.0 in	52.5 in
2	0.0 lbf	0.0 lbf	-706.0 lbf	48.5 in	28.0 in	52.5 in
3	0.0 lbf	0.0 lbf	240.0 lbf	48.5 in	28.0 in	52.5 in

The applied moments are listed below:

Moment #	Mx	My	Mz
----------	----	----	----

The applied forces and moments are plotted on the next page.



Forces and Moments at Pattern Centroid

The applied forces and moments are translated to the centroid of the pattern. Once forces and moments at the centroid are calculated, they can be used to calculate the forces acting on individual bolted joints.

The forces at the centroid are simply the sum of the applied forces:

$F_{c,x} = 0$ lbf sum of the forces in the X-direction

$F_{c,y} = 600$ lbf sum of the forces in the Y-direction

$F_{c,z} = -466$ lbf sum of the forces in the Z-direction

The moments at the centroid are:

$M_{c,x} = -31,500$ in*lb moments at centroid about X-axis

$M_{c,y} = 0$ in*lb moments at centroid about Y-axis

$M_{c,z} = 0$ in*lb moments at centroid about Z-axis

The forces at the centroid are calculated as the sum of all applied forces:

$$\bar{F}_c = \sum_i \bar{F}_i$$

The moments at the centroid are calculated as the sum of all applied moments, plus the sum of the cross product of each applied force with the vector from the centroid to the location of that applied force:

$$\bar{M}_c = \sum_i \bar{M}_i + \sum_i (\bar{R}_{c,i} \times \bar{F}_i)$$

Individual Bolt Forces

This section details the axial and shear forces acting on each individual bolt in the pattern.

Bolt Force Summary

The resultant axial and shear forces on each bolted joint are given below:

Bolt #	Ptrn #	Ptrn Type	Axial Force	Shear Force
1	1	Rectangle	-119.5 lbf	37.5 lbf
2	1	Rectangle	-59.3 lbf	37.5 lbf
3	1	Rectangle	1.0 lbf	37.5 lbf
4	1	Rectangle	61.3 lbf	37.5 lbf
5	1	Rectangle	-119.5 lbf	37.5 lbf
6	1	Rectangle	61.3 lbf	37.5 lbf
7	1	Rectangle	-119.5 lbf	37.5 lbf
8	1	Rectangle	61.3 lbf	37.5 lbf
9	1	Rectangle	-119.5 lbf	37.5 lbf
10	1	Rectangle	61.3 lbf	37.5 lbf
11	1	Rectangle	-119.5 lbf	37.5 lbf
12	1	Rectangle	61.3 lbf	37.5 lbf
13	1	Rectangle	-119.5 lbf	37.5 lbf
14	1	Rectangle	-59.3 lbf	37.5 lbf
15	1	Rectangle	1.0 lbf	37.5 lbf
16	1	Rectangle	61.3 lbf	37.5 lbf

Axial Force Calculation

The axial forces on each bolted joint are shown in the table below:

Bolt #	Area	P_ax total	P_z_FZ	P_z_MX	P_z_MY
1	0.0775 in ²	-119.527 lbf	-29.125 lbf	-90.402 lbf	0.0 lbf
2	0.0775 in ²	-59.259 lbf	-29.125 lbf	-30.134 lbf	0.0 lbf
3	0.0775 in ²	1.009 lbf	-29.125 lbf	30.134 lbf	0.0 lbf
4	0.0775 in ²	61.277 lbf	-29.125 lbf	90.402 lbf	0.0 lbf
5	0.0775 in ²	-119.527 lbf	-29.125 lbf	-90.402 lbf	0.0 lbf
6	0.0775 in ²	61.277 lbf	-29.125 lbf	90.402 lbf	0.0 lbf
7	0.0775 in ²	-119.527 lbf	-29.125 lbf	-90.402 lbf	0.0 lbf
8	0.0775 in ²	61.277 lbf	-29.125 lbf	90.402 lbf	0.0 lbf
9	0.0775 in ²	-119.527 lbf	-29.125 lbf	-90.402 lbf	0.0 lbf
10	0.0775 in ²	61.277 lbf	-29.125 lbf	90.402 lbf	0.0 lbf
11	0.0775 in ²	-119.527 lbf	-29.125 lbf	-90.402 lbf	0.0 lbf
12	0.0775 in ²	61.277 lbf	-29.125 lbf	90.402 lbf	0.0 lbf
13	0.0775 in ²	-119.527 lbf	-29.125 lbf	-90.402 lbf	0.0 lbf
14	0.0775 in ²	-59.259 lbf	-29.125 lbf	-30.134 lbf	0.0 lbf
15	0.0775 in ²	1.009 lbf	-29.125 lbf	30.134 lbf	0.0 lbf
16	0.0775 in ²	61.277 lbf	-29.125 lbf	90.402 lbf	0.0 lbf

The equations used to calculate each axial force component are:

$$P_{z.FZ} = \frac{F_{c.z}A}{\sum_i A_i} \quad \text{Z-force on bolt due to direct force in Z}$$

$$P_{z.MX} = \frac{M_{c.x}r_{c.y}}{I_{c.x}} \cdot A \quad \text{Z-force on bolt due to MX about centroid}$$

$$P_{z.MY} = \frac{-M_{c.y}r_{c.x}}{I_{c.y}} \cdot A \quad \text{Z-force on bolt due to MY about centroid}$$

The total axial force on an individual bolted joint is the sum of the axial force components:

$$P_{axial} = P_{z.FZ} + P_{z.MX} + P_{z.MY}$$

Shear Force Calculation

The shear forces on each bolted joint are shown in the table below:

Bolt #	Area	P_shr total	P_x_FX	P_y_FY	P_x_MZ	P_y_MZ
1	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
2	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
3	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
4	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
5	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
6	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
7	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
8	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
9	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
10	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
11	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
12	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
13	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
14	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
15	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf
16	0.0775 in ²	37.5 lbf	0.0 lbf	-37.5 lbf	0.0 lbf	0.0 lbf

The equations used to calculate each shear force component are:

$$P_{x.FX} = \frac{-F_{c.x}A}{\sum_i A_i} \quad \text{X-force on bolt due to direct force in X}$$

$$P_{y.FY} = \frac{-F_{c.y}A}{\sum_i A_i} \quad \text{Y-force on bolt due to direct force in Y}$$

$$P_{xy.MZ} = \frac{M_{c.z}r_{c.xy}}{I_{c.p}} \cdot A \quad \text{XY-force on bolt due to MZ about centroid}$$


$$P_{x.MZ} = P_{xy.MZ} \cdot \sin \theta \quad \text{X-force on bolt due to MZ about centroid}$$

$$P_{y.MZ} = -P_{xy.MZ} \cdot \cos \theta \quad \text{Y-force on bolt due to MZ about centroid}$$

The total shear force on an individual bolted joint is calculated as the vector sum of the X- components plus the Y- components:

$$P_{shear} = \sqrt{(P_{x.FX} + P_{x.MZ})^2 + (P_{y.FY} + P_{y.MZ})^2}$$

Bolt shear forces are displayed below. Applied forces and moments are shown in blue, and resultant shear forces on the individual bolts are shown in red.



New Unit Specifications



Project Submittal

Project Name: REI 17 Tustin CA
Project Number: 272071
Project Altitude: 138
Project Location:
2962 El Camino Real
Tustin, California US

Date: 2/11/2022
Quote: 201431A
Roof Top Units: 13
Split Systems: 0

Customer: Recreational Equipment Inc
Engineer: Pending Engineer
National Account: Rei

Table of Contents

Tag	Qty	Model	Description
<u>RTU 1-11</u>	11	KHB122H4E	KHB122H4E-G 10T CONF E=12.3
<u>RTU 12</u>	1	KHB060H4E	KHB060H4E-G 5T CONF H=16.0
<u>RTU 13</u>	1	KHB074S4T	KHB074S4T-G 6T CONF E=11.0
<u>Miscellaneous Items</u>			

Revit® Building Information Modeling (BIM) - [Click here](#)

AutoCAD® Templates - [Click here](#)



Project Submittal

Tag: RTU 1-11
 Model: KHB122H4E - KHB122H4E-G 10T CONF E=12.3

UNIT OVERVIEW										
Voltage	IEER EER	IPLV	HSPF	MCA/MOC P (amp)	Gross Cooling Ttl/Sens (MBH)	Net Cooling Ttl/Sens (MBH)	Supply Air Flow (cfm)	ESP/TSP (in.WC)	EAT DB/WB (°F)	LAT DB/WB (°F)
460V 3Ph 60Hz	14.8 12.3			28 / 35	130.1 / 95.0	121.2 / 86.0	4,000	1.00 / 1.34	80.0 / 67.0	57.3 / 56.2

COOLING

Cooling Performance			Temperatures (DB/WB °F)		
Gross Cooling (Ttl/Sens)	130.1 / 95.0 MBH		Ambient	95.0	
Net Cooling (Ttl/Sens)	121.2 / 86.0 MBH		Entering	80.0	
Coil Moisture Removal	33.11 lb/hr		Leaving - (Coil)	57.3	
System Moisture Removal	33.11 lb/hr		Leaving - (Unit)	59.5	
				67.0	
				56.2	
				57.0	

ARI Performance		Compressors		Refrigerant		Condensate Drain	
ARI Cooling	121.0 / 118.0 MBH	Cooling Stages	2	Type	R-410A	Qty	1
ARI Power	9,600 W	Compressor Qty	2	Charge	30 LBS. 0 OZ.	Size	1 in.
		Compressor RLA	15.6 amp			Pipe Thread	npt

HEATING

Heating Performance		Temperatures (DB/WB °F)	
HP Output @ Design	70.8 MBH	HP Design	17.0
COP (High/Low)	3.6 / 2.4	HP Heat Rise @ Design	0.0
HP Power (High/Low)	9.5 / 8.6 kW	Leaving	16.4

VENTILATION

Air Flow (cfm)		Supply Fan		Air Resistance (in.WC)	
Supply	4,000	Nominal Power	3.75 hp	Total	1.34
	0	Required Power	3.75 hp	Ext Supply	1.00
		Drive Type	MSAV Direct Drive		
		Speed	0		
		Motor Torque			

AIR RESISTANCE - OPTIONS/ACCESSORIES (in.WC)

Wet Coil	Humiditrol	Heat	Economizer	Filters	Diffuser	Exhaust	ERW
0.15			0.19				

ELECTRICAL

Voltage	460V 3Ph / 60Hz	Compressor RLA	15.6 amp
MCA	28 amp	Cooling FLA Total	24.1 amp
MOCP	35 amp	Condenser FLA	4.2 amp
Condenser Power	806 W	Supply Fan FLA	4.3 amp
Oper Range-Nom Volt	+/- 10%		

ADDITIONAL DATA

Cabinet	124.38 in. x 60.12 in. x 46.88 in.	Total Weight	1,401 lb
Downflow Supply	20.0 in. x 28.0 in.	Base Unit Net Weight	1,301 lb
Downflow Return	24.0 in. x 27.0 in.	OAS/Econ Weight	83 lb
Filters	(4) 20.0 in. x 25.0 in. x 2.0 in.		
Sound Rating	85 dBA		



Project Submittal

Tag: RTU 1-11

Factory Installed Options

- High Performance Economizer Upgrade Factory Installed
- Single Enthalpy Economizer
- Standard Cap, Std Packaging
- Unit Orientation Downflow
- MSAV Direct Drive
- 440V/460V/480V 3Phase
- 175 Amp Terminal Block Factory Installed
- Supply Motor - 3.75 Hp - DirectPlus w/MSAV
- Barometric Relief Damper (Fac)
- GFCI Factory Installed/Field Wired
- BACnet Module (Fac)
- Tube and Fin Coil System Factory Installed
- 2" MERV4 - Std. Filter Factory Installed

Field Installed Accessories

Catalog Number	Qty	Description
53W45	11	Power Exhaust Fan Field Installed
13T06	11	Combination Coil/Hail Guards Field Installed
97W23	11	Bacnet Sensor With Display Field installed
50W61	44	2" MERV8 - Filter Field Installed
87N53	11	CO2 Sensors - Wall-mount, off-white plastic cover, no display Field Installed

Product Features

Cabinet

- Durable Outdoor Enamel Paint Finish
- Totally Enclosed Outdoor Fan Motor
- PVC Coated Fan Guard
- Corrosion-Resistant Removable, Reversible Drain Pan
- Isolated Compressor Compartment

Cooling System

- Scroll Compressor
- Expansion Valves
- High Capacity Driers
- High Pressure Switch (Manual Reset)
- Crankcase Heater
- System can operate from 30°F to 125°F without any additional controls
- Pre-charged Refrigeration System
- Internal Pressure Relief Valve
- Thermostat Control – 2 Stages of Cooling

Control System

- Fan and Limit Controls
- Overload Protection


Warranty

- Limited warranty on compressor of 5 years
- Limited warranty on High Performance Economizer of 5 years
- Limited warranty on all other components of 1 year
- See Limited Warranty Certificate included with unit for details




Project Submittal


Corner Weights (lb)								Center of Gravity (in.)			
AA		BB		CC		DD		EE		FF	
Base	Max	Base	Max	Base	Max	Base	Max	Base	Max	Base	Max
316	365	273	316	288	333	339	392	56.50	55.50	25.50	26.50




TOP VIEW



END VIEW




SIDE VIEW




SIDE VIEW
(Horizontal Openings)

OUTDOOR AIR HOOD DETAIL



UNIT CLEARANCES



¹ Unit Clearance	A		B		C		D		Top Clearance
	in.	mm	in.	mm	in.	mm	in.	mm	
Service Clearance	60	1524	36	914	36	914	60	1524	Unobstructed
Minimum Operation Clearance	36	914	36	914	36	914	36	914	

NOTE - Entire perimeter of unit base requires support when elevated above the mounting surface.

¹ **Service Clearance** - Required for removal of serviceable parts.

Minimum Operation Clearance - Required clearance for proper unit operation.



Project Submittal

Tag: RTU 12
 Model: KHB060H4E - KHB060H4E-G 5T CONF H=16.0

UNIT OVERVIEW										
Voltage	SEER EER	IPLV	HSPF	MCA/MOC P (amp)	Gross Cooling Ttl/Sens (MBH)	Net Cooling Ttl/Sens (MBH)	Supply Air Flow (cfm)	ESP/TSP (in.WC)	EAT DB/WB (°F)	LAT DB/WB (°F)
460V 3Ph 60Hz	16 12.5		8.5	15 / 20	62.5 / 48.5	60.1 / 46.1	2,092	0.75 / 0.85	80.0 / 67.0	57.9 / 57.2

COOLING

Cooling Performance			Temperatures (DB/WB °F)		
Gross Cooling (Ttl/Sens)	62.5 / 48.5 MBH		Ambient	95.0	
Net Cooling (Ttl/Sens)	60.1 / 46.1 MBH		Entering	80.0	
Coil Moisture Removal	13.18 lb/hr		Leaving - (Coil)	57.9	
System Moisture Removal	13.18 lb/hr		Leaving - (Unit)	59.0	
				67.0	57.2
				57.2	57.6

ARI Performance		Compressors		Refrigerant		Condensate Drain	
ARI Cooling	59.4 / 58.0 MBH	Cooling Stages	2	Type	R-410A	Qty	1
ARI Power	4,700 W	Compressor Qty	1	Charge	20 LBS. 0 OZ.	Size	1 in.
		Compressor RLA	7.2 amp			Pipe Thread	npt

HEATING

Heating Performance		Temperatures (DB/WB °F)	
HP Output @ Design	33.2 MBH	HP Design	17.0
COP (High/Low)	3.7 / 2.5	HP Heat Rise @ Design	0.0
HP Power (High/Low)	4.7 / 4.0 kW	Leaving	14.7

VENTILATION

Air Flow (cfm)		Supply Fan		Air Resistance (in.WC)	
Supply	2,092	Nominal Power	1.00 hp	Total	0.85
	0	Required Power	1.00 hp	Ext Supply	0.75
		Drive Type	MSAV Direct Drive		
		Speed	5		
		Motor Torque			

AIR RESISTANCE - OPTIONS/ACCESSORIES (in.WC)

Wet Coil	Humiditrol	Heat	Economizer	Filters	Diffuser	Exhaust	ERW
0.05			0.05				

ELECTRICAL

Voltage	460V 3Ph / 60Hz	Compressor RLA	7.2 amp
MCA	15 amp	Cooling FLA Total	12.3 amp
MOCP	20 amp	Condenser FLA	1.4 amp
Condenser Power	280 W	Supply Fan FLA	3.7 amp
Oper Range-Nom Volt	+/- 10%		

ADDITIONAL DATA

Cabinet	98.25 in. x 47.00 in. x 46.88 in.	Total Weight	867 lb
Downflow Supply	20.0 in. x 18.0 in.	Base Unit Net Weight	727 lb
Downflow Return	29.0 in. x 11.0 in.	OAS/Econ Weight	131 lb
Filters	(4) 20.0 in. x 20.0 in. x 2.0 in.		
Sound Rating	77 dBA		



Project Submittal

Tag:

RTU 12

Factory Installed Options

- High Performance Economizer Upgrade Factory Installed
- Single Enthalpy Economizer
- Standard Cap, Std Packaging
- Unit Orientation Downflow
- MSAV Direct Drive
- 440V/460V/480V 3Phase
- Supply Motor - 1.0 Hp ECM - w/ MSAV
- Barometric Relief Damper (Fac)
- GFCI Factory Installed/Field Wired
- BACnet Module (Fac)
- Tube and Fin Coil System Factory Installed
- 2" MERV4 - Std. Filter Factory Installed

Field Installed Accessories

Catalog Number	Qty	Description
13T17	1	Combination Coil/Hail Guards Field Installed
97W23	1	Bacnet Sensor With Display Field installed
54W21	4	2" MERV8 - Filter Field Installed
87N53	1	CO2 Sensors - Wall-mount, off-white plastic cover, no display Field Installed

Product Features

Cabinet

- Durable Outdoor Enamel Paint Finish
- Totally Enclosed Outdoor Fan Motor
- PVC Coated Fan Guard
- Corrosion-Resistant Removable, Reversible Drain Pan
- Isolated Compressor Compartment

Cooling System

- Scroll Compressor
- Expansion Valves
- High Capacity Driers
- High Pressure Switch (Manual Reset)
- Crankcase Heater
- System can operate from 30°F to 125°F without any additional controls
- Pre-charged Refrigeration System
- Internal Pressure Relief Valve
- Thermostat Control – 2 Stages of Cooling

Control System

- Fan and Limit Controls
- Overload Protection


Warranty

- Limited warranty on compressor of 5 years
- Limited warranty on High Performance Economizer of 5 years
- Limited warranty on all other components of 1 year
- See Limited Warranty Certificate included with unit for details




Project Submittal


Corner Weights (lb)								Center of Gravity (in.)			
AA		BB		CC		DD		EE		FF	
Base	Max	Base	Max	Base	Max	Base	Max	Base	Max	Base	Max
162	217	192	201	218	229	184	247	45.00	51.00	22.00	22.00




TOP VIEW (Base)



END VIEW




SIDE VIEW





BACK VIEW


COMBINATION OUTDOOR AIR HOOD DETAIL FOR OPTIONAL ECONOMIZER AND BAROMETRIC RELIEF DAMPERS (Furnished With Economizer for Downflow Applications)



OUTDOOR AIR DAMPER HOOD DETAIL (Downflow or Horizontal Applications)



UNIT CLEARANCES



¹ Unit Clearance	A		B		C		D		Top Clearance
	in.	mm	in.	mm	in.	mm	in.	mm	
Service Clearance	36	914	36	914	36	914	36	914	Unobstructed
Minimum Operation Clearance	36	914	36	914	36	914	36	914	

NOTE - Entire perimeter of unit base requires support when elevated above the mounting surface.

¹ Service Clearance - Required for removal of serviceable parts.

Minimum Operation Clearance - Required clearance for proper unit operation.



Project Submittal

Tag: RTU 13
 Model: KHB074S4T - KHB074S4T-G 6T CONF E=11.0

UNIT OVERVIEW										
Voltage	IEER EER	IPLV	HSPF	MCA/MOC P (amp)	Gross Cooling Ttl/Sens (MBH)	Net Cooling Ttl/Sens (MBH)	Supply Air Flow (cfm)	ESP/TSP (in.WC)	EAT DB/WB (°F)	LAT DB/WB (°F)
460V 3Ph 60Hz	14 11			17 / 25	70.5 / 56.4	66.5 / 52.4	2,400	1.00 / 1.12	80.0 / 67.0	57.6 / 57.3

COOLING

Cooling Performance			Temperatures (DB/WB °F)		
Gross Cooling (Ttl/Sens)	70.5 / 56.4 MBH		Ambient	95.0	
Net Cooling (Ttl/Sens)	66.5 / 52.4 MBH		Entering	80.0	
Coil Moisture Removal	13.29 lb/hr		Leaving - (Coil)	57.6	
System Moisture Removal	13.29 lb/hr		Leaving - (Unit)	59.2	
				67.0	57.3
				57.6	57.3
				59.2	57.9

ARI Performance		Compressors		Refrigerant		Condensate Drain	
ARI Cooling	71.0 / 68.0 MBH	Cooling Stages	2	Type	R-410A	Qty	1
ARI Power	6,200 W	Compressor Qty	1	Charge	24 LBS. 0 OZ.	Size	1 in.
		Compressor RLA	8.5 amp			Pipe Thread	npt

HEATING

Heating Performance		Temperatures (DB/WB °F)	
HP Output @ Design	40.7 MBH	HP Design	17.0
COP (High/Low)	3.3 / 2.3	HP Heat Rise @ Design	0.0
HP Power (High/Low)	6.1 / 5.6 kW	Leaving	15.7

VENTILATION

Air Flow (cfm)		Supply Fan		Air Resistance (in.WC)	
Supply	2,400	Nominal Power	2.00 hp	Total	1.12
		Required Power	1.25 hp	Ext Supply	1.00
		Drive Type	MSAV Belt Drive		
		RPM Range	968 - 1,340 rpm		
		Required RPM	1,288 rpm		

AIR RESISTANCE - OPTIONS/ACCESSORIES (in.WC)

Wet Coil	Humiditrol	Heat	Economizer	Filters	Diffuser	Exhaust	ERW
0.07			0.05				

ELECTRICAL

Voltage	460V 3Ph / 60Hz	Compressor RLA	8.5 amp
MCA	17 amp	Cooling FLA Total	13.4 amp
MOCP	25 amp	Condenser FLA	1.5 amp
Condenser Power	505 W	Supply Fan FLA	3.4 amp
Oper Range-Nom Volt	+/- 10%		

ADDITIONAL DATA

Cabinet	98.25 in. x 47.00 in. x 46.88 in.	Total Weight	890 lb
Downflow Supply	20.0 in. x 18.0 in.	Base Unit Net Weight	750 lb
Downflow Return	29.0 in. x 11.0 in.	OAS/Econ Weight	131 lb
Filters	(4) 20.0 in. x 20.0 in. x 2.0 in.		
Sound Rating	83 dBA		



Project Submittal

Tag:

RTU 13

Factory Installed Options

- High Performance Economizer Upgrade Factory Installed
- Single Enthalpy Economizer
- Standard Cap, Std Packaging
- Unit Orientation Downflow
- MSAV Belt Drive 2-Speed
- 440V/460V/480V 3Phase
- Supply Motor - 2.0 Hp - w/ MSAV
- Supply Drive Kit 4 (968-1340 RPM)
- Barometric Relief Damper (Fac)
- GFCI Factory Installed/Field Wired
- BACnet Module (Fac)
- Tube and Fin Coil System Factory Installed
- 2" MERV4 - Std. Filter Factory Installed

Field Installed Accessories

Catalog Number	Qty	Description
13T17	1	Combination Coil/Hail Guards Field Installed
97W23	1	Bacnet Sensor With Display Field installed
54W21	4	2" MERV8 - Filter Field Installed
87N53	1	CO2 Sensors - Wall-mount, off-white plastic cover, no display Field Installed

Product Features

Cabinet

- Durable Outdoor Enamel Paint Finish
- Totally Enclosed Outdoor Fan Motor
- PVC Coated Fan Guard
- Corrosion-Resistant Removable, Reversible Drain Pan
- Isolated Compressor Compartment

Cooling System

- Scroll Compressor
- Expansion Valves
- High Capacity Driers
- High Pressure Switch (Manual Reset)
- Crankcase Heater
- System can operate from 30°F to 125°F without any additional controls
- Pre-charged Refrigeration System
- Internal Pressure Relief Valve
- Thermostat Control – 2 Stages of Cooling

Control System

- Fan and Limit Controls
- Overload Protection





Warranty

- Limited warranty on compressor of 5 years
- Limited warranty on High Performance Economizer of 5 years
- Limited warranty on all other components of 1 year
- See Limited Warranty Certificate included with unit for details




Project Submittal



Corner Weights (lb)								Center of Gravity (in.)			
AA		BB		CC		DD		EE		FF	
Base	Max	Base	Max	Base	Max	Base	Max	Base	Max	Base	Max
160	185	180	208	233	269	207	239	46.25	46.25	20.50	20.50




COMBINATION OUTDOOR AIR HOOD DETAIL FOR OPTIONAL ECONOMIZER AND BAROMETRIC RELIEF DAMPERS (Furnished With Economizer for Downflow Applications)



OUTDOOR AIR DAMPER HOOD DETAIL (Downflow or Horizontal Applications)



UNIT CLEARANCES



¹ Unit Clearance	A		B		C		D		Top Clearance
	in.	mm	in.	mm	in.	mm	in.	mm	
Service Clearance	36	914	36	914	36	914	36	914	Unobstructed
Minimum Operation Clearance	36	914	36	914	36	914	36	914	

NOTE - Entire perimeter of unit base requires support when elevated above the mounting surface.

¹ Service Clearance - Required for removal of serviceable parts.

Minimum Operation Clearance - Required clearance for proper unit operation.



Project Submittal




Tag: Miscellaneous Items

Miscellaneous Items

Tag	Catalog Number	Qty	Description
(12) CPT-1 High Efficiency Curb Adapters	COMSD	1	(12) CPT-1 High Efficiency Curb Adapters

Drawing Date: 5-9-18	REV: 001	Approved By:	Approved Date:
SHELL: 16 GA	PANS: 18 GA	CHANNELS: 16 GA	CLOSURES: 16 GA
TOP FLANGE DIM: 1 1/2"			

1 1/2" SQ STEEL TUBE
SUPPORTS AT CORNERS



DESIGNED TO MEET LOCAL SEISMIC AND WIND CRITERIA

NOTE: WELD IN BULK-HEADS TO CURB WALL ON 24\"/>

QTY.:11	DRAWN BY.:SLR
NEW UNIT:LENNOX	
LGH-LCH 094-152 FULL PERIMETER	
OLD UNIT:LENNOX	
L/T-SERIES 090-150	
ROLLS OF GASKET:2	
TAG:	

CURBS PLUS, INC.

8767 Alabama Hwy
Ringgold, GA 30736
Phone:(706) 858-1188 / Fax: (706) 866-2339
website: www.curbs-plus.com

TRANSITION-CURB SYSTEM

Confidential and propriety information of Curbs Plus, Inc. unauthorized use, disclosure, or reproduction is expressly prohibited.

TAG PLATE:LX466LX9-SEISMIC




APPROXIMATE WEIGHT:235 LBS.

Note: Design subject to change without notice.

File Name:LX466LX9-SEISMIC NEW LENNOX LGH-LCH 094-152 FULL PERIMETER EXISTING LENNOX LGH-LCH 094-152 FULL PERIMETER

©2008 Curbs Plus, Inc.

Drawing Date: 8-20-10	REV: 001	Approved By:	Approved Date:
SHELL: 16 GA	PANS: 18 GA	CHANNELS: 18 GA	CLOSURES: 16 GA
TOP FLANGE DIM: 1 1/2"			



DESIGNED TO MEET LOCAL SEISMIC AND WIND CRITERIA

NOTE: WELD IN BULK-HEADS TO CURB WALL ON 24" CENTERS ALL SIDES (MIN 3 BULK-HEADS)

EXISTING LENNOX UNIT
 GCS/CHA/CHP16 511 / 653 / 16W- 413-653
 GCS/CHA/CHP20 411 / 653
 GCS16/20 048-060

QTY.:1	DRAWN BY.:SLR
NEW UNIT:LENNOX	
K-SERIES 090,KHA072,KHB060-074 FULL PERIMETER	
OLD UNIT:LENNOX	
SEE ABOVE	
ROLLS OF GASKET:2	
TAG:	

CURBS PLUS, INC.

8767 Alabama Hwy
 Ringgold, GA 30736
 Phone:(706) 858-1188 / Fax: (706) 866-2339
 website: www.curbs-plus.com

TRANSITION-CURB SYSTEM

Confidential and propriety information of Curbs Plus, Inc. unauthorized use, disclosure, or reproduction is expressly prohibited.

TAG PLATE:LX297LX86-SEISMIC

APPROXIMATE WEIGHT:215 LBS.

Note: Design subject to change without notice.




File Name:LX297LX86--SEISMIC NEW LENNOX K-SERIES 090 A BOX EXISTING LENNOX GCS CHA ©2008 Curbs Plus, Inc.

Drawing Date:

REV: 2-21-17

Approved By:

14 GA GALVANIZED CONSTRUCTION



LENNOX: L/T/K-SERIES/LGH-LCH/LC,LGM 024-150 UNITS USE UP TO (8) CLIPS PER CURB MAX (SEE INSTALL SHEET)

LENNOX: L/T/K-SERIES/LGH-LCH/LC,LGM 156-360 UNITS USE UP TO (10) CLIPS PER CURB MAX (SEE INSTALL SHEET)

ATTACH VIA (8) 1/4"X14X1 1/4" TEK SCREWS

QTY.: 13 SET(S) (10 CLIPS PER SET)

PROJECT NAME:

CITY, STATE:

CUSTOMER:

JOB NUMBER:

TAG:

CURBS PLUS, INC.

8767 Alabama Hwy Ringgold, GA 30736
205 Metcalf Rd. El Dorado, KS 67042
Phone: (706) 858-1188 / FAX (706) 866-2339
website: www.curbs-plus.com

LENNOX UNIT CLIPS
MODEL# L/T/K/S-SERIES/LGH-LCH 024-360

LENNOX PART# X6523