

MECHANICAL SHEET INDEX

| | |
|------|------------------------------------|
| M001 | MECHANICAL ABBREVIATIONS & SYMBOLS |
| M101 | MECHANICAL FLOOR PLAN |
| M150 | MECHANICAL ROOF PLAN |
| M501 | MECHANICAL DETAILS |
| M502 | MECHANICAL DETAILS |
| M590 | MECHANICAL SPECIFICATIONS |
| M591 | MECHANICAL SPECIFICATIONS |
| M592 | MECHANICAL SPECIFICATIONS |
| M601 | MECHANICAL SCHEDULES |
| M630 | MECHANICAL ENERGY CODE COMPLIANCE |
| M631 | MECHANICAL ENERGY CODE COMPLIANCE |
| M701 | HALTON DRAWINGS |
| M702 | HALTON DRAWINGS |
| M703 | HALTON DRAWINGS |
| M704 | HALTON DRAWINGS |

GENERAL NEW NOTES:

- PRIOR TO SUBMITTING BID, VISIT THE JOB SITE AND BECOME FULLY ACQUAINTED WITH THE EXISTING CONDITIONS OF THE PROJECT. REVIEW THE GENERAL NOTES, SPECIFICATIONS AND OTHER DRAWINGS FOR ADDITIONAL REQUIREMENTS WHICH MAY NOT BE SPECIFICALLY CALLED OUT IN THIS PORTION OF THE CONSTRUCTION DOCUMENTS. NOTIFY ARCHITECT, ENGINEER AND/OR OWNER OF CONFLICTS OR DISCREPANCIES PRIOR TO SUBMISSION OF BID.
- EXISTING CONDITIONS WERE TAKEN FROM ORIGINAL DRAWINGS AND SITE VISITS AND MAY NOT REFLECT EXACT "AS-BUILT" CONDITIONS. FIELD VERIFY EXISTING CONDITIONS PRIOR TO SUBMITTING FINAL BIDS. COORDINATE NEW WORK AND DEMOLITION WITH OTHER DISCIPLINES AND EXISTING CONDITIONS PRIOR TO CONSTRUCTION.
- COORDINATE THE INSTALLATION OF THE MECHANICAL SYSTEMS WITH OTHER TRADES TO ENSURE A NEAT AND ORDERLY INSTALLATION. INSTALL DUCTWORK AND PIPING AS TIGHT TO STRUCTURE AS POSSIBLE. COORDINATE WITH OTHER TRADES TO AVOID CONFLICTS. COORDINATE INSTALLATION OF DUCTWORK AND PIPING TO AVOID CONFLICTS WITH ELECTRICAL PANELS, LIGHTING FIXTURES, ETC. ANY MODIFICATIONS REQUIRED DUE TO LACK OF COORDINATION WILL BE THE RESPONSIBILITY OF THE CONTRACTOR AT NO EXTRA COST TO THE OWNER.
- WHERE SHUTDOWN OF EXISTING SYSTEMS IS REQUIRED DURING NEW WORK, COORDINATE SHUTDOWN TIME AND DURATION WITH THE OWNER TO MINIMIZE DOWNTIME. NOTIFY OWNER SEVEN (7) DAYS PRIOR TO INTERRUPTION OF SERVICE.
- DURING INSTALLATION OF NEW WORK, AVOID DAMAGING EXISTING SURFACES AND EQUIPMENT TO REMAIN. REPAIR DAMAGE CAUSED DURING CONSTRUCTION AT NO EXTRA COST TO THE OWNER.
- PROVIDE TEMPORARY BARRIERS TO CONTAIN DUST AND DEBRIS RESULTING FROM THE PERFORMANCE OF THE WORK TO THE AREA WHERE WORK IS BEING PERFORMED.
- ALL MECHANICAL EQUIPMENT SHOWN ON THE MECHANICAL PLANS SHALL BE PROVIDED BY DIVISION 23 UNLESS OTHERWISE NOTED.
- NEW MECHANICAL EQUIPMENT, DUCTWORK AND PIPING ARE SHOWN AT APPROXIMATE LOCATIONS. FIELD MEASURE FINAL DUCTWORK AND PIPING LOCATIONS PRIOR TO FABRICATION AND MAKE ADJUSTMENTS AS REQUIRED TO FIT THE DUCTWORK AND PIPING WITHIN THE AVAILABLE SPACE. VERIFY THAT FINAL EQUIPMENT LOCATIONS MEET MANUFACTURER'S RECOMMENDATIONS REGARDING SERVICE CLEARANCE AND PROPER AIRFLOW CLEARANCE AROUND EQUIPMENT.
- REFER TO ARCHITECTURAL DRAWINGS FOR RELATED CONSTRUCTION DETAILS AS APPLICABLE TO THE HVAC SYSTEM. VERIFY CHASES AND PENETRATIONS SHOWN ON ARCHITECTURAL DRAWINGS THAT ARE INTENDED FOR DUCTWORK AND PIPING MEET REQUIREMENTS.
- COORDINATE LOCATION OF ROOF MOUNTED HVAC EQUIPMENT AND ROOF PENETRATIONS WITH THE ARCHITECTURAL AND STRUCTURAL DRAWINGS.
- INDOOR AIR QUALITY MEASURES: PROTECT INSIDE OF (INSTALLED AND DELIVERED) DUCTWORK AND HVAC UNITS FROM EXPOSURE TO DUST, DIRT, PAINT AND MOISTURE. REPLACE INSULATION THAT HAS BECOME WET AT ANY TIME DURING CONSTRUCTION. DRYING THE INSULATION IS NOT ACCEPTABLE. SEAL ANY TEARS OR JOINTS OF INTERNAL FIBERGLASS INSULATION. REMOVE DEBRIS FROM CEILING/RETURN AIR PLENUM INCLUDING DUST. AN INDEPENDENT PROFESSIONAL DUCT CLEANING COMPANY SHALL VACUUM CLEAN ANY DUCTWORK CONNECTED TO HVAC UNITS THAT WERE OPERATED DURING THE CONSTRUCTION PERIOD AFTER NEW FILTERS ARE INSTALLED AND PRIOR TO TURNING SYSTEM OVER TO THE OWNER. THE INTERNAL SURFACES AND ASSOCIATED COILS OF ANY HVAC UNITS THAT WERE OPERATED SHALL ALSO BE CLEANED.
- INSTALL DUCTWORK AND PIPING PARALLEL TO BUILDING COLUMN LINES UNLESS OTHERWISE SHOWN OR NOTED.
- OVERHEAD HANGERS AND SUPPORTS FOR EQUIPMENT, DUCTWORK AND PIPING SHALL BE FASTENED TO BUILDING JOISTS OR BEAMS. DO NOT ATTACH HANGERS AND SUPPORTS TO THE ABOVE FLOOR SLAB OR ROOF EXCEPT WHERE CONCRETE INSERTS IN CONCRETE SLABS ARE ALLOWED BY THE SPECIFICATIONS.
- COORDINATE LOCATION OF EQUIPMENT SUPPORTS WITH LOCATION OF EQUIPMENT ACCESS PANELS/DOORS TO ENABLE SERVICE OF EQUIPMENT AND/OR FILTER REPLACEMENT.
- SEAL PENETRATIONS THROUGH THE BUILDING COMPONENTS IN ACCORDANCE WITH THE CONTRACT SPECIFICATIONS. FIREPROOF PENETRATIONS THROUGH FIRE RATED COMPONENTS IN ACCORDANCE WITH U.L. REQUIREMENTS.
- COORDINATE THE EXACT MOUNTING SIZE AND FRAME TYPE OF DIFFUSERS, REGISTERS AND GRILLES WITH THE SUPPLIER TO MEET THE CEILING, WALL AND DUCT INSTALLATION REQUIREMENTS.
- ADJUST LOCATION OF CEILING DIFFUSERS, REGISTERS AND GRILLES AS REQUIRED TO ACCOMMODATE FINAL CEILING GRID AND LIGHTING LOCATIONS.
- PAINT PORTIONS OF DUCTWORK AND INSULATION THAT ARE EXPOSED TO VIEW BY THE INSTALLATION OF DIFFUSERS, REGISTERS, AND GRILLES IN CEILINGS OR WALLS FLAT BLACK. PORTIONS INCLUDE BOTH THE INTERIOR OF UNLINED DUCTWORK AND THE EXTERIOR OF DUCTWORK AND INSULATION.
- LOCATE AND SET THERMOSTATS AND HUMIDISTATS AT LOCATIONS SHOWN ON PLANS. VERIFY EXACT LOCATIONS WITH ARCHITECT PRIOR TO INSTALLATION. INSTALL DEVICES WITH TOP OF DEVICE AT MAXIMUM 48" AFF TO MEET ADA REQUIREMENTS UNLESS NOTED OTHERWISE ON PLANS. PROVIDE INSULATED BACKING FOR THERMOSTATS MOUNTED ON EXTERIOR BUILDING WALLS. INSTALL WIRING IN CONDUIT PROVIDED BY DIVISION 26. AT A MINIMUM, PROVIDE CONDUIT IN THE WALL FROM THE JUNCTION BOX TO 6" ABOVE THE CEILING.
- COORDINATE THE LOCATION AND ELEVATION OF WALL-MOUNTED DEVICES WITH PRESENTATION BOARDS, DISPLAY CABINETS, SHELVES OR OTHER COMPONENTS SHOWN ON THE ARCHITECTURAL DRAWINGS THAT ARE TO BE INSTALLED UNDER OTHER DIVISIONS. CONTRACTOR WILL NOT BE REBURSED FOR ELEVATION OF WALL MOUNTED DEVICES CAUSED BY A LACK OF COORDINATION.
- PROVIDE A MANUAL BALANCING DAMPER IN EACH DUCT TAKEOFF FROM SUPPLY, RETURN, OUTDOOR AND EXHAUST AIR DUCTS.
- PROVIDE A PREFABRICATED 45 DEGREE, HIGH EFFICIENCY, RECTANGULAR/ROUND BRANCH DUCT TAKEOFF FITTING FOR BRANCH DUCT CONNECTIONS AND TAKE-OFFS TO INDIVIDUAL DIFFUSERS, REGISTERS AND GRILLES. PROVIDE WITH INTEGRAL MANUAL BALANCING DAMPER AND LOCKING QUADRANT WHERE INDICATED ON PLANS.
- BRANCH DUCTWORK TO AIR OUTLETS SHALL BE SAME SIZE AS OUTLET NECK SIZE UNLESS OTHERWISE NOTED.
- REFER TO SPECIFICATIONS FOR DUCTWORK AND PIPING INSULATION REQUIREMENTS. DUCT SIZES ON MECHANICAL PLANS INDICATE CLEAR INSIDE AIRFLOW DIMENSIONS. INCREASE SHEET METAL SIZES ACCORDINGLY TO ACCOUNT FOR THICKNESS OF DUCT LINER.
- FLEXIBLE DUCTWORK SHALL NOT EXCEED 5'-0" IN LENGTH AND SHALL BE INSTALLED AND SUPPORTED TO AVOID SHARP BENDS AND SAGGING. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
- PROVIDE EQUIPMENT VENTS AND FLUES PER EQUIPMENT MANUFACTURERS RECOMMENDATIONS AND EQUIPMENT SPECIFICATIONS. KEEP PENETRATIONS THROUGH ROOF A MINIMUM OF 10'-0" FROM HVAC EQUIPMENT FRESH AIR INLETS AND 2'-0" FROM ROOF PARAPETS.
- PROVIDE TYPE I GREASE HOOD EXHAUST DUCTWORK OF MINIMUM 16 GAUGE BLACK IRON WITH LIQUID TIGHT WELDS. WITH ACCESS PANELS FOR GREASE CLEANING AS REQUIRED BY NFPA 96 AND LOCAL CODES. SLOPE DUCT BACK TOWARDS HOOD AT MINIMUM OF 1/4" PER LINEAL FOOT MAINTAINING 18" CLEARANCE TO COMBUSTIBLE MATERIALS. INSTALL GREASE DUCTS IN AN APPROVED FIRE-RATED ENCLOSURE SEPARATED FROM THE EXHAUST DUCT BY A MINIMUM OF 6" AND MAXIMUM OF 12". VENTILATE ENCLOSURE TO THE OUTSIDE AIR IF REQUIRED BY CODE. AS AN OPTION, IF APPROVED BY LOCAL CODES, PROVIDE AN APPROVED WRAP SYSTEM IN LIEU OF THE RATED DUCT ENCLOSURE SYSTEM. DUCT WRAP SYSTEM SHALL MEET U.L. REQUIREMENTS FOR GREASE DUCT ENCLOSURES.
- PROVIDE A NEW SET OF AIR FILTERS IN UNITS PRIOR TO TESTING. ADJUSTING AND BALANCING AND BEFORE TURNING SYSTEM(S) OVER TO OWNER.
- FIELD VERIFY THAT THE EXISTING EQUIPMENT INCLUDING ACCESSORIES BEING REUSED FOR THIS PROJECT IS NOT DAMAGED AND IS IN GOOD WORKING ORDER. REPORT ANY DEFICIENCIES TO THE OWNER OR ARCHITECT. SUBMIT TO THE OWNER AND ARCHITECT A WRITTEN REPORT DESCRIBING TESTS PERFORMED TO VERIFY OPERATION AND RESULTS OF THE TESTS.
- CLEAN EXISTING EQUIPMENT AND EQUIPMENT COMPONENTS BEING REUSED FOR THIS PROJECT. PROVIDE NEW FILTERS FOR EXISTING AIR HANDLING EQUIPMENT PRIOR TO STARTUP OF EQUIPMENT. NEW FILTERS SHALL BE COMPATIBLE WITH THE EXISTING EQUIPMENT AND EQUAL IN PERFORMANCE TO THE EXISTING FILTERS AT NEW CONDITION UNLESS OTHERWISE NOTED. CLEAN STRAINERS IN PIPING SYSTEMS PRIOR TO STARTING PUMPS.
- TEMPORARY INSTALLATIONS OF INFECTION CONTROL MEASURES DURING CONSTRUCTION SHALL BE COORDINATED WITH THE FACILITY'S INFECTION CONTROL STAFF. PRIOR TO CONSTRUCTION PROVIDE ALL REQUIRED TEMPORARY INSTALLATIONS, INCLUDING DETAILS OF THE INFECTION CONTROL MEASURES SUCH AS TEMPORARY BARRIERS AND MEMBRANES, PORTABLE EXHAUST FANS AND TEMPORARY DUCTWORK. TEMPORARY INSTALLATIONS MUST NOT HAVE A NEGATIVE IMPACT ON EXISTING SYSTEMS NOR CAUSE UNSAFE CONDITIONS. TEMPORARY INSTALLATIONS SHALL MAINTAIN ADEQUATE EGRESS AND SHALL NOT OBSTRUCT EXISTING EXITS. CREATE A FIRE HAZARD OR REDUCE REQUIRED FIRE RESISTANCE. TEMPORARY VENTILATION SYSTEMS SHALL NOT CAUSE THE AIR BALANCE OF ADJACENT ROOMS OR SPACES TO BE IMPACTED OR ALTER THE PERFORMANCE OF PERMANENT BUILDING VENTILATION SYSTEMS. AIRFLOW MEASUREMENTS SHALL BE TAKEN TO VERIFY ADJACENT ROOMS OR SPACES ARE NOT IMPACTED.

MECHANICAL SYMBOLS

THIS IS A MASTER LEGEND AND NOT ALL SYMBOLS OR ABBREVIATIONS ARE USED.

| STANDARD MOUNTING HEIGHT | | HVAC DUCTWORK AND ACCESSORIES | | PIPING SYMBOLS | | PIPING LINETYPES | |
|---|--|--|--|---------------------------------------|--|---|--|
| THERMOSTATS (USER ADJUSTABLE)(TOP OF DEVICE) 48" | | LINEAR SLOT DIFFUSER | | DIRECTION OF FLOW | | CONDENSATE DRAIN (CD) | |
| CONTROLS (TOP OF DEVICE) 48" | | INSULATED FLEXIBLE DUCT (MAX. 5'-0" LONG) | | CONTROL VALVE | | AUXILIARY CONDENSATE DRAIN (ACD) | |
| INSTALL DEVICES AT THE MOUNTING HEIGHTS SHOWN ABOVE UNO IN THE CONSTRUCTION DOCUMENTS. MOUNTING HEIGHTS LISTED ABOVE OR ELSEWHERE IN THE CONSTRUCTION DOCUMENTS ARE OFF OR AFG TO BOTTOM OF DEVICE UNO. ALL DEVICES SHALL BE INSTALLED IN COMPLIANCE WITH CURRENT ADA AND LOCAL REQUIREMENTS. | | BRANCH DUCT WITH 45° RECTANGLE-ROUND BRANCH FITTING AND MANUAL VOLUME DAMPER | | THREE-WAY CONTROL VALVE | | NON-POTABLE WATER (NPW) | |
| ANNOTATION | | ELBOW WITH TURNING VANES | | SHUTOFF VALVE | | NATURAL GAS (G) | |
| MECHANICAL PLAN NOTE CALLOUT | | BRANCH DUCT WITH BELL-MOUTH FITTING & MANUAL VOLUME CONTROL DAMPER | | CHECK VALVE | | NATURAL GAS ON ROOF (G) | |
| MECHANICAL EQUIPMENT DESIGNATION (CONTRACTOR FURNISHED AND INSTALLED UNLESS NOTED OTHERWISE) | | RETURN, EXHAUST, OR OUTSIDE AIR DUCT UP | | BALANCING VALVE WITH PRESSURE PORTS | | MEDIUM PRESSURE NATURAL GAS (MPG) | |
| CONNECTION POINT OF NEW WORK TO EXISTING | | RETURN, EXHAUST, OR OUTSIDE AIR DUCT DOWN | | TRIPLE DUTY VALVE WITH PRESSURE PORTS | | MEDIUM PRESSURE NATURAL GAS ON ROOF (MPG) | |
| DETAIL REFERENCE. UPPER NUMBER INDICATES DETAIL NUMBER LOWER NUMBER INDICATES SHEET NUMBER | | SUPPLY AIR DUCT UP | | STRAINER | | FUEL OIL SUPPLY (FOS) | |
| SECTION CUT DESIGNATION | | SUPPLY AIR DUCT DOWN | | STRAINER WITH BLOWDOWN VALVE | | FUEL OIL RETURN (FOR) | |
| ABBREVIATIONS | | EQUIPMENT WITH FLEXIBLE DUCT CONNECTION | | RELIEF / SAFETY VALVE | | FUEL OIL VENT (FOV) | |
| ACC AIR CONDITIONING | | 10" (NECK SIZE) CSD-1 (TYPE) 300 CFM (CFM OF SUPPLY DIFFUSER OR REGISTER) | | SOLENOID VALVE | | LIQUEFIED PETROLEUM GAS (LPG) | |
| ACC AIR COOLED CHILLER | | 24x24 (NECK SIZE) CEG-1 (TYPE) 600 CFM (CFM OF EXHAUST GRILLE) | | PRESSURE REDUCING VALVE | | BOILER FEED WATER (BFW) | |
| ACCU AIR COOLED CONDENSING UNIT | | SQUARE TO ROUND TRANSITION | | GAS PRESSURE REGULATOR | | HIGH PRESSURE STEAM SUPPLY (HPS) | |
| AFC ABOVE FINISHED CEILING | | DUCT MOUNTED SMOKE DETECTOR (RD=SUPPLY/RD=RETURN) | | THERMOSTATIC MIXING VALVE | | HIGH PRESSURE STEAM CONDENSATE (HPC) | |
| AFF ABOVE FINISHED FLOOR | | RD-50 DUCT TAG INDICATING DIAMETER | | PIPE ANCHOR | | LOW PRESSURE STEAM SUPPLY (LPS) | |
| AFG ABOVE FINISHED GRADE | | XX" Ø | | EXPANSION JOINT | | LOW PRESSURE STEAM CONDENSATE (LPC) | |
| AFH AUTHORITY HAVING JURISDICTION | | XX" x XX" | | PIPE GUIDE | | CONDENSATE PUMP DISCHARGE (PD) | |
| AHU AIR HANDLING UNIT | | XX' x XX' | | PIPING SUPPORT | | HEATING HOT WATER SUPPLY (HWS) | |
| AI ANALOG INPUT | | PROVIDE FURNISH AND INSTALL | | F & T TRAP | | HEATING HOT WATER RETURN (HWR) | |
| AO ANALOG OUTPUT | | QTY QUANTITY | | BUCKET TRAP | | CHILLED WATER SUPPLY (CHWS) | |
| AP ACCESS PANEL | | RA RETURN AIR | | THERMOSTATIC TRAP | | CHILLED WATER RETURN (CHWR) | |
| APD AIR PRESSURE DROP | | RC ROOM CRITERIA | | THERMOSTATIC TRAP | | HOT / CHILLED WATER SUPPLY (HCR) | |
| AWG AMERICAN WIRE GAUGE | | RD RETURN DUCT | | BACKFLOW PREVENTER | | CONDENSER WATER SUPPLY (CWS) | |
| B BOILER | | REA RELIEF AIR | | PRESSURE GAUGE | | CONDENSER WATER RETURN (CWR) | |
| BAS BUILDING AUTOMATION SYSTEM | | RF RETURN FAN | | THERMOMETER | | HEAT PUMP WATER SUPPLY (HPWS) | |
| BB BACKBONE | | RFR REFRIGERANT | | PRESSURE AND TEMPERATURE TEST PLUG | | HEAT PUMP WATER RETURN (HPWR) | |
| BD BACKDRAFT DAMPER | | RH RELATIVE HUMIDITY | | UNION | | REFRIGERANT LIQUID (RL) | |
| BF BLOWDOWN | | RHM REVOLUTIONS PER MINUTE | | FLANGE CONNECTION | | REFRIGERANT DISCHARGE (HOT GAS) (RD) | |
| BFC BELOW FINISHED CEILING | | RHS REVISIONS PER MINUTE | | THERMOMETER | | REFRIGERANT SUCTION (RS) | |
| BFF BELOW FINISHED FLOOR | | SA SUPPLY AIR | | PRESSURE / VACUUM SWITCH | | REFRIGERANT DISCHARGE BYPASS (RDB) | |
| BFG BELOW FINISHED GRADE | | SD STEAM CONDENSATE PUMP | | CLEANOUT | | REFRIGERANT VENT (RV) | |
| BFP BOILER FEED PUMP | | SDP SMOKE DETECTOR | | CAP | | | |
| BHP BRAKE HORSEPOWER | | SE SMOKE DUCT DETECTOR | | ELBOW UP | | | |
| BIN BINARY INPUT | | SF SUPPLY FAN | | ELBOW DOWN | | | |
| BO BINARY OUTPUT | | SH SENSIBLE HEAT CAPACITY | | TEE UP | | | |
| BOD BOTTOM OF DUCT | | SOW SCOPE OF WORK | | TEE DOWN | | | |
| BOT BOTTOM OF STRUCTURE | | SP STATIC PRESSURE | | ELBOW UP WITH SHUT-OFF VALVE (SOV) | | | |
| BTU BRITISH THERMAL UNIT | | ST STEAM TRAP | | ELBOW DOWN WITH SHUT-OFF VALVE (SOV) | | | |
| CFM CUBIC FEET PER MINUTE | | STM STEAM | | TEE UP WITH SHUT-OFF VALVE (SOV) | | | |
| CH CHILLER | | TBD TO BE DETERMINED | | TEE DOWN WITH SHUT-OFF VALVE (SOV) | | | |
| CLG COOLING | | TCB TEMPERATURE CONTROLS CONTRACTOR | | REDUCER | | | |
| CPC CONDENSATE PUMP CONTROL POWER | | TCP TEMPERATURE CONTROL PANEL | | RECIRCULATION PUMP | | | |
| CPT TRANSFORMER | | TF TRANSFER FAN | | P-TRAP | | | |
| CRAC COMPUTER ROOM AIR CONDITIONING UNIT | | TFA TO FLOOR ABOVE TO FLOOR BELOW | | GAS COCK | | | |
| CRU COOLING TOWER | | TEB TO FLOOR ABOVE TO FLOOR BELOW | | TOP BEAM CLAMP | | | |
| CVP CONTROL VALVE | | TH TOTAL HEAT CAPACITY | | TRAPEZE HANGER | | | |
| CW CONDENSER | | TSP TOTAL STATIC PRESSURE | | FLEXIBLE CONNECTION | | | |
| CU WATER PUMP | | TT TEMPERATURE | | | | | |
| CUP CONDENSING UNIT | | TYP TYPICAL | | | | | |
| CHWP CHILLED WATER PUMP | | UF UNDERFLOOR | | | | | |
| DB DECIBELS | | UG UNDERGROUND | | | | | |
| DBA DECIBEL AVERAGE | | UIS UNDERSLAB | | | | | |
| DDC DIRECT DIGITAL CONTROL | | UH UNIT HEATER | | | | | |
| DI DIGITAL INPUT | | UNO UNLESS NOTED OTHERWISE | | | | | |
| DISC DISCONNECT | | VAV VARIABLE AIR VOLUME | | | | | |
| DN DOWN | | VEL VELOCITY | | | | | |
| DS DUCT SILENCER | | VFD VARIABLE FREQUENCY DRIVE | | | | | |
| DX DIRECT EXPANSION | | VRF VARIABLE REFRIGERANT FLOW | | | | | |
| (E) EXISTING | | VVR VARIABLE REFRIGERANT VOLUME | | | | | |
| EA EXHAUST AIR | | W/ WITH | | | | | |
| EAT ENTERING | | W/O WITHOUT | | | | | |
| EAIR AIR TEMPERATURE | | WB WET BULB | | | | | |
| EDB EXHAUST DUCT | | WC WATER COLUMN | | | | | |
| ED ENTERING DRY BULB | | WPD WATER PRESSURE DROP | | | | | |
| EF EXHAUST FAN | | XP EXPLOSION PROOF | | | | | |
| EFC EFFICIENCY | | | | | | | |
| EMS ENERGY MANAGEMENT SYSTEM | | | | | | | |
| ESP EXTERNAL STATIC PRESSURE | | | | | | | |
| ETR EXISTING TO REMAIN | | | | | | | |
| EVB ENTERING WATER BULB | | | | | | | |
| EWT ENTERING WATER | | | | | | | |
| FDU FAULT DETECTION DIAGNOSTICS | | | | | | | |
| FDD FAN COIL UNIT | | | | | | | |
| FFA FROM FLOOR ABOVE | | | | | | | |
| FFB FROM FLOOR BELOW | | | | | | | |
| FF FINISHED FLOOR | | | | | | | |
| FPI FINS PER INCH | | | | | | | |
| FPM FEET PER MINUTE | | | | | | | |
| GC GENERAL CONTRACTOR | | | | | | | |
| GPM GALLONS PER MINUTE | | | | | | | |
| GDA HAND-OFF-AUTOMATIC | | | | | | | |
| HP HORSEPOWER | | | | | | | |
| HTG HEATING | | | | | | | |

| HVAC CONTROL DEVICES | |
|--|-------------------------|
| ① HUMIDISTAT | ② THERMOSTAT |
| ③ CARBON MONOXIDE SENSOR | ④ CARBON DIOXIDE SENSOR |
| ⑤ DIFFERENTIAL PRESSURE SENSOR | ⑥ FLOW SWITCH |
| ⑦ HUMIDITY SENSOR | ⑧ PULL STATION |
| ⑨ REMOTE TESTING STATION WITH INDICATING LIGHT | ⑩ STATIC PRESSURE |
| ⑪ TEMPERATURE SENSOR | |

| LINETYPE LEGEND | |
|-----------------|--------|
| EXISTING | NEW |
| DEMOLISH | FUTURE |

THROUGHOUT THE DRAWINGS DIFFERENT LINETYPES ARE USED IN COMBINATION WITH THE SYMBOLS TO INDICATE THE STATUS OF ITEMS AS EXISTING, TO BE DEMOLISHED, TO BE INCLUDED AS PART OF NEW WORK AND/OR ITEMS WHICH ARE ANTICIPATED TO BE PROVIDED IN THE FUTURE. THE STATUS OF ITEMS USING THESE LINETYPES ARE RELATIVE TO THE VIEW IN WHICH THEY APPEAR. PHASING SHOWN IN DRAWINGS IS NOT INTENDED TO FULLY DESCRIBE ALL NECESSARY CONSTRUCTION PHASING, WHICH IS DETERMINED BY THE CONTRACTOR AS PART OF THEIR RESPONSIBILITIES. ANY SUCH PHASING DESCRIBED IN THE CONSTRUCTION DOCUMENTS ARE GENERAL AND ONLY INTENDED TO INDICATE A BROAD ORDER FOR THE SAKE OF DESCRIBING THE PROJECT. THE FOLLOWING LINETYPES MAY BE USED ON ANY DEVICE, EQUIPMENT, NOTE, LINE, SHAPE, ETC.

RESPONSIBILITY MATRIX

| DESCRIPTION | FURNISHED | | | INSTALLED | | | NOTES |
|---|-----------|-------|----|-----------|-------|----|-------|
| | GC | OWNER | LL | GC | OWNER | LL | |
| DIVISION 23: HEATING, VENTILATION, AND AIR CONDITIONING | | | | | | | |
| HVAC DUCTWORK AND PIPING IDENTIFICATION: HVAC DUCTWORK SYSTEM, PIPING SYSTEM, UTILITY SHUT OFF, VALVE TAGS AND CHART, AND HVAC DAMPER IDENTIFICATIONS) | | • | | • | | | |
| ROOF CURBS: EXHAUST FAN CURBS, ROOFTOP UNIT CURBS, CONDENSING UNIT CURBS, MAKE UP AIR UNIT CURBS, KITCHEN EXHAUST FAN CURBS | | • | | • | | | 1 |
| ROOF CURBS: MAKE UP AIR UNIT CURBS, KITCHEN EXHAUST FAN CURBS | | • | | • | | | 1 |
| HVAC DUCTWORK SYSTEM COMPONENTS: HVAC DUCTWORK, INSULATION AND FIRE WRAP, DAMPERS, SMOKE DETECTORS, SUPPLY/RETURN/EXHAUST GRILLS AND REGISTERS | | • | | • | | | 2 |
| MECHANICAL PIPING SYSTEM COMPONENTS: WALK-IN COOLER AND FREEZER REFRIGERATION | | • | | • | | | 3 |
| MECHANICAL PIPING SYSTEM COMPONENTS: REFRIGERATION FOR OTHER HVAC EQUIPMENT, CHILLED WATER, CONDENSER WATER, HEATING HOT WATER, VALVES AND ACCESSORIES (E.G. AIR VENTS) | | • | | • | | | 4 |
| HVAC EQUIPMENT: SUPPLY FAN, TOILET EXHAUST FAN, DUCTED AND NON-DUCTED HEATING AND COOLING UNITS, NATURAL GAS PATIO HEATERS, CONDENSING UNITS | | • | | • | | | 4 |
| HVAC EQUIPMENT: KITCHEN EXHAUST FAN, MAKE UP AIR UNITS | | • | | • | | | 4.5 |
| KITCHEN EXHAUST WITH FIRE SUPPRESSION SYSTEM: HOOD CONTROL PANEL, KITCHEN EXHAUST HOOD, ANSUL SYSTEM, ANSUL GAS VALVE | | • | | • | | | |
| KITCHEN EXHAUST WITH FIRE SUPPRESSION SYSTEM: STRUCTURAL SUPPORT, ELECTRICAL AND CONTROL WIRING, ANSUL WIRING AND UTILITIES CONNECTION | | • | | • | | | |
| COMMISSIONING ACTIVITIES: GREASE EXHAUST WATER LEAKAGE TEST, TESTING AIR BALANCE (TAB) REPORT | | • | | • | | | |
| GENERAL NOTES | | | | | | | |
| 1. INFORMATION CONTAINED WITHIN IS BASED ON THE DRAFT WORK LETTER AVAILABLE AT THE TIME OF THIS DESIGN. | | | | | | | |
| 2. REFER TO FINAL WORK LETTER FOR ALL LANDLORD/TENANT SCOPE OF WORK RESPONSIBILITIES. | | | | | | | |
| SCHEDULED NOTES | | | | | | | |
| 1. GENERAL CONTRACTOR SCOPE OF WORK TO INCLUDE RIGGING, CURBS, AND ACCESSORIES. | | | | | | | |
| 2. GENERAL CONTRACTOR SCOPE OF WORK TO INCLUDE TENANT FIT OUT FROM LANDLORD POINT OF CONNECTION. | | | | | | | |
| 3. WALK-IN COOLER AND FREEZER SUPPLIED BY VENDOR NO. 27 GENERAL CONTRACTOR SCOPE OF WORK TO INCLUDE PIPING INSTALLATION AND... | | | | | | | |
| 4. GENERAL CONTRACTOR SCOPE OF WORK TO INCLUDE RIGGING FOR ALL ROOFTOP EQUIPMENT. | | | | | | | |
| 5. SUPPLIED BY VENDOR NO. 28. | | | | | | | |

SUBMITTAL MATRIX

GENERAL CONTRACTORS TO ALSO REVIEW ARCHITECTURAL SPECIFICATIONS AS NOTED IN PLANS IN PLAN SECTION 700 OF THE ARCHITECTURAL PACKAGE FOR REQUIRED SUBMITTALS THAT MIGHT NOT BE LISTED BELOW.

| Required Review Time (Business Days) | Architect of Record | Shake Shack | Commissioning Agent | Physical Sample Required | Submitted for Record | Submitted for Record Only |
|--------------------------------------|---------------------|-------------|---------------------|--------------------------|----------------------|---------------------------|
| 5 | X | | X | X | X | |
| 5 | X | | X | X | X | |
| 5 | X | | X | X | X | |
| 5 | X | | X | X | X | |

SUBMITTAL DESCRIPTION
Diffusers, Grills & Registers
Ductwork Layout (if there are significant changes in field)
HVAC Equipment (if Carrier - Submitted by Owner Vendor directly to Owner/AOR prior to construction))
MEP Tests, Start-up, and Programming Reports



14614 N KIERNAN BLVD., SUITE 200
SCOTTSDALE, ARIZONA 85254
PHONE: 480.912.1169 www.zbr.co.uk

ENGINEER OF RECORD: JUSTIN M. OLDER

8345 LENEVA DRIVE, SUITE 300
LENEVA, KS 66214
TEL 913.742.5000 FAX 913.742.5001
30301910
MO CORPORATE NUMBER: 07-6699 EXPRESS 10110201

STORE NO: 1366



REVISION

| NO | DATE | DESCRIPTION |
|----|----------|-----------------|
| 1 | 04/08/21 | CITY COMMENTS |
| 2 | 05/03/21 | OWNER REVISIONS |

STATUS: PERMIT / BID SET



05/03/2021

FIELD VERIFICATION:
The contractor shall verify all signed dimensions and location of the project site and notify Zebra Architecture, LLC, of any dimensional errors, or omissions or omissions in the drawings before beginning any work. Do not commence work until approved by the architect.

COPYRIGHT © 2021:
Zebra Architecture, LLC, shall retain all common law, copyright and all other intellectual property rights in the documents and drawings prepared by or for the architect. No electronic or other reproduction or distribution of any part of these documents is permitted without the written consent of Zebra Architecture, LLC.

SHEET NAME:
MECHANICAL GENERAL INFORMATION

DATE: 04/08/21 **PROJECT NO:** 2050004103
DRAWN: AJP **SCALE:** AS NOTED

SHEET NO: M001

PROFESSIONAL CERTIFICATION
I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
PRINT NAME: JUSTIN M. OLDER
LICENSE #: 2138
EXPIRATION DATE: 1/8/2022

MECHANICAL PLAN NOTES:

- TYPE I GREASE HOOD EXHAUST DUCTWORK SHALL BE MINIMUM 16 GAUGE STEEL OR MINIMUM 16 GAUGE STAINLESS STEEL WITH LIQUID TIGHT WELDS. INSTALL ACCESS PANELS FOR CLEANING AS REQUIRED BY NFPA 96 AND LOCAL CODES. TRANSITION GREASE DUCTWORK AS REQUIRED TO HOOD AND FAN CONNECTIONS. PROVIDE 45° MAX OFFSETS AS REQUIRED TO COORDINATE WITH STRUCTURE. PROVIDE RADIUS ELBOWS WITHOUT TURNING VANES. SLOPE HORIZONTAL GREASE DUCT BACK TOWARDS HOOD AT MINIMUM OF 1/4" PER LINEAL FOOT. GREASE DUCTS SHALL BE CONTAINED IN A UL APPROVED GREASE DUCT WRAP SYSTEM.
- TYPE I HOODS SHALL BE FURNISHED COMPLETE WITH INTERNALLY PIPED FIRE SUPPRESSION SYSTEM AND EXTERNAL FOAM SUPPLY BOTTLES WITH REMOTE PULL CONTROLS AND IN COMPLIANCE WITH NFPA 96. DIVISION 23 SHALL COORDINATE COMPLETE INSTALLATION WITH FIRE PROTECTION CONTRACTOR TO MEET APPROVAL OF LOCAL INSPECTOR AND CODE COMPLIANCE INCLUDING TESTING.
- PROVIDE RA DUCT THROUGH ROOF. FULL SIZE OF UNIT OPENING, AND CONNECT TO UNIT WITH FLEXIBLE CONNECTOR.
- PROVIDE SA DUCT THROUGH ROOF. FULL SIZE OF UNIT OPENING, AND CONNECT TO UNIT WITH FLEXIBLE CONNECTOR.
- MOUNT THERMOSTATS AND TEMPERATURE SENSOR(S) ON WALL. THERMOSTATS AND SENSOR(S) SHALL BE LABELED TO MATCH THE UNIT TAG AND CORRESPOND TO THE ELECTRICAL LEGEND IN THE ELECTRICAL PANELBOARD SERVING THE EQUIPMENT. COORDINATE COLOR WITH ARCHITECT.
- REFER TO HALTON SHEETS FOR DUCT CONNECTION SIZES.
- PROVIDE MAKEUP AIR SUPPLY DUCT THROUGH ROOF. FULL SIZE OF UNIT OPENING, AND CONNECT TO UNIT WITH FLEXIBLE CONNECTOR.
- 12"x12" GREASE EXHAUST DUCT UP TO KEF-1 ON ROOF.
- 12"x12" GREASE EXHAUST DUCT UP TO KEF-2 ON ROOF.
- MOUNT TEMPERATURE SENSOR PROVIDED WITH KITCHEN EXHAUST HOODS ON WALL.
- INSTALL "DUCTMATE ULTIMATE DOOR" GREASE DUCT ACCESS PANELS FOR CLEANING IN LOCATION SHOWN AT A MINIMUM AND AS REQUIRED BY NFPA 96 AND LOCAL CODES.
- REFRIGERANT PIPING UP TO CU-1 ON ROOF, REF. 1/M150. UP TO EF-2 ON ROOF.
- INSTALL COMBUSTION AIR AND EXHAUST SYSTEM PER MANUFACTURER'S REQUIREMENTS AND SPECIFICATIONS AND IN COMPLIANCE WITH LOCAL CODES. MAINTAIN A MINIMUM 10'-0" SEPARATION FROM ALL AIR INTAKES.
- PROVIDE CONCENTRIC VENT MODEL NUMBER IPEX #PVC-UCVK.
- PROVIDE LOUVER IN DOOR AS MEANS OF AIR TRANSFER IN THE EVENT OF ACCESS CARBON MONOXIDE OR CARBON DIOXIDE DETECTION. BOTTOM OF LOUVER, 6' ABOVE BOTTOM OF DOOR.
- PROVIDE ANALOX AX80 OR APPROVED EQUAL CARBON DIOXIDE SENSOR WITH REMOTE ALARM REPEATER TO BE MOUNTED AT 18" AFF. PROVIDE CARBON DIOXIDE SENSOR WITH RELAY. RELAY SHALL BE INTERLOCKED WITH THE BUILDING FIRE ALARM SYSTEM. THE SENSOR SHALL BE EQUIPPED WITH A LOCAL AUDIBLE AND VISUAL ALARM. THE LOW LEVEL ALARM SHALL ACTIVATE THE LOCAL AUDIBLE AND VISUAL ALARM. THE HIGH LEVEL ALARM SHALL ACTIVATE RELAY. INSTALL SENSOR PER MANUFACTURER'S INSTALLATION INSTRUCTIONS.
- CARBON MONOXIDE DETECTOR FURNISHED BY OWNER. INSTALL AT 5'-0" AFF. COORDINATE FINAL LOCATION WITH OWNER REPRESENTATIVE.
- UP TO EF-1 ON ROOF.
- MOUNT RETURN AIR DUCTWORK TIGHT TO TOP OF SUPPLY DUCT. PROVIDE 1/4" GALVANIZED CONSTRUCTION. HARDWARE CLOTH SCREEN OVER OPEN END OF RETURN DUCT. PROVIDE DUCT LINER IN BOOT. RETURN AIR DUCT SHALL BE MINIMUM 36" HORIZONTAL EXTENSION FOR SOUND ATTENUATION.
- MOUNT SUPPLY AIR DUCTWORK TIGHT TO BOTTOM OF STRUCTURE.

ALL GREASE DUCT TO BE WATER TESTED BY ENVIROMATIC AT MECHANICAL CONTRACTOR'S EXPENSE. CONTACT OWNER'S NATIONAL ACCOUNT VENDOR*

ENVIROMATIC
DON PFLEDERER
1.800.325.8478
INSPECTIONS@ENVIROMATIC.COM

THE BUILDINGS HVAC SYSTEMS SHALL BE BALANCED BY NATIONAL TAB (NO EXCEPTIONS) AND CONTRACTED BY THE GENERAL CONTRACTOR.

CONTACT:
WILL TURNBOUGH
WILL@NATIONALTAB.COM
955-862-8822 ext1704


STORE NO:
1366

SHAKE SHACK
KENTLANDS SQUARE
1518 KENTLANDS SQUARE
GANTHERSBURG, MD 20874

REVISION

| NO. | DATE | DESCRIPTION |
|-----|----------|-----------------|
| 1 | 04/08/21 | CITY COMMENTS |
| 2 | 05/03/21 | OWNER REVISIONS |

STATUS:
PERMIT / BID SET



05/03/2021

FIELD VERIFICATION:
The contractor shall verify all signed dimensions and location of the project site and notify Zebra Architecture, LLC of any dimensional errors, or omissions or work. Do not commence field operations or fabricating any work. Do not proceed with any work.

COPYRIGHT © 2021:
Zebra Architecture, LLC, shall retain all common law, statutory and all other intellectual property rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.


SHEET NAME:
MECHANICAL FLOOR PLAN

DATE: 04/08/21 PROJECT NO: 2050004103

DRAWN: AJP SCALE: AS NOTED

SHEET NO:
M101


PROFESSIONAL CERTIFICATION
I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
PRINT NAME: JUSTIN M. OLDER
LICENSE #: 2198
EXPIRATION DATE: 1/8/2022




1 MECHANICAL FLOOR PLAN NTS

STORE NO:
1366

- MECHANICAL PLAN NOTES:**
- 1 MAINTAIN ALL OUTSIDE AIR INTAKES A MINIMUM OF 10'-0" RADIUS FROM EXHAUST, TYPICAL.
 - 2 TURN DOWN 6"Ø INTAKE AND END OPEN OVER ROOF (MIN. 24") WITH INSECT SCREEN.
 - 3 CONTRACTOR SHALL VERIFY WITH EQUIPMENT SUPPLIER EXACT ROUTING AND SIZE OF INSULATED REFRIGERANT PIPING. INSTALL PER MANUFACTURERS RECOMMENDATIONS.
 - 4 REFER TO HALTON DRAWINGS FOR INFORMATION REGARDING GREASE FAN GUARDS.
 - 5 PROVIDE EQUIPMENT WITH NATIONAL TAB UV-PH INDOOR AIR PURIFICATION SYSTEM, MODEL PHH-PKG-24V. INSTALL IN UNIT BLOWER COMPARTMENT PER MANUFACTURERS INSTRUCTIONS.



MECHANICAL ROOF PLAN
NTS



| REVISION | |
|----------|-----------------|
| DATE | DESCRIPTION |
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |
| | |
| | |

STATUS:
PERMIT / BID SET



05/03/2021

FIELD VERIFICATION:
The contractor shall verify all signed dimensions and condition of the project site and notify Zebra Architecture, LLC of any dimensional errors, or omissions on drawings before beginning or fabricating any work. Do not discharge before beginning or fabricating any work. Do not discharge before beginning or fabricating any work.

COPYRIGHT © 2021:
Zebra Architecture, LLC, shall retain all common law, statutory and all other reserved rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.

SHEET NAME:
MECHANICAL ROOF PLAN

| | |
|-------------------|---------------------------|
| DATE: 04/08/21 | PROJECT NO: 2050004103 |
| DRAWN: AJP | SCALE: AS NOTED |

SHEET NO:
M150

PROFESSIONAL CERTIFICATION
I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
PRINT NAME: JUSTIN M. OLDER
LICENSE #: 52138
EXPIRATION DATE: 1/8/2022


STORE NO:
1366

SHAKE SHACK
KENTLANDS SQUARE
158 MARKET STREET
CANTERSBURG, MD 20612

REVISION

| DATE | DESCRIPTION |
|----------|-----------------|
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |

STATUS:
PERMIT / BID SET



FIELD VERIFICATION:
The contractor shall verify all signed dimensions and location of the project site and notify Zebra Architecture, LLC of any dimensional errors, or omissions or work. Do not proceed until approved by the Engineer of Record.
COPYRIGHT © 2021:
Zebra Architecture, LLC shall retain all common law, statutory and all other intellectual rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.


SHEET NAME:
MECHANICAL DETAILS

DATE: 04/08/21 PROJECT NO: 2050004103


DRAWN: AJP SCALE: AS NOTED

SHEET NO:
M501


PROFESSIONAL CERTIFICATION
I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A FULLY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
PRINT NAME: JUSTIN M. OLDER
LICENSE #: 2050004103
EXPIRATION DATE: 1/8/2022




9 ROOF EQUIPMENT SUPPORT RAIL DETAIL NTS




10 ROUND AIR DUCT OR PIPE PENETRATION THROUGH ROOF DETAIL NTS




11 DOWNBLAST EXHAUST FAN DETAIL NTS




12 UPBLAST GREASE EXHAUST FAN DETAIL NTS




5 KITCHEN EXHAUST HOOD ELEVATION DETAIL NTS




6 DUCT HANGER LOWER ATTACHMENT DETAILS NTS




7 GREASE DUCT FIRE WRAP INSULATION INSTALLATION DETAIL NTS




8 GREASE DUCT CLEANOUT ACCESS DOOR DETAIL NTS




1 LAY-IN CEILING DIFFUSER DETAIL NTS



2 HARD CEILING DIFFUSER DETAIL NTS



3 DUCT MOUNTED REGISTER DETAIL NTS



4 CEILING CASSETTE DETAIL NTS

ENGINEER OF RECORD:

JUSTIN M. OLDER


8345 LENEKA DRIVE, SUITE 300
LENEKA, KS 66214
TEL 913.742.5000 FAX 913.742.5001
30201410
MO. CORPORATE NUMBER: 07 66969 EXPRES: 10/11/2021

STORE NO:
1366



| REVISION | |
|----------|-----------------|
| DATE | DESCRIPTION |
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |
| | |
| | |

STATUS:
PERMIT / BID SET



05/03/2021

FIELD VERIFICATION:
The contractor shall verify all signed dimensions and conditions of the project site and notify Zebra Architecture, PLLC of any dimensional errors, or omissions or discrepancies before beginning or finishing any work. Do not proceed otherwise.
COPYRIGHT © 2021: Zebra Architecture, PLLC. shall retain all common law, statutory and all other intellectual rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.


SHEET NAME:
MECHANICAL DETAILS

DATE: 04/08/21 PROJECT NO: 2050004103

DRAWN: AJP SCALE: AS NOTED


SHEET NO:
M502

PROFESSIONAL CERTIFICATION
I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
PRINT NAME: JUSTIN M. OLDER
LICENSE #: 52138
EXPIRATION DATE: 1/8/2022



- NOTES:**
1. PROVIDE OPENING THROUGH ROOF AND ROOF DECK INSULATION NO LARGER THAN REQUIRED TO ALLOW DUCTS TO PASS THROUGH. REFER TO PLANS FOR DUCT SIZES. TRANSITION AS REQUIRED IN ROOF CURB TO RTU SUPPLY AND RETURN OPENINGS.
 2. PROVIDE SLOPED ROOF CURB TO INSTALL ROOFTOP UNIT LEVEL TO ENSURE PROPER DRAINAGE. COORDINATE ROOF SLOPE WITH ARCHITECTURAL FLASH AND COUNTER FLASH ROOF PENETRATIONS, ETC. TO ENSURE WEATHER TIGHT INSTALLATION.

② ROOFTOP UNIT WITH DUCTWORK DETAIL NTS



- NOTES:**
1. CUT METAL DECKING TO ALLOW CURB INSTALLATION ON STEEL FRAMING. AFTER CURB IS SET IN PLACE, TRIM REMAINING METAL DECKING AND INSTALL WITHIN CURB. TACK WELD DECKING TO SUPPORT STEEL. DO NOT WELD INTERIOR DECKING TO ROOF CURB. PROVIDE ADDITIONAL CROSS FRAMING TO SUPPORT INTERIOR DECKING AND FILL MATERIAL AS REQUIRED.
 2. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS FOR ROOF CURBS, ANCHORING AND SEISMIC/WIND RESISTANCE.

① ROOF CURB DETAIL NTS

Division 23. TABLE OF CONTENTS

GENERAL MECHANICAL REQUIREMENTS

1. GENERAL INSTRUCTIONS

- A. GENERAL REQUIREMENTS
B. DEFINITIONS
C. PRE-BID SITE VISIT
D. MATERIAL AND WORKMANSHIP
E. MANUFACTURERS
F. COORDINATION
G. ORDINANCES AND CODES
H. PROTECTION OF EQUIPMENT AND MATERIALS
I. SUBSTITUTIONS
J. SUBMITTALS
K. ELECTRONIC DRAWINGS FILES
L. RECORD DRAWINGS (AS-BUILT DRAWINGS)
M. OPERATION AND MAINTENANCE INSTRUCTIONS
N. SPARE PARTS
O. TRAINING
P. WARRANTIES

2. GENERAL MATERIALS AND INSTALLATION

- A. BUILDING OPERATION
B. EXISTING EQUIPMENT REUSE AND REMOVAL
C. EXCAVATION AND BACKFILLING
D. COINCIDENTAL DAMAGE
E. CUTTING AND PATCHING
F. ROUGH-IN
G. STRUCTURAL SUPPORT SYSTEMS
H. PRE-ENGINEERED ROOF EQUIPMENT SUPPORTS AND CURBS
I. ACCESS PANELS AND DOORS
J. PENETRATIONS
K. FIRESTOPPING
L. MOTORS AND STARTERS
M. VARIABLE FREQUENCY DRIVES
N. ELECTRICAL WIRING
O. EQUIPMENT FURNISHED BY OTHERS
P. SYSTEM TESTING, ADJUSTING, AND BALANCING
Q. VIBRATION ISOLATION
R. SEISMIC CONTROLS FOR MEPP SYSTEMS
S. AIR FILTERS
T. REFRIGERANT AND OIL
U. IDENTIFICATION

3. DUCT INSULATION, DUCTWORK, ACCESSORIES, FLUES AND FANS

- A. DUCT INSULATION
B. DUCTWORK
C. FLEXIBLE DUCT
D. PLASTIC FLUE GAS VENTS
E. AIR DEVICES
F. CONTROL DAMPERS
G. EXHAUST AIR SYSTEMS
H. KITCHEN EXHAUST AIR SYSTEMS

4. HVAC EQUIPMENT

- A. CONDENSING UNITS (1.5-6 TONS)
B. FAN COIL UNITS (DIRECT EXPANSION, 1.5-5 TONS)
C. SPLIT DUCTLESS AIR-CONDITIONING SYSTEMS
D. NATURAL GAS RADIANT HEATERS

5. PIPING AND PIPING SPECIALTIES

- A. REFRIGERANT PIPING AND INSTALLATION
B. SYSTEM EVACUATION AND CHARGING

6. TEMPERATURE CONTROLS

- A. GENERAL REQUIREMENTS
B. WIRING
C. THERMOSTAT CONTROL EQUIPMENT
D. SENSORS AND RELAYS

7. SEQUENCE OF OPERATION

- A. FAN COIL UNIT CONTROL
B. KITCHEN EXHAUST FAN CONTROL
C. MAKE-UP AIR UNIT CONTROL
D. RESTROOM EXHAUST FAN (EF-1) CONTROL
E. OUTSIDE AIR FAN (OAF-1) CONTROL

8. ALTERNATIVES

- A. DESCRIPTION

9. COMMISSIONING OF MECHANICAL SYSTEM

- A. GENERAL
B. EXECUTION

Division 23. HEATING, VENTILATING, AND AIR CONDITIONING

A. GENERAL REQUIREMENTS

All requirements under Division 01 and the general and supplementary conditions of these specifications apply to this section and division. Where the requirements of this section and division exceed those of Division 01, this section and division take precedence.

The specifications and drawings for the project are complementary, and any portion of work described in one shall be provided as described in both. In the event of discrepancies, notify the Engineer and request clarification prior to proceeding with the work involved.

Drawings are graphic representations of the work upon which the contract is based. They show the materials and their relationships, locations, and connections. They convey the scope of work, indicating the intended general arrangement of the systems without showing all of the exact details, control lines, and other installation requirements.

B. DEFINITIONS

Division. References contained in this specification follow the numbering system defined in the Construction Specifications Institute (CSI) MasterFormat 2004 Edition. Specification Divisions 01 through 13 provided with this project are referred to as the CSI MasterFormat 1995 Edition.

- 1. Division 21 - Fire Suppression
2. Division 22 - Plumbing
3. Division 23 - HVAC
4. Division 24 - Electrical
5. Division 27 - Communications
6. Division 28 - Electronic Safety and Security

Furnish: "to supply and deliver to the project site, ready for unloading, unpacking, assembly, installation and similar operations." Install: "to perform all operations at the project site, including, but not limited to, the actual unloading, unpacking, assembling, erecting, placing, anchoring, applying, working to dimension, finishing, curing, protecting, cleaning, testing, commissioning, starting up and other operations, complete, and ready for the intended use."

Furnished by Owner (or Owner-Furnished) or Furnished by Others: "an item furnished by the Owner or under other divisions or contracts, and installed under the requirements of this division, complete and ready for intended use, including all items and services incidental to the work necessary for proper installation and operation. Include the installation under the warranty required by this division."

Engineer: Where referenced in this division, "Engineer" is the Engineer of Record and the Design Professional for the work under this division, and an authorized representative of the architect, as defined in the General and/or Supplementary Conditions. When used in this division, Engineer means increased involvement by and obligations to the Engineer, in addition to involvement by and obligations to the Architect.

AHJ: The local code and/or inspection agency (Authority) Having Jurisdiction over the work. NRTL: Nationally recognized testing laboratory, as defined and listed by OSHA in 29 CFR 1910.7 (e.g., UL, ETL, CSA), and acceptable to the AHJ over this project. Nationally recognized testing laboratories and standards listed are used only to represent the characteristics required and are not intended to restrict the use of other NRTLs that are acceptable to the AHJ and standards that meet the specified criteria.

Substitution: Changes in products, materials, equipment, and methods of construction from those required by the Contract Documents and proposed by Contractor. Substitutions include Value Engineering proposals. 1. Substitutions for Cause: Changes proposed by Contractor that are required due to changed Project conditions, such as unavailability of product, regulatory changes, or unavailability of required warranty terms.

The terms "approved equal," "equivalent," or "equal" are used synonymously and shall mean "accepted by or acceptable to the Engineer as equivalent to the item or manufacturer specified." The term "approved" shall mean labeled, listed, or both, by an NRTL, and acceptable to the AHJ over this project.

Prior to submitting bid, visit the site of the proposed work and become fully informed as to the conditions under which the work is to be done. Failure to comply with this requirement shall not be considered sufficient justification to request or obtain extra compensation over and above the contract price.

Provide new material, equipment, and apparatus under this contract unless otherwise stated herein, of best quality normally used for the purpose in good commercial practice, and free from defects. Install material and equipment in accordance with the manufacturer's installation instructions. Model numbers listed in the specifications or shown on the drawings are not necessarily intended to designate the required item, written descriptions of the item govern model numbers.

Pipe, pipe fittings, pipe specialties and valves shall be manufactured in plants located in the United States or certified to meet the specified ASTM and ANSI standards.

Work performed under this contract shall provide a neat and "workmanlike" appearance when completed, to the satisfaction of the Architect and Engineer. Workmanship shall be the finest possible by experienced mechanics. Installations shall comply with applicable codes and laws.

The complete installation shall function as designed and intended with respect to efficiency, capacity, noise level, etc. Abnormal noise caused by rattling equipment, piping, ducts, air devices, and squeaks in rotating components shall not be acceptable. Materials and equipment shall be of commercial specification grade in quality. Light duty and residential grade equipment shall not be accepted unless otherwise indicated.

Remove from the premises waste material present as a result of work, including cartons, crating, paper, stickers, and/or excavation material not used in backfilling, etc. Clean equipment installed under this contract to present a neat and clean installation at the termination of the work.

Repair or replace public and private property damaged as a result of work performed under this contract to the satisfaction of authorities and regulations having jurisdiction. Provide all safety lights, guards, and warning signs required for the performance of the work and for the safety of the public.

In other articles where lists of manufacturers are introduced, subject to compliance with requirements, provide products by one of the manufacturers specified. Where a list is provided, manufacturers are listed alphabetically and not in accordance with any ranking or preference.

Where manufacturers are not listed, provide products subject to compliance with requirements from manufacturers that have been actively involved in manufacturing the specified product for no less than 5 years.

Coordinate work with that of other trades so that the various components of the systems are installed at the proper time, will fit the available space, and will allow proper service access to those items requiring maintenance. Components which are installed without regard to the above shall be relocated at no additional cost to the Owner.

Unless otherwise indicated, the General Contractor shall provide chases and openings in building construction required for installation of the systems specified herein. Contractor shall furnish the General Contractor with information where chases and openings are required. Contractor shall keep informed as to the work of other trades engaged in the construction of the project and shall execute work in a manner as to not interfere with or delay the work of other trades.

Fixed dimensions shall be taken in preference to scale dimensions. Contractor shall take his own measurements at the building, as variations may occur. Contractor shall be held responsible for errors that could have been avoided by proper checking and inspection.

Provide materials with trim that will properly fit the types of ceiling, wall, or floor finishes actually installed. Model numbers listed in the specifications or shown on the drawings are not intended to designate the required item.

Work performed under this contract shall, at a minimum, be in conformance with applicable national, state and local codes having jurisdiction. Equipment furnished and associated installation work performed under this contract shall be in strict compliance with current applicable codes adopted by the local AHJ, including any amendments and standards as set forth by the following:

- 1. National Electrical Code (NEC)
2. National Fire Protection Association (NFPA)
3. Underwriters Laboratories (UL)
4. Occupational Safety and Health Administration (OSHA)
5. American Society of Mechanical Engineers (ASME)
6. American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE)
7. American National Standards Institute (ANSI)
8. American Society of Testing and Materials (ASTM)
9. Other national standards and codes where applicable.

Where the contract documents exceed the requirements of the referenced codes, standards, etc., the contract documents shall take precedence. Where conflicts between various codes, ordinances, rules, and regulations exist, comply with the most stringent.

Promptly bring all conflicts observed between codes, ordinances, rules, regulations, referenced standards, and these documents to the attention of the Architect and Engineer for final resolution. Contractor will be held responsible for any violation of the law.

Procure and pay for permits and licenses required for the accomplishment of the work herein described. Where required, obtain, pay for, and furnish certificates of inspection to Owner.

Store and protect from damage equipment and materials delivered to job site. For materials and equipment susceptible to changing weather conditions, dampness, or temperature variations, store inside in conditioned spaces. For materials and equipment not susceptible to these conditions, cover with waterproof, tear-resistant, heavy tarp or polyethylene plastic as required to protect from plaster, dust, dirt, paint, water, or physical damage. Restore insulation that has become wet at any time during construction. Drying the insulation is not acceptable. Seal any tears or joints of internal fiberglass insulation. Equipment and material damaged by construction activities shall be rejected and Contractor shall furnish new equipment and material of a like kind at his own expense.

Keep premises broom clean of foreign material created during work performed under this contract. Piping, equipment, etc. shall have a neat and clean appearance at the termination of the work. Remove debris from ceiling/return air plenum, including dust.

Plug, seal, or cap open ends of ductwork and piping systems while stored and installed during construction when not in use to prevent the entrance of debris into the systems. Remove temporary protection prior to starting equipment and turning the system over to the owner.

Materials, products, equipment, and systems described in the Bidding Documents establish a standard of required function, dimension, appearance and quality to be met by the proposed substitution.

The base bid shall include only the products from manufacturers specifically named in the drawings and specifications. To request a substitution, request the Substitution Request Form from the Architect or Engineer. Complete and send the Substitution Request Form for each material, product, equipment, or system that is proposed to be substituted. The burden of proof of the merit of the proposed substitution is upon the proposer.

Unless stated otherwise in writing to the Engineer by the Contractor, Contractor warrants to the Engineer, Architect, and Owner the following:

- 1. Proposed substitution has been fully investigated and determined to meet or exceed the specified Work in all respects unless otherwise indicated in the substitution request.
2. Proposed substitution is consistent with the Contract Documents and will produce indicated results, including functional clearances, maintenance service, and sourcing of replacement parts.
3. Proposed substitution has received necessary approvals having jurisdiction.
4. Same warranty will be furnished for proposed substitution as for specified Work.
5. If accepted substitution fails to perform as required, Contractor shall replace substitute material or system with that originally specified and bear costs incurred thereby.
6. Coordination, installation and changes in the Work as necessary for accepted substitution will be complete in all respects.

No substitutions will be considered unless the Substitution Request Form is completed and attached with the appropriate substitution documentation. No substitution will be considered prior to receipt of bids unless written request for approval to bid has been received by the Engineer at least ten (10) calendar days prior to the date of receipt of bids.

If the proposed substitution is approved prior to receipt of bids, such approval will be stated in an addendum. Bidders shall not rely upon approvals made in any other way. Verbal approval will not be given. No substitutions will be considered after the contract is awarded unless specifically provided in the contract documents.

J. SUBMITTALS

Assemble and submit for review shop drawings, material lists, manufacturer product literature for equipment to be furnished, and items requiring coordination between contractors under this contract. Provide submittals in sufficient detail so as to demonstrate compliance with these contract documents and the design concept. Prior to submitting submittals, verify that the equipment submitted is mutually compatible and suitable for the intended use, will fit the available space, and maintain manufacturer recommended service clearances. If the size of equipment furnished makes necessary any change in location or configuration, submit a shop drawing showing the proposed layout.

Transmit submittals as early as required to support the project schedule. Allow for two weeks Engineer review time, plus tollfree mailing to the Architect, plus a duplication of this time for resubmission, if required. Only submittals received by the Contractor, Contractor shall submit the submittals.

Submittals shall contain the project name, applicable specification section, submittal date, equipment identification acronym as used on the drawings, and the contractor's stamp. The contractor shall certify that the submittal has been checked by the Contractor, complies with the drawings and specifications, and is coordinated with other trades. Manufacturer product literature shall include shop drawings, product data, performance sheets, samples and other submittals required by this division. Highlight, mark, list, or indicate the materials, products, and accessories that are being proposed. General product catalog data not specifically noted to be part of the specified product will be rejected and returned without review.

Submittals and shop drawings shall not contain the firm name, logo, seal, or signature of the Engineer. They shall not be copies of the work product of the Engineer. If the Contractor desires to use elements of such product, refer to paragraph "Electronic Drawing Files" for procedures to be used.

Separate submittals according to individual specification sections. Illegible submittals will be rejected and returned without review. Catalog data shall be properly bound, identified, indexed and tabbed in a 3-ring binder. Each item or model number shall be clearly marked and accessories indicated. Label the catalog data with the equipment identification acronym or number as used on the drawings and include performance curves, capacities, sizes, weights, materials, finishes, wiring diagrams, electrical requirements and deviations from specified equipment or materials. For equipment with motor starters or VFDs, include short circuit current ratings. Mark out applicable items. Shop drawings will be returned without review if the above mentioned requirements are not met.

Provide the quantity of submittals required by Division 01. If not indicated and hard-copy sets are provided, submit a minimum of six (6) copies. Refer to Division 01 for acceptance of electronic submittals for this project. For electronic submittals, Contractor shall submit the documents in accordance with the procedures specified in Division 01. Contractor shall notify the Architect and Engineer that the submittals have been posted. If electronic submittal procedures are not defined in Division 01, Contractor shall include the website, user name, and password information needed to access the submittals. For submittals sent by e-mail, Contractor shall copy the designated representatives of the Architect and Engineer. Contractor shall allow for the Engineer review time as specified above in the construction schedule. Contractor shall submit only the documents required to purchase the materials and/or equipment in the submittal.

The checking and subsequent acceptance of submittals by the Engineer and/or Architect shall not relieve the Contractor from responsibility for deviations from the drawings and specifications, errors in dimensions, details, size of members, or quantities, omissions of components or fittings; coordination of electrical requirements; and not coordinating items with actual building conditions and adjacent work. Proceed with the procurement and installation of equipment only after receiving approved shop drawings relative to each item.

K. ELECTRONIC DRAWING FILES

In preparation of shop drawings or record drawings, Contractor may, at his option, obtain electronic drawing files in AutoCAD or DXF format on CD-ROM disk, DVD disk, flash drive or direct download, as desired, from the Engineer for a shipping and handling fee of \$200 for a drawing set up to 12 sheets and \$15 per sheet for each additional sheet. Contact the Architect for written authorization and Engineer for the necessary release agreement form and to specify shipping method and drawing format. In addition to payment, the written authorization from the Architect and release agreement form from the Engineer must be received before electronic drawing files will be sent.

L. RECORD DRAWINGS (AS-BUILT DRAWINGS)

During progress of the work in this division, Contractor shall maintain an accurate record of all changes made during the installation of the system. Upon completion of the work, accurately transfer all record information to three identical sets of the approved shop drawings. Insert one set into each copy of the manual described below.

See Division 01 and General Conditions for additional information.

M. OPERATION AND MAINTENANCE INSTRUCTIONS

During the course of construction, collect and compile a complete brochure of equipment furnished and installed on this project, including operational and maintenance instructions, manufacturer's catalog sheets, wiring diagrams, parts lists, approved submittals and shop drawings, warranties, and descriptive literature as furnished by the equipment manufacturer. Include an inside cover sheet that lists the project name, date, Owner, Architect, Engineer, General Contractor, Sub-Contractor, and an index of contents.

Submit three copies of literature bound in approved binders with index and tabs separating equipment types to the Architect, for Engineer's review, at the termination of the work. Paper clips, staples, rubber bands, loose-leaf binding, and mailing envelopes are not considered approved binders. Final approval of systems installed under this contract shall be withheld until the equipment brochure is received and deemed complete by the Architect and Engineer. Instruct workmen to save required literature shipped with the equipment itself for inclusion in this brochure. Include Record Drawings as described above.

Refer to Division 01 for acceptance of electronic manuals for this project. For electronic manuals, refer to paragraph "Submittals" for requirements.

N. SPARE PARTS

Furnish to Owner, with receipt, the following spare parts for the equipment furnished for this project: 1. One set of spare filters of each type required for each unit. In addition to the spare set of filters, install new filters prior to testing, adjusting, and balancing work and before turning system over to Owner. 2. Furnish one complete set of belts for each fan. 3. Furnish three operating keys for each type of air outlet and inlet that require them.

O. TRAINING

At a time mutually agreed upon between the Owner and Contractor, provide the services of a factory trained and authorized representative to train Owner's designated personnel on the operation and maintenance of the equipment provided for this project.

Provide training to include, but not be limited to, an overview of the system and/or equipment as it relates to the facility as a whole; operation and maintenance procedures and schedules related to startup and shutdown, troubleshooting, servicing, preventive maintenance and appropriate operator intervention; and review of data included in the operation and maintenance manuals.

Submit a certification letter to the Architect stating that the Owner's designated representative has been trained as specified herein. Letter shall include date, time, attendees and subject of training. The Contractor and the Owner's representative shall sign the certification letter indicating agreement that the training has been provided.

Schedule training with Owner with at least 7 days advance notice.

P. WARRANTIES

Warrant each system and each element thereof against all defects due to faulty workmanship, design, or material for a period of 12 months from date of Substantial Completion, unless specific items are noted to carry a longer warranty in the construction documents or manufacturer's standard warranty exceeds 12 months. Remedy all defects, occurring within the warranty period(s), as stated in the General Conditions and Division 01.

Warranties shall include labor and material, including travel expenses. Make repairs or replacements without any additional costs to the Owner, and to the satisfaction of the Owner, Architect, and Engineer.

Perform the remedial work promptly, upon written notice from the Engineer or Owner.

At the time of Substantial Completion, deliver to the Owner all warranties, in writing and properly executed, including term limits for warranties extending beyond the one year period and any actions the Owner must take in order to maintain warranty status. Each warranty instrument shall be addressed to the Owner and state the commencement date and term.

2. GENERAL MATERIALS AND INSTALLATION

A. BUILDING OPERATION

Comply with the schedule of operations as outlined in the architectural portions of this specification. Accomplish work requiring interruption of building operation at a time when the building is not in operation and will not require approval of building Owner and/or tenant. Coordinate interruption of building operation with the Owner and/or tenant a minimum of seven (7) days in advance of work.

B. EXISTING EQUIPMENT REUSE AND REMOVAL

Remove all unused equipment, ductwork, piping, and associated supports. Cap ductwork and piping at mains and seal air and water tight.

Provide items of HVAC systems modification required because of building remodeling, as noted on the drawings or necessary for proper operation. Match existing materials and construction techniques when modifying existing systems unless specified otherwise. Coordinate additional requirements with General Contractor and Architect.

Seal airtight existing ductwork required to be abandoned in place or not in use at the termination of the work.

Cap and seal weathertight existing roof curbs and roof openings to be abandoned in place as a result of equipment removal.

Clean and reface existing ductwork, diffusers, registers, and grilles intended for reuse as required or as indicated on drawings.

Clean and refurbish existing HVAC equipment intended for reuse as required for proper operation including replacement of filters, belts, motors, remote controls, and safety interlocks.

C. COINCIDENTAL DAMAGE

Repair streets, sidewalks, drives, paving, walls, finishes, and other facilities damaged in the course of the work. Repair materials shall match existing construction.

Repair work shall meet all requirements of the Owner, local authorities having jurisdiction, and meet the satisfaction of the Architect.

D. CUTTING AND PATCHING

Conform to the requirements in Division 01. Cut walls, floors, ceilings, and other portions of the facility as required to install work under this division. Obtain permission from the Architect prior to cutting. Do not cut or disturb structural members without prior approval from the Architect and Structural Engineer. For post-tension slabs, x-ray slab and closely coordinate all core drill locations with Architect and Structural Engineer prior to performing any work. Obtain approval from Architect and Structural Engineer for all core drills and penetrations at least four days prior to performing work. Penetrations shall be made as small as possible while maintaining required clearances between the building element penetrated and the system component.

Patch around openings to match the adjacent construction including fire ratings, if applicable. Repair and refinish areas disturbed by work to the condition of adjoining surfaces in a manner satisfactory to the Architect.

E. ROUGH-IN

Coordinate without delay all rough-in with other divisions. Conceal piping, conduit, and rough-in except in unfinished areas and where otherwise shown.

F. STRUCTURAL SUPPORT SYSTEMS

Structural steel used for support of equipment, ductwork and piping shall be new, clean, and conform to ASTM Designation A-36.

Support mechanical components from the building structure. Do not support mechanical components from ceilings, other mechanical or electrical components, and other non-structural elements.

G. PRE-ENGINEERED ROOF EQUIPMENT SUPPORTS AND CURBS

Provide prefabricated equipment support rails and roof curbs manufactured by AES Industries, Custom Curb, Inc., Pate Company, Thybar or approved equal. Provide with fully milled raised cant and step to match roof insulation thickness, welded, minimum 1/8 gauge galvanized steel rail, internally reinforced to load bearing factors of equipment being supported, minimum 1-1/2 inch long, 3 pound rigid insulation internally to shell to maintain continuous roof insulation where required, factory installed wood nailer, and minimum 1/8 gauge jacket with counterflashing where equipment does not fully cover the equipment support. Provide sloped roof equipment supports to enable level installation. Provide rigid backing material behind cant to maintain cant slope. Provide multi support rails to fully support the equipment. Attach to roof structure according to manufacturer's installation instructions.

Attach equipment directly to pre-engineered roof equipment support using one of the following methods: 1. Rail Equipment Supports: Secure each equipment support rail to the rail with a minimum of 4 points of connection per leg. 2. Roof Curbs: Secure each corner of the equipment to the curb nailer using a minimum of 4 lag screws, located along the length of the equipment. Alternatively, secure equipment to the curb using hold-down brackets. Provide minimum 6 inch long, 1/4 gauge galvanized steel brackets sized to wrap around top of curb and under equipment base rail with sufficient horizontal offset to cover overlap gap between the equipment rail and curb. Secure bracket to equipment and curb nailer using a minimum of 8 points of connection per bracket. Provide one bracket at each corner along the length of the unit.

3. Hold-down Brackets: Coordinate with the curb manufacturer to determine the quantity and size of hold-down brackets and fasteners, with installation instructions for each unit to meet a Building Design Risk Category of I and a Design Wind Speed of 115 mph. 4. Submit signed and sealed drawings that indicate the design and installation requirements of pre-engineered roof supports can withstand the design criteria listed. Include installation requirements for anchoring to the roof structure. The Engineer is not responsible and will not provide the seal and signature. Deliver submittals to the local AHJ for approval prior to installation of the contractor provided, pre-engineered roof supports. 5. Provide seismic restraints in accordance with Article "Seismic Controls for MEPP Systems."

H. ACCESS PANELS AND DOORS

Refer to Architectural documents for specification of access panels and doors.

Provide access doors for all concealed equipment and duct and piping accessories that require service where indicated or as required, except where above lay-in ceilings. Access doors shall be adequately sized for the devices served with a minimum size of 18 inches x 18 inches. Access doors must be of the proper construction for type of construction in which it is installed. Obtain Architect's approval of type, size, location and color before ordering. Provide factory-fabricated and assembled units, complete with attachment devices and fasteners ready for installation, concealed hinges, flush screwdriver-operated cam lock, and anchor straps. Provide access doors manufactured by Greenheck, Milcor, Tirus, Zum, or equal.

I. PENETRATIONS

Provide sleeves for pipes passing through above grade concrete or masonry walls, concrete floor or roof slabs. Sleeves are not required for core drilled holes in existing masonry walls, concrete floors or roofs. Provide 10 gauge galvanized steel sleeves for sleeves 6 inches and smaller. Provide galvanized steel sleeves for larger than 6 inches. Schedule 40 PVC sleeves are acceptable for installation in areas without return air plenums.

Seal elevated floor, exterior wall and roof penetrations watertight and weathertight with non-shrink, non-hardening commercial sealant. Pack with mineral wool and seal both ends with minimum of 1/2 inch of sealant.

Seal around penetrations of fire rated assemblies. Coordinate fire ratings and locations with the architectural drawings. Refer to architectural specifications for fire stoppings. Provide a product schedule for UL listing, location, wall or floor rating and installation drawing for each penetration fire stop system.

Extend pipe insulation for insulated pipe through floor, wall and roof penetrations, including fire rated walls and floors. The vapor barrier shall be maintained. Size sleeves for a minimum of 1 inch annular clear space between inside of sleeve and outside of insulation.

Provide prefabricated roof curbs where pipes and/or ductwork penetrations elevated the slabs or the roof to the exterior. Provide cover over curb of weather-resistant material and seal duct or pipe penetrations through the cover. Provide pipe collar of weather-resistant material with stainless steel pipe clamps for piping penetrations.

Provide box frames for rectangular openings welded 12 gauge galvanized steel attached to forms and of a maximum dimension established by the Architect. Notify the General Contractor or Architect before installing any box openings not shown on the Architectural or Structural drawings.

Seal concrete or masonry exterior wall penetrations below grade with "wall pipes" and mechanical sleeve seals. Provide cast iron "wall pipes" with integral waterstop ring manufactured by Jay R. Smith, Josam, Wade, Watts or Zum. Provide modular mechanical sleeve seals, manufactured by Catpico, Metastalk, or Thundefine / Link Seal.

Seal elevated concrete slab with wall pipe membrane penetrations with "wall pipes" and water proof sealant. Secure waterstop membrane flashing between wall pipe clamping flange and clamping ring. Provide cast iron "wall pipes" with integral waterstop ring manufactured by Jay R. Smith, Josam, Wade, Watts or Zum.

Provide sleeves for horizontal pipe passing through or under foundation. Sleeves shall be cast iron soil pipe two nominal pipe sizes larger than the pipe served.

Provide Schedule 40 PVC pipe sleeves for vertical pressure pipe passing through concrete slab on grade. Sleeves shall be one nominal pipe size larger than the pipe served and two pipe sizes larger than pipe served for ductile iron pipes with restraining rods. Seal water-tight with silicone caulk.

Provide 1/2 inch thick cellular foam insulation around perimeter of non-pressure pipe passing thru concrete slab on grade. Insulation shall extend to 2 inches above and below the concrete slab.

J. FIRESTOPPING

Sealants and accessories shall have fire-resistance ratings indicated, as established by testing identical assemblies in accordance with UL 2079 or ASTM E 814, or other NRTL acceptable to AHJ.

Manufacturers: Hilti, HectorSeal, Specified Technologies Inc., United States Gypsum Company, or 3M corp.

Through and Membrane Penetration Firestopping Systems Product Schedule: Provide UL listing, location, wall or floor rating, and installation drawing for each penetration fire stop system.

Where project conditions require modification to qualified testing and inspecting agency's illustrations for a particular firestopping condition, submit illustration, with modifications marked, approved by penetration firestopping manufacturer's fire-protector engineer as an engineering judgment or equivalent fire-resistance-rated assembly. Include qualifications data for testing agency.

K. MOTORS AND STARTERS

Provide motors and starting equipment where not furnished with the equipment package. Motors shall have copper windings, Class B insulation, and standard squirrel cage with starting torque characteristics suitable for the equipment served. Motors controlled by variable frequency drives shall be rated for voltage peaks and minimum rise times in accordance with NEMA MG-1, Part 31. Motors 5 horsepower and larger controlled by variable frequency drives shall be provided with a shaft grounding system equal to Aegis SCR Bearing Protection Ring, InproSeal Current Diverted Ring (CDR) or approved equal. Motors for air handling equipment shall be selected for quiet operation. Each motor shall be checked for proper rotation after electrical connection has been completed. Provide drip-proof enclosure for locations protected from weather and not in air stream of fan, and totally enclosed fan cooled enclosures for motors exposed to weather. Motors shall be manufactured by Century, General Electric, Louis Allis, Westinghouse, or approved equal.

Provide every motor, except fractional horsepower single phase motors with an approved type of "built-in" thermal overload protection, with a motor starter. Each starter shall be provided with overload heaters sized to the motor rating, and every three phase motor starter shall have overload heaters in each phase. Ambient compensated heaters shall be installed wherever necessary. Unless noted otherwise, motor starters shall be provided by the Division 23 Contractor for installation and connection by the Division 26 Contractor. Starters shall be Allen-Bradley, Clark, Furness, Square D, or approved equal.

L. VARIABLE FREQUENCY DRIVES

Provide PWM variable frequency drives (VFD) to control fan or pump motors as indicated on the drawings. Provide VFD as manufactured by AC Technology, Asea, Beckhoff, Danfoss, Danver, Danfoss, Reliance Electric, or Yaskawa. Include an integral, door-interlocked input circuit breaker or fused disconnect which may be padlocked in the "OFF" position.

Provide a magnetic contactor manual bypass integral to each drive. Provide two magnetic contactors, mechanically and electrically interlocked, to isolate the inverter output from line voltage. The inverter input shall be isolated by either a three magnetic contactor or a second disconnect switch to allow removal of power to the inverter for service while still operating the motor across the line. Bypass shall include a 120/180 control transformer, fused on both the primary and secondary, and bi-metallic thermal motor overload relays with adjustable trip settings.

Provide input AC line reactors without exception. Reactors shall be minimum 3 percent impedance, and "K" rated per IEEE C57-110 for harmonic current content. Reactors shall be integral to the drive enclosure without need for field wiring.

The VFD shall have an RS-485 port as standard. The standard protocols shall be Johnson Controls N2 bus, Modbus, and Siemens Building Technologies FLN. Optional protocols for BACnet, DeviceNet, Ethernet, LonWorks, and Profibus shall be available. Each individual drive shall have the protocol in the base VFD. The use of third party gateways and multiplexers is not acceptable. All protocols shall be "certified" by the governing authority. Use of non-certified protocols is not allowed. The VFD shall show the DDC system to control the digital and analog outputs of the drive via the serial interface. This control shall

2. Type SPNH (Spring and Neoprene Hangers): Provide a steel hanger box containing a laterally stable, double-deflecting neoprene isolator in series with steel spring. Design springs so the ratio of the horizontal to vertical spring constant is between one and two. The spring diameter shall not be less than 80 percent of the compressed height of the spring at rated load. Loaded springs shall operate within the linear portion of their load versus deflection curve over a deflection range of not less than 50 percent above design deflection. Spring diameter shall be large enough to permit the hanger rod to swing through a 30 degree arc. Include a neoprene bushing to prevent contact between the lower hanger rod and hanger box and short-circuiting the isolating function. The neoprene element shall have a maximum diameter of 50 and designed for 15 percent strain, with a static deflection of not less than 0.4 inches. Unless otherwise specified, the static deflection of SPNH hangers shall be 2 inches. Provide SPNH hangers with 1 inch static deflection for water suction heat pumps and fan-powered VAV terminal units. When installed, do not coat the spring element and do not allow the hanger box to rotate through a full 360 degree arc without encountering obstructions. Provide Mason Industries Type 30N or equal.

3. Type NR (Neoprene Bushing): Provide neoprene, rubber-in-shear bushings for lightweight (less than 100 pounds), suspended equipment with all horizontal and angle iron or Unistrut. Select all neoprene bushings with a minimum diameter of 50 and designed for 15 percent strain, with a static deflection of 0.15 inches. Provide Neoprene Bushing Type HMB or equal.

Q. AIR FILTERS
Provide AAF/Flanders Perfect Flat HC M6, Camfil F40 30/30, pleated, throwaway type filters, minimum MERV 8, or similar as manufactured by Air Filter, Inc., Biodynamic, Columbus, Koch, or approved equal, unless otherwise indicated.

Temporary filters used to protect openings in ductwork and inside equipment when permanent HVAC equipment is used during the construction period shall be pleated, throwaway type filters, minimum MERV 6.

R. REFRIGERANT AND OIL
Provide full refrigerant and oil charge in new air conditioning refrigeration systems, and maintain it for full term of the guarantee.

S. IDENTIFICATION
Provide manufacturer's standard pre-printed, semi-rigid snap-on or permanent adhesive, pressure-sensitive vinyl pipe markers. Color code pipe markers to comply with ANSI A13.1.

Install pipe markers on each HVAC piping system and include arrows to show normal direction of flow.

Locate pipe markers and color bands wherever piping is exposed to view in occupied spaces, machine rooms, accessible maintenance spaces (shafts, tunnels, plenums) and exterior non-enclosed locations.

Provide plastic laminate or brass valve tag on every valve, check and control device in each HVAC piping system; exclude check valves, valves within factory-fabricated equipment units, and shut-off valves at HVAC terminal devices and similar rough-in connections of end-use fixtures and units.

Provide manufacturer's standard laminated plastic, color coded equipment markers. Conform to the following color code: Green for Cooling; Yellow for Heating; Yellow/Red for Heating and Cooling; Brown for Energy Reclamation; Blue for other equipment types. Conform to ANSI A13.1 for Hazardous Equipment.

Provide stenciled signs for equipment identification at Contractor's option or where distance of required identification requires lettering larger than 1 inch height. Stencil paint shall be exterior type, oil-based, alkyl enamel, minimum 1/16 inch height or greater as required for long distance identification, white or black color for best contrast.

Provide duct markers or provide stenciled signs and arrows indicating ductwork service and flow direction in black or white lettering for best contrast with duct or insulation color. Locate markers maximum 50 feet along each duct side and within 5 feet of all control and balancing dampers or branch ducts and within 5 feet on each side of wall, floor, and ceiling penetrations. Provide additional markers in congested areas or at multiple duct runs as required for clarity.

3. DUCT INSULATION, DUCTWORK, ACCESSORIES, FLUES AND FANS
A. DUCT INSULATION
Provide fiberglass duct liner with fibers firmly bonded together with a thermosetting resin. Liner surface shall serve as a barrier against infiltration of dust and dirt, shall meet ASTM C1338 for fungi resistance, and shall be cleanable using duct cleaning methods and equipment outlined in National Air Conditioning Contractors Association (NACCA) duct cleaning guide. Install with liner adhesive and mechanical fasteners in accordance with manufacturer's instructions and recommendations. Ductwork sizes shown on drawings are inside clear dimensions. Increase sheet metal liner thickness in both directions where liner is installed.

Provide rectangular liner conforming to ASTM C1071, Type I or II that is 1-1/2 inch thick, 1-1/2 pound density, minimum R-6.0 Certainteed Corp. "Toughguard" or equivalent, Johns Manville, Owens-Corning, or Knaflex.

Provide round liner that is 1-1/2 inch thick, 4 pound density, minimum R-6.0 Johns Manville "Spiracoustic Plus" or equivalent, Certainteed or Owens-Corning.

Provide liner on the following interior air ducts and where specified on the drawings:
1. Exposed round and rectangular supply ductwork.
2. Exposed round and rectangular return ductwork.

At interface of lined and wrapped ductwork, overlap lined ductwork at least 2 feet beyond wrapped insulation.

Conduct concealed, rigid ductwork with ASTM C553, Type II flexible fiberglass insulation. Installed insulation shall be 2-inch thick, 3/4 pound density, minimum R-6 ductwork wrap, Certainteed or equivalent Johns Manville, Owens-Corning, or Knaflex with heavy-duty foil scrim-kraft facing, and with joints taped with 3/16 inch wide foil tape as follows:

1. Round and rectangular supply and return air ductwork.
2. Unlined Round and rectangular outside air ductwork.
3. Round and rectangular exhaust and relief air ductwork within 10 feet of exterior discharge.

Cover Outdoor air, Exhaust air and Relief air plenums connected to exterior louvers with 1-1/2 inch thick, 1.5 pound density, rigid fiberglass insulation conforming to ASTM C612, Class 2.

Insulating materials, adhesives, coatings, etc., shall not exceed flame spread rating of 25 and smoke developed rating of 50 per ASTM E84. Containers for mastics and adhesives shall have U.L. Label.

B. DUCTWORK
Provide galvanized steel ductwork and housings as shown on drawings. Construct ductwork including fittings and transitions in conformance with current SMACNA standards relative to gauge, tracing, joints, etc. Minimum thickness of duct shall be 26-gauge sheet metal. Reinforce housings and ductwork over 30 inches with 1-1/4 inch rings not less than 9" on centers, and closer if required for sufficient rigidity to prevent vibration. Support horizontal runs of duct from strap iron hangers on centers not to exceed 8'-0". Do not support ceiling grid, conduits, pipes, equipment, etc. from ductwork. Coordinate routing of ductwork with other contractors such that piping, electrical conduit, and associated supports are not routed through the ductwork.

Provide pre-engineered roof duct supports supports by Cooper B-Line, Elite Components, ERICO, FNW, Miro, PHD Manufacturing, PHP Systems, Roof Top Box, Unistrut (Akorre), Zsi Foster, or approved equal. Support ductwork on the roof with pre-engineered roof duct supports that are attached to the roof membrane, not requiring any attachment to the roof structure and not penetrating the roofing assembly, with embedded support fixtures as required to support the duct. Provide steel pedestal type supports with minimum 10x18 inch thermoplastic or rubber base or 4 inch wide closed-cell polyethylene block with length as required. Maintain minimum 6 inches clearance under duct to finished roof surface.

Coordinate with the pre-engineered roof duct support manufacturer to anchor the duct supports directly to the roof structure in accordance with the manufacturer's installation instructions or provide intermediate duct supports engineered to meet the wind resistance and seismic design criteria. Reference Section, "PRE-ENGINEERED ROOF EQUIPMENT SUPPORTS."

Construct non-VAV supply ducts to meet SMACNA positive pressure of 2 inches w.g. Construct Return, Outdoor and Exhaust ductwork upstream of fans to meet SMACNA negative pressure of 1 inch w.g. Construct exhaust ductwork downstream of fans to meet SMACNA positive pressure of 1 inch w.g.

Provide mill phosphatized or galvanized finish for exposed ductwork to be field painted. Shop treated sheet metal shall have galvanized metal primer applied in the shop after fabrication and prior to shipping.

Seal ductwork with heavy liquid sealant, Hardcoat Tongrip 601, Design Polymer DP 1010, United Mogli duct sealer or approved equal, applied according to sealant manufacturer's instructions. Seal all longitudinal and transverse ductwork joints airtight to meet SMACNA Seal Class A. Tapes and mastics shall be listed and labeled in accordance with UL 181A.

Provide radius elbows, turns, and offsets with a minimum centerline radius of 1-1/2 times the duct width. Where space does not permit full radius elbows, provide short radius elbows with a minimum of two continuous 90 degree turns. Varies only by the length of the bend. Provide mitered elbows where space does not permit radius elbows, where shown on the drawings, or at the option of the contractor with the engineer's approval. Mitered elbows less than 45 degrees shall not require turning vanes. Mitered elbows 45 degrees and greater shall have stainless turning vanes of same gauge as ductwork, rigidly fastened with gasket strip and screws. Ductwork vanes for mitered elbows shall be provided in all supply and exhaust ductwork and in return and outside air ductwork that has an air velocity exceeding 1000 fpm. Do not install vanes in grease ductwork. The use of square throat, radius heel elbows is prohibited. Remove and replace all installed elbows of this type with an approved elbow at no additional cost to the contractor.

Connect ducts to vibrating equipment and when transitioning between two different metallic duct materials (e.g., aluminum to galvanized steel) by means of flexible connectors. Flexible connectors shall be neoprene coated glass cloth canvas connections, Duro-Dyne, Elgen, Ventafabric or equal. Flexible connectors shall have a flame spread of 25 or less and smoke developed rating not higher than 50. Make airtight joints and install with minimum 1-1/2 inches slack.

Provide balancing dampers, manufactured by Cesco, Greenheck, Louvers & Dampers, Nalor Industries, Pottorf, Ruskin, Tamco, or approved equal, where shown on drawings and wherever necessary for complete control of air flow. Splitter dampers shall be controlled by locking quadrants, provide Young Regulator or Ventlok end bearings for the damper rod. Rectangular volume dampers shall be opposed blade interlocking type. Round volume dampers shall be single-blade type consisting of circular blade mounted to a shaft. Provide Flexmaster model ST1 or equal 45 degree rectangular/round side louvered taking with model B03 damper with locking quadrant and insulation built out for round ductwork branch takeoffs to individual air devices. Onlit damper at takeoff wiring duct damper is located downstream of takeoff.

Where access to dampers through a hard ceiling is required, provide a concealed, remote cable-operated, butterfly-type volume damper assembly with external worm gear operator. Damper assembly shall include duct casing with rolled blade stiffeners, reinforced blade, self-lubricating bearing, and remote operator mounting plate. External operator shall attach to damper as a single piece with no linkage adjustment required. Damper shall be adjustable through the diffuser frame with standard 1/4 inch nutdriver or flat screwdriver. Provide positive, direct, two-way damper control with no sleeves, springs or screw adjustments to come loose after installation. Provide cable length to span the distance from the damper to the remote operator location. Install damper in branch duct. Do not install in diffuser neck. Install remote operator on the back of the diffuser frame or side of a slot diffuser assembly to avoid bends and kinks in cable at manufacturer recommended intervals. Where approved by architect, a ceiling cup with cover plate may be used for approved cable operator. Provide round dampers by Metropolitan Air Technology model RT-250, Young's Regulator model 820-1200, or approved equal. Provide rectangular dampers by Metropolitan Air Technology model RT-250, Young's Regulator model 820-1200, or approved equal. Provide remote cable control by Metropolitan Air Technology model RT-250, Young's Regulator model 270-275, or approved equal.

Round or oval ductwork shall be FlakGroup Semco, United, Hercules industries or equal, sheetmetal, with smooth interior surface, with low pressure (duct pressure class up to and including 2 inches w.g.) Round ductwork gauges per the following table (reference SMACNA HVAC duct construction standards for gauges when pressures exceed 2 inches w.g.).

| Size | Duct Gauge | Fittings Gauge |
|--------------|------------|----------------|
| 14" & under | 26 | 24 |
| 15" thru 24" | 24 | 22 |
| 25" thru 36" | 20 | 20 |
| 36" thru 50" | 20 | 20 |
| 50" thru 60" | 18 | 18 |

Lewis & Lambert, Link Industries Lindab Safe, or approved equal factory-manufactured round ductwork and fittings may be substituted for specified round branch ductwork, at Contractors option. Heavy liquid joint sealant may be omitted on factory-manufactured round ductwork.

Low pressure (duct pressure class up to and including 2 inches w.g.) Fittings 24 inches in diameter and less shall be prefabricated, spot-welded and internally sealed. Continuously welded fittings larger than 24 inches in diameter. Fittings larger than 22 inches in diameter, 36 inch fittings and under, 20 gauge for larger sizes, 90 degree tees shall be conical type. Seal longitudinal and transverse ductwork joints airtight with heavy liquid sealant applied according to manufacturer's instructions.

Provide gauge thickness in medium pressure (duct pressure class 3 inches to 6 inches w.g.) ductwork as recommended by SMACNA.

C. FLEXIBLE DUCT
Low pressure (duct pressure class up to and including 2 inches w.g.) and medium pressure (duct pressure class 2.1 inch to 6 inches w.g.) flexible duct shall be Flexmaster type 8B, Thermflex type G-KM, M-KE, JPL type Silver Jacket, or equal (fire retardant polyethylene) protective vapor barrier, U.L. 161 Class 1, acoustical insulated duct, R-6.0 fiberglass insulation. Provide CPE liner with steel wire helix mechanically locked or permanently bonded to the liner.

Flexible duct runs shall not exceed 5 feet in length, and shall be installed fully extended and straight as possible avoiding tight turns. Install flexible duct in accordance with manufacturer's instructions. Support flexible duct at maximum 5 feet center and within 6 inches of bends. Bends shall not exceed a centerline radius of one duct diameter. Duct sag shall not exceed 1/2 inch. Supporting material in direct contact with the duct shall not be less than 1-1/2 inches in width.

Connect flexible duct to rigid metal duct or air devices as recommended by the manufacturer. At a minimum, install two wraps of duct tape around the inner core connection and a metallic or non-metallic cap over the tape and two wraps of duct tape or a clamp over outer jacket. Duct dampers shall be installed in accordance with UL-181B and marked 181B-C. Duct duct shall be labeled in accordance with UL 181B and marked 181B-F.

D. PLASTIC FLUE GAS VENTS
Provide UL 1738 listed plastic flue gas vents, with positive or negative flue pressure complying with NFPA 211 and suitable for condensing unit applications. Provide plastic flue vents with integral thermal overcoat protection. Provide devices with a soft plastic gasket to make an airtight seal against the mounting surface. Coordinate final location, frame, and mounting type of air devices with Architectural reflected ceiling plans.

Where plastic gas vents are installed in a return air plenum, wrap the vent with fire rated plenum insulation. Reference Article "Plenum Insulation" for plenum material application. Coordinate vent material compatibility with the appliance manufacturer's installation instructions prior to purchasing and installation.

D. AIR DEVICES
Provide air devices as scheduled on drawings, manufactured by Carnes, Krueger, Metalaire, Nalor Industries, Price, Trico, or Tuttle & Fane. Coordinate final location, frame, and mounting type of air devices with Architectural reflected ceiling plans.

Submit shop drawings including information on noise level, pressure drop, throw, CFM for each air device, sizes, borders, etc. Clearly mark with specified equipment number. Submit samples of each air device as requested by the Engineer.

Provide wall return air grilles and exhaust air registers with horizontal 35 or 45 degree angle vision-proof bars. Provide concealed fasteners for wall mounted registers and grilles. Provide floor supply air registers of aluminum heavy duty type with 0 degree deflection. Provide opposed blade dampers for supply air registers and exhaust air registers unless indicated otherwise.

Provide ceiling mounted air devices of lay-in or surface mounted type as required to be compatible with ceiling construction. Provide ceiling diffusers and grilles with white enamel finish unless noted otherwise.

Provide linear slot diffusers of standard one-piece lengths up to 6-feet and linear in multiple sections greater than 6-feet. Join multiple sections together and end with alignment pins to form a continuous slot appearance. For installations in a hard ceiling, install diffuser per manufacturer's installation instructions prior to installation of drywall. Contractor shall use manufacturer's hard ceiling clips for mounting to ceiling framing. Screws through linear slot diffuser are not acceptable. Provide alignment components by the manufacturer. Provide diffusers with a minimum 1/4 inch thick, fiberglass insulation.

E. CONTROL DAMPERS
Provide factory fabricated, parallel blade control dampers sized as shown on the drawings and as specified. Individual damper sections shall be not larger than 48 inches wide by 60 inches high with maximum blade width of 18 inches. Provide minimum 16 gauge galvanized steel for rectangular dampers, 20 gauge for round, 1/8 inch thick for aluminum, with flanges for duct mounting. Provide elastomeric or neoprene seals, mechanically actuated and field replaceable. Provide a minimum of one damper actuator per section. Test damper performance in accordance with AMCA 500-D.

Provide modulating dampers with linear flow characteristics. Size modulating dampers based on the smaller of 1,500 FPM through the damper or full open air pressure drop of 0.1 inches W.C. Size two-position dampers full duct size and select to minimize pressure drop.

Motorized dampers used for ventilation air intake, exhaust air, or relief air shall have leakage rates not to exceed 4.0 CFM/square foot in full closed position at 1 inch W.G. pressure differential across the damper.

Provide dampers as manufactured by Greenheck, CESCO, Pottorf, Nalor, or Ruskin. Reference manufacturer manual with model number for control air dampers is Ruskin CD-50 constructed of aluminum, and all other applications is Ruskin CD-35 constructed of galvanized steel.

Provide damper operator for each automatic damper with sufficient capacity to operate the damper under all conditions and to guarantee tight close-off of dampers against system pressure encountered. Each operator shall be provided with spring-return for normally closed or normally open position for fail safe operation to account for fire, low temperatures, or power interruption as required by the manufacturer on the drawings. Damper operators shall be manufactured by Belimo, Johnson Controls or approved equal. Provide transformer for damper motors if different voltages are required.

F. EXHAUST AIR SYSTEMS
Provide roof mounted exhaust fans as scheduled on the drawings, or equal ACME, Carnes, Cook, Greenheck, Pennbray, or Twin City Fans. Coordinate final location, frame, and mounting type of exhaust fans with Architectural reflected ceiling plans.

Provide roof mounted exhaust fans as scheduled on the drawings, or equal ACME, Carnes, Cook, Greenheck, Pennbray, or Twin City Fans. Coordinate final location, frame, and mounting type of exhaust fans with Architectural reflected ceiling plans.

Provide roof mounted exhaust fans as scheduled on the drawings, or equal ACME, Carnes, Cook, Greenheck, Pennbray, or Twin City Fans. Coordinate final location, frame, and mounting type of exhaust fans with Architectural reflected ceiling plans.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Exhaust fans serving Type I kitchen exhaust hoods shall discharge a minimum of 40 inches above the roof surface, shall have hinged access including access for blade inspection and cleaning per NFPA 96, grease drain trough filled with replaceable, absorbent material or stainless steel, and with clean-out access to prevent grease and rejects water, and insulated curb, and shall be installed in accordance with NFPA 96 and local codes.

Brazing filler metals:
1. AWS AS 8, Classification BAg-5, Silver (Ag) 44.0-46.0 percent, Zinc (Zn) 23.0-27.0 percent, and Copper (Cu) 29.0-31.0 percent.
2. AWS A5.8, Classification BAgP-5, Phosphorus (P) 4.8-5.2 percent, and Copper (Cu) remainder.

Brace mechanical joints. Solder joints connecting to refrigerant valves and specialties. Continuously purge the pipe and fittings during brazing with an inert gas per manufacturer's recommendation (e.g., dry nitrogen) to prevent formation of scale. Maintain purge until the joint is cool to the touch. Provide temporary cap or cover on completed joints with open ends to prevent entry of contaminating materials.

Insulate refrigerant lines with flexible elastomeric insulation, Armaflex or equal. Insulate suction and liquid lines between the expansion valve, evaporator, and compressor with 1/2 inch thick insulation on pipes less than 1 inch in size and 1 inch thick for pipes 1 inch and larger. Insulate hot gas and liquid lines between the compressor condenser, and expansion valve with 1 inch thick insulation on pipes less than 1-1/2 inch and 1-1/2 inch thick for pipes 1-1/2 inch and larger. Piping insulation shall have a flame spread of 25 or less, and a smoke developed rating of 50 or less when tested in accordance with ASTM E84. Coat insulation that is exposed to the elements with a protective sealer. Install and support piping to keep noise and vibration to a minimum.

Support and secure piping to Unistrut type supports so that no vibration passes to the building structure. Pipe attachments shall be copper-plated or have nonmetallic coating for electrolytic protection where attachments are in direct contact with copper tubing. Install a support within one foot of each change of direction. Mount pipe hangers around the outside of the insulation with saddles to prevent hangers from rupturing the insulation. Replace insulation that is cut or broken by the hangers.

Run refrigerant lines parallel and perpendicular to wall and floor lines and to appear straight and in good order. Pitch suction lines down slightly (1 inch in 20 feet) towards the compressor. Provide oil traps at the base of vertical suction risers over 6 feet high. Install liquid line sight glasses in liquid lines between the expansion valve. Factory mount expansion valves with the sensing bulbs shipped loose. Field mount expansion valve bulb after refrigerant piping is complete (damage may occur if bulbs come in contact with heat).

For systems of 5 ton capacity and smaller, the contractor shall have the option to provide copper refrigerant tubing line set sized as recommended by equipment manufacturer and of length as required for the installation. Break this vacuum by using flare tubing compression fittings, solder connections, or brazed connections as recommended by the manufacturer to match the connections of the condensing unit and evaporator coil.

B. SYSTEM EVACUATION AND CHARGING
Blow out refrigeration lines with dry nitrogen at a suitable pressure before making final connection at the condensing unit or coil to ensure against dirt, scale, or other foreign material being in the lines. Draw a vacuum to 29 inches of mercury. Break this vacuum by charging dry refrigerant gas into the system, raising the pressure to 0 PSIG. Repeat the latter two steps for a triple evacuation before the final evacuation is started. Make final evacuation by reducing the system to the absolute pressure to a maximum of 0.5 millimeters (500 microns) and allowing the pump to run at this pressure for a minimum of two hours.

Repeat the proper amount of refrigerant charge per the manufacturer's recommendations. Record the amount of refrigerant by weight charged into the system for each circuit recorded to the nearest 1/4 pound on tags and attach tags to the liquid line near the condensing unit. Refrigerant shall be supplied by the HVAC Contractor.

6. TEMPERATURE CONTROLS
A. GENERAL REQUIREMENTS
Provide a complete system of temperature controls including controllers, control panels, thermostats, sensors, time switches, override timers, actuators, relays, and wiring required to provide the desired control systems specified on the drawings.

Submit shop drawings of equipment provided for temperature control. Submit operation and maintenance data, including trouble-shooting maintenance guide, step-by-step procedures indexed for each controller and thermostat function, inspection period, cleaning methods and materials, and calibration tolerances.

Provide integrated wiring diagrams showing interconnections between field installed equipment and package wiring furnished with the HVAC equipment. Control wiring shall be sized to accommodate the voltage drop associated with the distance between the control device and the controller.

Provide supervision and on-job checkout service as required to ensure that installation and operation of the temperature control system meets requirements of the drawings, specifications, and schedules of operation. The system shall be guaranteed for a period of one year following the acceptance of the system by the Architect/Engineer. Correct defects occurring during this period at no additional cost to the Owner.

Install control devices with top of device at 48 inches AFF to meet ADA requirements unless otherwise noted on the plans.

B. WIRING
Provide electrical and control wiring as specified under the section "Electrical Wiring."

C. THERMOSTAT CONTROL EQUIPMENT
Manufacturers and model numbers are listed for reference as to quality and features required for the control devices. Provide control devices by Honeywell with quality and features as indicated. Seven day programmable, occupied/unoccupied thermostats for on/off or multiple stages of heating and cooling systems shall be Honeywell series T7350 or equal with integral subbase. Order thermostat with multi-stage capability as required to match scheduled unit cooling/heating stages.

Remote sensors integrated with the seven day programmable thermostat shall be Honeywell TR21/TR21H remote sensor.

D. SENSORS AND RELAYS
Provide general-purpose type elements for use in input and output sensors. Provide transmitters or transducers with sensor as required, compatible with the controllers used, with range suitable for the systems encountered. Transmitters and transducers shall have offset and span adjustments, temperature compensation, shock and vibration immunity, and zeroing capability. Accuracy requirements shall include the combined effects of linearity, hysteresis, repeatability, and the transmitter.

Dry-bulb temperature sensors at a minimum shall be accurate to +/- 2 degrees Fahrenheit over the range of 40 to 80 degrees Fahrenheit. Wet-bulb temperature sensors shall be calculated using dry-bulb temperature and humidity and shall be accurate to +/- 2 degrees Fahrenheit. Enthalpy shall be calculated using dry-bulb temperature and humidity and shall be accurate to +/- 3 BTU/lb over the range of 20 to 36 BTU/lb. Humidity sensors at a minimum shall be accurate within +/- 3 percent full scale with

| ROOFTOP UNIT CONTROL MATRIX | | | | |
|--|-------|--------------------------------------|--|-------|
| CONTROL FEATURE | UNITS | RTU-1 DRING SETPOINT OR Y/N | RTU-2 KITCHEN SETPOINT OR Y/N | NOTES |
| SETPOINTS | | | | |
| COOLING - OCCUPIED SETPOINT | "F | 75 | 75 | |
| COOLING - UNOCCUPIED SETPOINT | "F | 80 | 80 | |
| HEATING - OCCUPIED SETPOINT | "F | 70 | 70 | |
| HEATING - UNOCCUPIED SETPOINT | "F | 60 | 60 | |
| DEHUMIDIFICATION SETPOINT - HUMIDITY SENSOR FEEDBACK | % RH | 50% | 50% | B |
| PROGRAMMED CONTROL FEATURES | | | | |
| HVAC SYSTEM OCCUPIED/UNOCCUPIED MODE - PROGRAMMABLE THERMOSTAT | | Y | Y | B |
| REMOTE TEMPERATURE SENSOR | | Y | Y | B |
| EQUIPMENT ACCESSORIES AND CONTROL MODULES | | | | |
| OUTSIDE AIR DAMPER - MOTOR OPERATED (MODULATING) | | Y | Y | L |
| INTEGRATED ECONOMIZER - DIFFERENTIAL ENTHALPY ENABLE (OA ENTHALPY + RA ENTHALPY) | BTULB | Y | Y | E |
| ECONOMIZER FAULT DETECTION AND DIAGNOSTICS (FDD) SYSTEM | | Y | Y | F, G |
| RELIEF - BAROMETRIC DAMPER | | Y | N | H |
| RELIEF - CONSTANT VOLUME POWERED EXHAUST FAN | | N | Y | H |
| COOLING COIL (DX - STAGED) | | Y | Y | M |
| DEHUMIDIFICATION - HOT GAS REHEAT | | Y | Y | O |
| HEATING COIL (NATURAL GAS) | | Y | Y | M |
| SUPPLY FAN CONTROL METHODS | | | | |
| ON DURING OCCUPIED HOURS | | Y | Y | |
| CYCLE WITH LOADS DURING UNOCCUPIED HOURS | | Y | Y | |
| CONSTANT VOLUME FAN CONTROL | | Y | Y | |
| SAFETIES, INTERLOCKS, AND ALARMS | | | | |
| GAS VALVE SAFETY | | Y | Y | F |
| RETURN AIR SMOKE DETECTOR - SAFETY SHUTDOWN | | Y | Y | U |
| FIRE ALARM CONTROL PANEL - SAFETY SHUTDOWN INTERLOCK | | Y | Y | |
| KITCHEN EXHAUST SYSTEM INTERLOCK | | Y | Y | S |

DIV. 23 CONTRACTOR SHALL PROVIDE CONTROL PANEL(S), WIRING, THERMOSTAT(S), TEMPERATURE SENSOR(S), HUMIDISTAT(S), AND/OR CO2 SENSOR(S) WHERE SHOWN ON THE DRAWINGS AND AS REQUIRED TO FACILITATE THE SCHEDULED CONTROL, MODULES AND SEQUENCES OF OPERATION. EACH UNIT SHALL CONTROL BASED ON ITS OWN INTERNAL SAFETIES, TIME DELAYS, AND SEQUENCES UNLESS NOTED OTHERWISE. COORDINATE WITH OWNER FINAL BUILDING AND EQUIPMENT SCHEDULES DURING STARTUP. REFERENCE DIVISION SPECIFICATIONS FOR INDIVIDUAL DEVICE REQUIREMENTS.

NOTES:

B. DIVISION 23 CONTRACTOR SHALL PROVIDE DEVICE.

E. IF SETPOINT VALUE IS LISTED, IT INDICATES ECONOMIZER HIGH LIMIT SHUTOFF. UNIT SHALL BE IN ECONOMIZER IF CONDITIONS ARE LESS THAN SETPOINT. THE FOLLOWING SENSORS SHALL DETERMINE ECONOMIZER ON POINT.

OUTSIDE AIR TEMPERATURE: DIVISION 23 PROVIDED AS PART OF ECONOMIZER CONTROL MODULE.

RETURN AIR TEMPERATURE: DIVISION 23 PROVIDED AS PART OF ECONOMIZER CONTROL MODULE.

OUTSIDE AIR HUMIDITY: DIVISION 23 PROVIDED AS PART OF ECONOMIZER CONTROL MODULE.

RETURN AIR HUMIDITY: DIVISION 23 PROVIDED AS PART OF ECONOMIZER CONTROL MODULE.

F. DEVICE SHALL BE FACTORY MOUNTED AND PRE-WIRED FOR OPERATION SUBJECT TO THE ONBOARD CONTROLLER.

G. PROVIDE UNIT WITH AN FDD SYSTEM CONSISTING OF PERMANENTLY INSTALLED OUTSIDE AIR, SUPPLY AIR, AND RETURN AIR TEMPERATURE SENSORS. THE UNIT CONTROLLER SHALL AT A MINIMUM BE CAPABLE OF PROVIDING SYSTEM STATUS OF ECONOMIZER, COMPRESSOR, HEATING, MIXED AIR LOW LIMIT ALARM, AND SENSOR VALUES. EACH OPERATING MODE SHALL BE CAPABLE OF INDEPENDENTLY OPERATING FOR TESTING. THE SYSTEM SHALL REPORT FAILS TO AN APPLICATION ACCESSIBLE BY SERVICE PERSONNEL. THE FOLLOWING FAILS SHALL BE DETECTED: AIR TEMPERATURE SENSOR FAILURE, ECONOMIZER ENABLE/DISABLED WHEN ECONOMIZER SHOULD BE OFF, RESPECTIVELY, DAMPER NOT MODULATING, AND EXCESS OUTSIDE AIR.

H. POWERED EXHAUST FAN SHALL STAGE ON AND OFF ACCORDING TO DAMPER POSITION.

L. EQUIPMENT MANUFACTURER SHALL PROVIDE MODULATING DAMPER AND CONTROLS CAPABLE OF ADJUSTING THE DAMPER POSITION TO MAINTAIN THE SCHEDULED OUTSIDE AIR ON THE DRAWINGS ACROSS ALL FAN SPEEDS. DIV. 23 CONTRACTOR SHALL PROGRAM MULTIPLE DAMPER POSITION SETPOINTS IN THE FIELD DURING TESTING AND BALANCING TO MAINTAIN MINIMUM VENTILATION WHEN NOT IN ECONOMIZER. DAMPER SHALL BE CLOSED DURING UNOCCUPIED HOURS.

M. UNITARY CONTROLLER SHALL MODULATE AND/OR CYCLE SUPPLY FAN SPEED SETTING AND COIL CAPACITY SETTINGS SUBJECT TO THE INTERNAL SAFETIES AND SEQUENCES TO MAINTAIN SCHEDULED SETPOINTS.

O. PROGRAM DEHUMIDIFICATION EXCESS BASED ON ZONE AIR HUMIDITY.

S. INTERLOCK RTU WITH KITCHEN EXHAUST HOOD SYSTEM(S) TO SHUT DOWN UPON SIGNAL FROM HOOD FIRE EXTINGUISHING SYSTEM. INTERLOCK RTU WITH KITCHEN EXHAUST FAN TO ENERGIZE WHEN HOOD SYSTEM IS ENERGIZED FOR PRESSURIZATION.

U. DIVISION 28 CONTRACTOR SHALL PROVIDE DEVICE.

| BUILDING AIR BALANCE SUMMARY NORMAL OPERATION | | | | |
|---|--------------|---------------|---------------|---------------|
| UNIT NO. | SUPPLY (CFM) | OUTDOOR (CFM) | EXHAUST (CFM) | PERCENT OA/SA |
| MAU-1 | 2,250 | 2,250 | -- | 100% |
| RTU-1 | 4,500 | 1,300 | -- | 29% |
| RTU-2 | 4,800 | 1,120 | -- | 23% |
| FCU-1 | 420 | 40 | -- | 10% |
| KEF-1 | -- | -- | 1,958 | -- |
| KEF-2 | -- | -- | 1,846 | -- |
| EF-1 | -- | -- | 300 | -- |
| TOTAL | 11,970 | 4,710 | 4,104 | -- |
| DESIGN BUILDING PRESSURIZATION AIRFLOW (CFM) | | | | 606 |
| PRESSURIZATI... | | | | 13% |

| BUILDING AIR BALANCE SUMMARY ECONOMIZER MODE | | | | |
|---|--------------|---------------|---------------|---------------|
| UNIT NO. | SUPPLY (CFM) | OUTDOOR (CFM) | EXHAUST (CFM) | PERCENT OA/SA |
| MAU-1 | 2,250 | 2,250 | -- | 100% |
| RTU-1 | 3,015 | 3,015 | -- | 100% |
| RTU-2 | 3,216 | 3,216 | -- | 100% |
| FCU-1 | 420 | 40 | -- | 10% |
| KEF-1 | -- | -- | 1,958 | -- |
| KEF-2 | -- | -- | 1,846 | -- |
| EF-1 | -- | -- | 300 | -- |
| BAROMETRIC RELIEF RTU-1 | -- | -- | 1,715 | -- |
| POWER EF RTU-2 | -- | -- | 2,096 | -- |
| TOTAL | 8,901 | 8,521 | 7,915 | -- |
| DESIGN BUILDING PRESSURIZATION AIRFLOW (CFM) | | | | 606 |
| PRESSURIZATI... | | | | 7% |

| PROJECT DESIGN CONDITIONS | | | | | | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|--|-------------------------------|--|--|--|--|
| CLIMATE CONDITIONS | | | | | | | | | | BUILDING... | | | | |
| WEATHER STATION: LESSBURG EXECUTIVE, VA, USA | | | | | | | | | | MONDAY - FRIDAY: TBD BY OWNER | | | | |
| CLIMATE ZONE: 4A | | | | | | | | | | SATURDAY: TBD BY OWNER | | | | |
| HEATING (DB): 65.0% 14.2 "F | | | | | | | | | | SUNDAY: TBD BY OWNER | | | | |
| COOLING (DB/MCBW): 0.4% 95 "F/ 76.3 "F/ | | | | | | | | | | HOLIDAY: TBD BY OWNER | | | | |
| SPACE / UNIT DESCRIPTION | | | | | | | | | | | | | | |
| SET POINTS | | | | | | | | | | | | | | |
| COOLING / DE-HUMIDIFICATION | | | | | | | | | | | | | | |
| HEATING | | | | | | | | | | | | | | |
| HUMIDIFICATION | | | | | | | | | | | | | | |
| ZONE VENTILATION RESET | | | | | | | | | | | | | | |
| SPACE OPERATING HOURS OCCUPIED / UNOCCUPIED | | | | | | | | | | | | | | |
| NOTES | | | | | | | | | | | | | | |

NOTES:

A. ZONE LEVEL SET POINT CONDITIONS SHALL BE AS SCHEDULED UNLESS OTHERWISE SCHEDULED OR NOTED ON THE DRAWINGS FOR ROOM SPECIFIC SPACE CONDITIONS.

B. ZONE LEVEL OCCUPANCY HOUR SCHEDULE SHALL BE PER BUILDING OPERATING HOURS UNLESS OTHERWISE SCHEDULED.

C. ZONE LEVEL CONTROLS SHALL BE CAPABLE OF OPERATING WITH INDEPENDENT OCCUPANCY SCHEDULES.

| ROOFTOP UNIT SCHEDULE (DX COOLING, NATURAL GAS HEAT) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--------------|---------|--------------|-------------|------------|----------|-----------|-----------|----------|--------------|-------------|-------------|-----------|---------------|----------------|---------------|-----------------|--|-------------|---------|------|------|------|-----------|--------------|-------|---------------|---------------|-----------|------|-----|
| MARK | MANUFACTURER | MODEL | NOMINAL TONS | UNIT TYPE | SUPPLY FAN | | | | | COOLING COIL | | | | | HEAT EXCHANGER | | | | | MIN OIA | VIPH | MCA | MOCP | DISC TYPE | WEIGHT (LBS) | NOTES | | | | | |
| | | | | | CFM | ESP (IN) | BHP (Y/N) | VFD (Y/N) | TH (MBH) | SH (MBH) | EAT (°F WB) | LAT (°F WB) | REFR TYPE | MIN EFF (EER) | MIN NO STAGES | MIN OUT (MBH) | NOM INFLP (MBH) | HEAT PUMP HEATING COIL MIN EFF (°F DB) (°F WB) | EAT (°F DB) | | | | | | | | MIN NO STAGES | MIN OUT (CFM) | | | |
| RTU-1 | CARRIER | 48HDD17 | 15 | SINGLE ZONE | 4,500 | 0.5 | 1.23 | N | 188.9 | 115.9 | 80.8 | 68.5 | 57.8 | 55.6 | R410A | 12 | 13 | 2 | 178 | 220 | 81 | 53.9 | 90.3 | 2 | 1300 | 2063 | 69.2 | 90 | NON-FUSED | 2002 | A-R |
| RTU-2 | CARRIER | 48HDC17 | 15 | SINGLE ZONE | 4,800 | 0.5 | 1.45 | N | 173.4 | 122.9 | 79.8 | 66.6 | 56.5 | 55.1 | R410A | 12 | 13 | 2 | 178 | 220 | 81 | 57 | 91.2 | 2 | 1120 | 2063 | 69.2 | 90 | NON-FUSED | 2002 | A-R |

* EQUIPMENT FURNISHED AND INSTALLED PER THE RESPONSIBILITY SCHEDULE. REF ARCHITECTURAL DRAWINGS. EQUIPMENT SHALL BE OBTAINED THROUGH SHAKE SHACK NATIONAL ACCOUNT. REFER TO T12 / VENDOR LIST FOR MORE INFORMATION. MODEL NUMBERS AND NOMINAL TONS LISTED SHALL NOT BE CONSIDERED COMPLETE AND MATERIAL SHALL NOT BE ORDERED BY MANUFACTURER, MODEL NUMBERS, OR NOMINAL TONS ONLY. REVIEW THE COMPLETE DESCRIPTION, NOTES AND SPECIFICATIONS TO DETERMINE THE EXACT MATERIAL AND ACCESSORIES TO BE ORDERED. THE MANUFACTURERS LISTED ARE THE BASIS FOR THE DESIGN.

NOTES:

A. REFER TO ROOFTOP UNIT CONTROL MATRIX FOR CONTROL FEATURES, MODULES, AND ACCESSORIES THAT SHALL BE PROVIDED WITH THE EQUIPMENT.

B. EQUIPMENT SIZED FOR 100°F AMBIENT TEMPERATURE.

C. PROVIDE 2" MERV 8, EFFICIENT PLEATED THROWAWAY AIR FILTERS.

D. PROVIDE FACTORY MOUNTED DISCONNECT INSTALLED ON SERVICE SIDE OF UNIT.

E. STARTERS FOR ALL MOTORS SHALL BE FURNISHED INTEGRAL WITH UNIT.

F. PROVIDE FACTORY MOUNTED VARIABLE FREQUENCY DRIVE OR 2-SPEED MOTOR TO FACILITATE STAGED FAN SPEED CONTROL.

G. PROVIDE SINGLE POINT POWER CONNECTION.

H. COORDINATE SIZE OF CONDUCTOR TERMINATION LUGS WITH CONDUCTOR SIZES SHOWN ON ELECTRICAL DRAWINGS.

I. PROVIDE 125 VAC, 20 AMP DUPLEX CONVENIENCE RECEPTACLE MOUNTED TO UNIT READY FOR FIELD WIRING WITH A COVER UL LISTED FOR WET AND DAMPER LOCATIONS WHEN IN USE.

J. SPECIFIED FAN ESP ACCOUNTS FOR DUCT LOSSES EXTERNAL TO UNIT.

L. PROVIDE MOTOR HORSEPOWER TO OVERCOME INTERNAL UNIT STATIC PRESSURE DROP PLUS SPECIFIED EXTERNAL STATIC PRESSURE DROP. NOMINAL MOTOR HP SHALL BE NO LARGER THAN THE FIRST AVAILABLE NOMINAL MOTOR SIZE GREATER THAN THE REQUIRED BHP.

M. PROVIDE INSULATED ROOF CURB WITH MINIMUM HEIGHT REQUIRED TO MAINTAIN BOTTOM OF EQUIPMENT A MINIMUM OF 18 INCHES ABOVE FINISHED ROOF SURFACE. PROVIDE SLOPED CURB IF NEEDED TO MATCH ROOF SLOPE.

N. COORDINATE WITH ROOF INSULATION THICKNESS AND ROOF TAPER AT INSTALLED LOCATION. COORDINATE CURB TYPE WITH DRAWINGS.

K. SCHEDULED WEIGHT IS THE MAXIMUM ALLOWABLE OPERATING WEIGHT OF THE EQUIPMENT ONLY.

O. COOLING COIL LAT IS LEAVING AIR TEMPERATURE OF COIL.

P. PROVIDE GUARDS TO PROTECT CONDENSER COIL FROM HAIL OR OTHER DAMAGE.

Q. PROVIDE HEATER TO MEET OR EXCEED SCHEDULED MINIMUM MBH OUTPUT. NOMINAL INPUT IS BASED ON LISTED MANUFACTURER'S STANDARD PRODUCT. COORDINATE EQUIPMENT GAS LOAD WITH PLUMBING CONTRACTOR IF DIFFERENT FROM THAT SCHEDULED. MEET MINIMUM EFFICIENCY SCHEDULED.

R. PROVIDE EQUIPMENT WITH AIRBORNE DISINFECTION SYSTEM, RGF MODEL PHI-PK14-24V.

| AIR CURTAIN SCHEDULE | | | | | | | | | |
|----------------------|----------------|--------------|-------|-------------|-------------|-----------------------|------------|---------|-------|
| MARK | SERVICE AREA | MANUFACTURER | MODEL | UNIT SPECS | | | | VIPH/Hz | NOTES |
| | | | | LENGTH (IN) | MAX AIRFLOW | HEATING CAPACITY (KW) | MOTOR (HP) | | |
| AC-1 | SERVICE ENTRY | MARS | STD2 | 36 | 1379 | N/A | 1/2 | 115/1 | A-E |
| AC-2 | CARRYOUT ENTRY | MARS | PH10 | 36 | 1460 | 12 | 1/2 | 208/3 | A-E |

MODEL NUMBERS SHALL NOT BE CONSIDERED COMPLETE AND MATERIAL SHALL NOT BE ORDERED BY MANUFACTURER AND MODEL NUMBERS ONLY. REVIEW THE COMPLETE DESCRIPTION, NOTES AND SPECIFICATIONS TO DETERMINE THE EXACT MATERIAL AND ACCESSORIES TO BE ORDERED. THE MANUFACTURERS LISTED ARE THE BASIS FOR THE DESIGN.

NOTES:

A. EQUIPMENT FURNISHED AND INSTALLED PER THE RESPONSIBILITY SCHEDULE, REF ARCHITECTURAL DRAWINGS.

B. MOUNT UNIT PER MANUFACTURERS RECOMMENDATIONS TO FACE OF WALL AND SUPPORT VERTICALLY.

C. PROVIDE INTEGRAL STARTER AND DISCONNECT SWITCH.

D. PROVIDE AIR CURTAIN WITH NORMALLY CLOSED DOOR LIMIT SWITCH FOR INSTALLATION ON DOOR. THE AIR CURTAIN SHALL ENERGIZE WHEN DOOR OPENS.

E. PROVIDE WITH DELAY MICROSWITCH WITH ADJUSTABLE DELAY TIMERS PRE MOUNTED IN THE AIR CURTAIN CONTROL PANEL.

F. MOUNT UNIT PER MANUFACTURERS RECOMMENDATIONS IN CEILING ASSEMBLY AND SUPPORT VERTICALLY.

| LOUVER SCHEDULE | | | | | | |
|-----------------|---------|--------------|-------|----------------|---------------------|-------|
| MARK | SERVICE | MANUFACTURER | MODEL | SIZE (W" x H") | MIN. FREE AREA (SF) | NOTES |
| | | | | | | |

MODEL NUMBERS SHALL NOT BE CONSIDERED COMPLETE AND MATERIAL SHALL NOT BE ORDERED BY MANUFACTURER AND MODEL NUMBERS ONLY. REVIEW THE COMPLETE DESCRIPTION, NOTES AND SPECIFICATIONS TO DETERMINE THE EXACT MATERIAL AND ACCESSORIES TO BE ORDERED. THE MANUFACTURERS LISTED ARE THE BASIS FOR THE DESIGN.

NOTES:

A. EQUIPMENT FURNISHED AND INSTALLED PER THE RESPONSIBILITY SCHEDULE, REF ARCHITECTURAL DRAWINGS.

B. PROVIDE PRIME COAT FINISH. FIELD PAINT COLOR SELECTED BY ARCHITECT.

C. PROVIDE SELF ATTACHING, VANDAL-PROOF FRAME.

| UNIT HEATER SCHEDULE (ELECTRIC) | | | | | | | | | |
|---------------------------------|--------------|-------|---------------|----------|------------------|-----|------------|------|-------|
| MARK | MANUFACTURER | MODEL | MIN OUT (MBH) | NOM (KW) | MIN NO OF STAGES | CFM | MOTOR AMPS | VIPH | NOTES |
| | | | | | | | | | |

MODEL NUMBERS SHALL NOT BE CONSIDERED COMPLETE AND MATERIAL SHALL NOT BE ORDERED BY MANUFACTURER AND MODEL NUMBERS ONLY. REVIEW THE COMPLETE DESCRIPTION, NOTES AND SPECIFICATIONS TO DETERMINE THE EXACT MATERIAL AND ACCESSORIES TO BE ORDERED. THE MANUFACTURERS LISTED ARE THE BASIS FOR THE DESIGN.

NOTES:

A. EQUIPMENT FURNISHED AND INSTALLED PER THE RESPONSIBILITY SCHEDULE, REF ARCHITECTURAL DRAWINGS.

B. PROVIDE WITH UNIT MOUNTED THERMOSTAT.

C. PROVIDE MANUAL SUMMER/WINTER CHANGE-OVER SWITCH.

D. PROVIDE NECESSARY MOUNTING BRACKET AND ACCESSORIES FOR CEILING MOUNTING.

E. PROVIDE FACTORY MOUNTED DISCONNECT INSTALLED ON SERVICE SIDE OF UNIT.

| HEAT PUMP CONDENSING UNIT SCHEDULE | | | | | | | | | | | | | | | |
|------------------------------------|---------|--------------|----------|-----------|------------------|--------------|----------------|------------------|--------------|------------------|------------|------|-------|--------------|-------|
| MARK | SERVICE | MANUFACTURER | MODEL | REFR TYPE | COOLING CAPACITY | | | HEATING CAPACITY | | | ELECTRICAL | | | WEIGHT (LBS) | NOTES |
| | | | | | TH (MBH) | AMBIENT (DB) | MIN EFF (SEER) | CAP (MBH) | AMBIENT (DB) | MIN EFF COP 47°F | MCA | MOCP | VIPH | | |
| CU-1 | FCU-1 | CARRIER | 38MAQB18 | R410A | 11.6 | 91.0 | 19.0 | 12.2 | 8.7 | 3.3 | 13 | 15 | 208/1 | 102.5 | A - H |

* EQUIPMENT SHALL BE OBTAINED THROUGH SHAKE SHACK NATIONAL ACCOUNT. REFER TO T02 / VENDOR LIST FOR MORE INFORMATION. MODEL NUMBERS SHALL NOT BE CONSIDERED COMPLETE AND MATERIAL SHALL NOT BE ORDERED BY MANUFACTURER AND MODEL NUMBERS ONLY. REVIEW THE COMPLETE DESCRIPTION, NOTES AND SPECIFICATIONS TO DETERMINE THE EXACT MATERIAL AND ACCESSORIES TO BE ORDERED. THE MANUFACTURERS LISTED ARE THE BASIS FOR THE DESIGN.

NOTES:

A. EQUIPMENT FURNISHED AND INSTALLED PER THE RESPONSIBILITY SCHEDULE, REF ARCHITECTURAL DRAWINGS.

B. EQUIPMENT CAPACITY SCHEDULED IS MINIMUM CAPACITY THAT MUST BE PROVIDED AT AMBIENT TEMPERATURE INDICATED.

C. CONTRACTOR SHALL VERIFY WITH EQUIPMENT SUPPLIER EXACT QUANTITY AND SIZE OF REFRIGERANT PIPING.

D. PROVIDE LIQUID LINE FILTER DRYER AND SIGHT GLASS.

E. PROVIDE PREFABRICATED EQUIPMENT SUPPORT RAILS.

F. PROVIDE FACTORY MOUNTED DISCONNECT INSTALLED ON SERVICE SIDE OF UNIT.

G. STARTERS FOR ALL MOTORS SHALL BE FURNISHED INTEGRAL WITH UNIT.

H. COORDINATE SIZE OF CONDUCTOR TERMINATION LUGS WITH CONDUCTOR SIZES SHOWN ON ELECTRICAL DRAWINGS.

| OUTSIDE AIR REQUIREMENTS, IMC-2018 (IP) | | | | | | | | | | | | | |
|---|----------------------------------|-----------------------------|---|------------------------------------|----------------|------------------------|--|----------------------------|--|---------------------------|---|-----------------------------------|-------|
| SYSTEM DESIGNATION | SYSTEM TAB NAME OR LIST 'SINGLE' | SINGLE-ZONE SYSTEMS ONLY | | MULTI-ZONE SYSTEMS ONLY | | FLOOR AREA SERVED (SF) | SYSTEM AVERAGED AREA-BASED OUTDOOR AIR RATE (CFM/SF) | SYSTEM POPULATION (PEOPLE) | SYSTEM AVERAGED PEOPLE-BASED OUTDOOR AIR RATE (CFM/PEOPLE) | REQUIRED FLOW [Vot] (CFM) | REQUIRED DCV OA INTAKE FLOW [Vot] (CFM) | DESIGN OA INTAKE FLOW [Vot] (CFM) | NOTES |
| | | ASSOCIATED VENTILATION ZONE | SINGLE ZONE WORST CASE ZONE AIR DISTRIBUTION EFFECTIVENESS [Ez] | SYSTEM VENTILATION EFFICIENCY [Ev] | BY SYSTEM [Aq] | | | | | | | | |
| RTU-1 | MULTI-ZONE (RTU-1) | - | - | 0.84 | 1.071 | 108 | 1.18 | 108 | 7.50 | 1,225 | N/A | 1,200 | - |
| RTU-2 | MULTI-ZONE (RTU-2) | - | - | 1.00 | 850 | 850 | 0.120 | 12 | 7.50 | 192 | N/A | 1,120 | - |
| FCU-1 | SINGLE ZONE | OFFICE | 0.80 | 47 | 0.080 | 47 | 0.080 | 2 | 5.00 | 16 | N/A | 40 | - |
| UH-1 | SINGLE ZONE | MECH ROOM | 0.80 | 78 | 0.000 | 78 | 0.000 | 0 | 0.00 | 0 | N/A | 0 | - |
| TOTALS | | | | | | | | | | 1,433 | 0 | 2,480 | |

GENERAL NOTES:

1. VENTILATION CALCULATIONS BASED ON IMC-2018.

2. SYSTEM POPULATIONS BASED ON MAX SEATING AND/OR CODE MAXIMUM VALUES.

3. SINGLE ZONE SYSTEMS (Vot = Voz): SYSTEM VENTILATION EFFICIENCY CALCULATION IS NOT REQUIRED FOR SINGLE ZONE SYSTEMS. WORST CASE AIR DISTRIBUTION EFFECTIVENESS BETWEEN HEATING AND COOLING MODES OF OPERATION IS SHOWN IN TABLE.

4. 100% OA SYSTEMS (Vot = 200 + 2000 * Voz): WHEN ONE AIR HANDLER SUPPLIES ONLY OUTDOOR AIR TO ONE OR MORE ZONES. EACH ZONE IS INDIVIDUALLY CALCULATED WITH ITS WORST CASE ZONE AIR DISTRIBUTION EFFECTIVENESS (HEATING/COOLING).

5. MULTI-ZONE REGRULATING SYSTEMS: CALCULATOR USED TO DETERMINE VENTILATION AIRFLOW IN COMPLIANCE WITH IMC-2018 VPP AND ASHRAE 62.1-2016 APPENDIX A. VENTILATION RATE SHOWN IS ACTUAL CALCULATED WITH CORRECTION FACTORS INCLUDED. EACH ZONE IS CALCULATED WITH ITS WORST CASE ZONE AIR DISTRIBUTION EFFECTIVENESS (HEATING/COOLING) AS PART OF CALCULATIONS TO FIND Ev.

| GRILLE, REGISTER, AND DIFFUSER SCHEDULE | | | | | | | | | | | | | | |
|---|--------------|--------------------------|-------|-----------------------|---------------|-------------------|----------------|--------|-------|---|---|---|---|---|
| MARK | MANUFACTURER | SERVICE | MODEL | CONSTRUCTION MATERIAL | FACE TYPE | MOUNTING LOCATION | FACE SIZE (IN) | MAX NC | NOTES | | | | | |
| CEG1 | E.H. PRICE | EXHAUST GRILLE W/ DAMPER | 80D | STEEL | EGGCRATE | SURFACE | 12x12 | 30 | A | B | C | F | G | H |
| CRG1 | E.H. PRICE | RETURN GRILLE | 80 | STEEL | EGGCRATE | LAY-IN | 24x24 | 30 | A | B | C | F | H | |
| CSO1 | E.H. PRICE | SUPPLY DIFFUSER | SCD | STEEL | SQUARE CONE | SURFACE | 12x12 | 30 | A | B | C | F | H | J |
| CSO2 | E.H. PRICE | SUPPLY DIFFUSER | SCD | STEEL | SQUARE CONE | LAY-IN | 24x24 | 30 | A | B | C | F | H | K |
| CSO3 | E.H. PRICE | SUPPLY DIFFUSER | PDOOR | STEEL | PERFORATED | LAY-IN | 24x24 | 30 | A | B | C | F | H | |
| WSR1 | E.H. PRICE | SUPPLY REGISTER W/... | 520D | STEEL | LOUVERED FACE | WALL OR DUCT | (SEE PLANS) | 30 | A | B | C | D | E | F |

MODEL NUMBERS SHALL NOT BE CONSIDERED COMPLETE AND MATERIAL SHALL NOT BE ORDERED BY MANUFACTURER AND MODEL NUMBERS ONLY. REVIEW THE COMPLETE DESCRIPTION, NOTES AND SPECIFICATIONS TO DETERMINE THE EXACT MATERIAL AND ACCESSORIES TO BE ORDERED. THE MANUFACTURERS LISTED ARE THE BASIS FOR THE DESIGN.

NOTES:

A. EQUIPMENT FURNISHED AND INSTALLED PER THE EQUIPMENT RESPONSIBILITY SCHEDULE.

B. NECK SIZE SHOWN ON DRAWINGS. PROVIDE BRANCH DUCT TO MATCH NECK SIZE UNLESS OTHERWISE SHOWN ON DRAWINGS.

C. DIFFUSERS SHALL BE PREFINISHED TO MATCH CEILING/WALL EXPOSED DUCT COLOR (COORDINATE WITH ARCHITECT).

D. FRONT BLADES PARALLEL TO LONG DIMENSION.

E. DOUBLE DEFLECTION BARS SHALL BE ADJUSTABLE.

F. FRAME TYPE TO MATCH CEILING/WALL CONSTRUCTION. COORDINATE WITH ARCHITECTURAL REFLECTED CEILING/WALL PLAN.

G. PROVIDE OPPOSED BLADE DAMPER ADJUSTABLE FROM FACE OF DEVICE.

H. PROVIDE DIFFUSERS, LINEAR SLOTS, AND GRILLES WITH NO EXPOSED MOUNTING SCREWS.

J. CONTRACTOR SHALL PROVIDE REMOTE CABLE OPERATED VOLUME DAMPER BY METROPOLITAN AIR TECHNOLOGIES MODEL RT-250 WITH EXTERNAL WORM GEAR OPERATOR OR EQUIVALENT YOUNG REGULATOR BUTTERFLY DAMPER WITH 270-275 CONTROLLER. OPERATOR SHALL HAVE A SQUARE DRIVE FOR 1/4" NUT DRIVER. DAMPER ASSEMBLY SHALL INCLUDE GALVANIZED STEEL DUCT WITH ROLLED BEAD STIFFENERS, REINFORCED BLADE, SELF LUBRICATING BEARING AND WORM GEAR MOUNTING PLATE. DAMPER SHALL BE INSTALLED IN BRANCH DUCT NOT INLET OF PLENUM DIFFUSER. (REF: 2/MS01)

K. 4-WAY THROW PATTERN UNLESS OTHERWISE INDICATED BY FLOW ARROWS ON DRAWINGS.

L. PROVIDE RAPID MOUNT FRAME FOR INSTALLATION IN HARD CEILING.



ZEBRA ARCHITECTURE, LLC
14614 N KIERNLAND BLVD, SUITE N300
SCOTTSDALE, ARIZONA 85254
PHONE: 480.912.1169 www.zbr.co.uk

ENGINEER OF RECORD:
JUSTIN M. OLDER

8345 LENEVA DRIVE, SUITE 300
LENEVA, KS 66214
TEL 913.742.5000 FAX 913.742.5001
2021010
MO. CORPORATE NUMBER: 07-6699 EXPRESS 10/10/2021

STORE NO:
1366



REVISION

| DATE | DESCRIPTION |
|----------|-----------------|
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |

STATUS:
PERMIT / BID SET



05/03/2021

FIELD VERIFICATION:
The contractor shall verify all signed dimensions and location of the project site and notify Zebra Architecture, LLC of any dimensional errors, or omissions of dimensions before beginning or resuming any work. Do not commence work until all errors are corrected.

COPYRIGHT © 2021:
Zebra Architecture, LLC shall retain all common law, statutory and all other intellectual property rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise used without the written consent of Zebra Architecture, LLC.

SHEET NAME:
MECHANICAL SCHEDULES

DATE: 04/08/21 PROJECT NO: 2050004103
DRAWN: AJP SCALE: AS NOTED

SHEET NO:
M601

PROFESSIONAL CERTIFICATION
I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
PROJECT NAME: JUSTIN M. OLDER
LICENSE # 2138
EXPIRATION DATE: 1/8/2022

COMcheck Software Version 4.1.5.1
Mechanical Compliance Certificate

Project Information

Energy Code: 2018 IECC
 Project Title: Shake Shack
 Location: Gaithersburg, Maryland
 Climate Zone: 4a
 Project Type: New Construction

Construction Site: Gaithersburg, MD
 Owner/Agent: Shake Shack
 Designer/Contractor: Henderson Engineers Inc. Lenexa, KS

Additional Efficiency Package(s)
 Reduced interior lighting power. Requirements are implicitly enforced within interior lighting allowance calculations.

Mechanical Systems List

| Quantity | System Type & Description |
|----------|---|
| 1 | RTU-1 (Single Zone) Heating: 1 each - Other, Gas, Capacity = 178 kBtu/h No minimum efficiency requirement applies Cooling: 1 each - Single Package DX Unit, Capacity = 177 kBtu/h, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.00 EER, Required Efficiency: 10.80 EER + 12.2 IEER Fan System: FAN SYSTEM 1 - Compliance (Motor nameplate HP method) : Passes Fans: FAN 1 Supply, Constant Volume, 4800 CFM, 3.0 motor nameplate hp, 0.0 fan efficiency grade |
| 1 | RTU-2 (Single Zone) Heating: 1 each - Other, Gas, Capacity = 178 kBtu/h No minimum efficiency requirement applies Cooling: 1 each - Single Package DX Unit, Capacity = 170 kBtu/h, Air-Cooled Condenser, Air Economizer Proposed Efficiency = 14.00 EER, Required Efficiency: 10.80 EER + 12.2 IEER Fan System: FAN SYSTEM 2 - Compliance (Motor nameplate HP method) : Passes Fans: FAN 2 Supply, Constant Volume, 4800 CFM, 3.0 motor nameplate hp, 0.0 fan efficiency grade |
| 1 | FCU-1/CU-1 (Single Zone) Cooling: 1 each - Split System, Capacity = 11 kBtu/h, Air-Cooled Condenser, No Economizer, Economizer exception: None Proposed Efficiency = 19.00 SEER, Required Efficiency: 13.00 SEER Fan System: FAN SYSTEM 3 - Compliance (Motor nameplate HP method) : Passes Fans: FAN 3 Supply, Constant Volume, 420 CFM, 0.1 motor nameplate hp, 0.0 fan efficiency grade |
| 2 | Water Heater 1: Gas Instantaneous Water Heater, Capacity: 0 gallons, Input Rating: 199 kBtu/h w/ Circulation Pump No minimum efficiency requirement applies |

Mechanical Compliance Statement
 Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed mechanical systems have been designed to meet the 2018 IECC requirements in COMcheck version 4.1.5.1 and to comply with any applicable mandatory requirements listed in the inspection Checklist.

Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 1 of 15
 MD\000\Energy\ComCheck.cck

Andrew Pettus - Mechanical Designer
 Name - Title Signature

2/23/2021
 Date

COMcheck Software Version 4.1.5.1
Inspection Checklist
 Energy Code: 2018 IECC

Requirements: 74.0% were addressed directly in the COMcheck software
 Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

| Section # & Req.ID | Plan Review | Complies? | Comments/Assumptions |
|---------------------------|--|---|--------------------------|
| C103.2 [PR3] ¹ | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical systems and equipment and document where exceptions to the standard are claimed. Load calculations per acceptable engineering standards and handbooks. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C103.2 [PR3] ¹ | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the service water heating systems and equipment and document where exceptions to the standard are claimed. Hot water system sized per manufacturer's sizing guide. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C406 [PR9] ¹ | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Applicable | |

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 3 of 15
 MD\000\Energy\ComCheck.cck

| Section # & Req.ID | Footings / Foundation Inspection | Complies? | Comments/Assumptions |
|------------------------------|--|--|--------------------------|
| C403.12.2 [F09] ¹ | Snowmelt melting system and freeze protection systems have sensors and controls configured to limit service for pavement temperature and outdoor temperature. Future connection to controls. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)
 Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 4 of 15
 MD\000\Energy\ComCheck.cck

| Section # & Req.ID | Plumbing Rough-In Inspection | Complies? | Comments/Assumptions |
|-----------------------------|---|--|--------------------------|
| C404.5.1 [PL6] ¹ | Heated water supply piping conforms to pipe length and volume requirements. Refer to section details. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.5.2 [PL6] ¹ | Heated water supply piping conforms to pipe length and volume requirements. Refer to section details. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.5.3 [PL6] ¹ | Heated water supply piping conforms to pipe length and volume requirements. Refer to section details. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.5.4 [PL6] ¹ | Heated water supply piping conforms to pipe length and volume requirements. Refer to section details. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.6.1 [PL3] ¹ | Automatic time switches installed to automatically switch off the recirculating hot-water system or heat trace. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.6.2 [PL7] ¹ | Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.6.3 [PL7] ¹ | Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.6.4 [PL7] ¹ | Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.7 [PL8] ¹ | Demand recirculation water systems have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.7 [PL8] ¹ | Demand recirculation water systems have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 5 of 15
 MD\000\Energy\ComCheck.cck

| Section # & Req.ID | Plumbing Rough-In Inspection | Complies? | Comments/Assumptions |
|---------------------------|---|--|--------------------------|
| C404.7 [PL8] ¹ | Demand recirculation water systems have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C404.7 [PL8] ¹ | Demand recirculation water systems have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 6 of 15
 MD\000\Energy\ComCheck.cck

| Section # & Req.ID | Mechanical Rough-In Inspection | Complies? | Comments/Assumptions |
|-------------------------------|---|--|---|
| C402.2.6 [ME41] ¹ | Thermally ineffective panel surfaces of heating radiant panels have insulation >= R-3.5. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.11.3 [ME61] ¹ | HVAC piping insulation insulated in accordance with Table C403.11.3. Insulation exposed to weather is protected from damage and is provided with shielding from solar radiation. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.8.4 [ME142] ¹ | Motors for fans that are not less than 1/2 hp and less than 1 hp are electronically commutated motors or have a minimum motor efficiency of 70 percent. These motors have the means to adjust motor speed. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.8.4 [ME142] ¹ | Motors for fans that are not less than 1/2 hp and less than 1 hp are electronically commutated motors or have a minimum motor efficiency of 70 percent. These motors have the means to adjust motor speed. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.8.4 [ME142] ¹ | Motors for fans that are not less than 1/2 hp and less than 1 hp are electronically commutated motors or have a minimum motor efficiency of 70 percent. These motors have the means to adjust motor speed. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.8.5 [ME143] ¹ | Each DX cooling system > 65 kbtu and chiller water/evaporative cooling system with fans > 1/4 hp are designed to vary the indoor fan airflow as a function of load and comply with detailed requirements of this section. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.8.5 [ME143] ¹ | Each DX cooling system > 65 kbtu and chiller water/evaporative cooling system with fans > 1/4 hp are designed to vary the indoor fan airflow as a function of load and comply with detailed requirements of this section. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.8.5 [ME143] ¹ | Each DX cooling system > 65 kbtu and chiller water/evaporative cooling system with fans > 1/4 hp are designed to vary the indoor fan airflow as a function of load and comply with detailed requirements of this section. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.12.1 [ME71] ¹ | Systems that heat outside the building envelope are radiant heat systems controlled by an occupancy sensing device or timer switch. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.2.3 [ME55] ¹ | HVAC equipment efficiency verified. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | See the Mechanical Systems list for values. |
| C403.5.5 [ME113] ¹ | Fault detection and diagnostics installed with air-cooled unitary DX units having economizers. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 7 of 15
 MD\000\Energy\ComCheck.cck

| Section # & Req.ID | Mechanical Rough-In Inspection | Complies? | Comments/Assumptions |
|-------------------------------|--|--|--------------------------|
| C403.5.5 [ME113] ¹ | Fault detection and diagnostics installed with air-cooled unitary DX units having economizers. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.2.2 [ME59] ¹ | Natural or mechanical ventilation is provided in accordance with International Mechanical Code Chapter 4. Mechanical ventilation has capability to reduce outdoor air supply to minimum per IMC Chapter 4. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.7.1 [ME59] ¹ | Demand control ventilation provided for spaces >= 100 ft ² and >= 25 people/1000 ft ² occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow >= 3,000 cfm. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.7.2 [ME115] ¹ | Enclosed parking garage ventilation has automatic contaminant detection and capacity to stack or modulate fans to 50% or less of design capacity. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.7.6 [ME141] ¹ | HVAC systems serving guestrooms in Group R-1 buildings with > 50 guestrooms. Each guestroom is provided with controls that automatically manage temperature setpoint and ventilation (see sections C403.7.6.1 and C403.7.6.2). | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.7.4 [ME57] ¹ | Exhaust air energy recovery on systems meeting Table C403.7.4(1) and C403.7.4(2). | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.7.5 [ME116] ¹ | Kitchen exhaust systems comply with replacement air and conditioned supply air limitations, and safety hood rating requirements and maximum exhaust rate criteria. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.11.1 [ME60] ¹ | HVAC ducts and plenums insulated in accordance with C403.11.1 and constructed in accordance with C403.11.2, verification may need to occur during Foundation Inspection. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.5.1 [ME62] ¹ | Air economizers provided where required, meet the requirements for design capacity, control signal, ventilation controls, high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| C403.5.2 [ME62] ¹ | Air economizers provided where required, meet the requirements for design capacity, control signal, ventilation controls, high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Shake Shack Report date: 02/23/21
 Data filename: J:\Lenexa\Programs\P-T\Shake Shack\2050004103 Shake Shack 1366 - (Kentlands) Gaithersburg Page 8 of 15
 MD\000\Energy\ComCheck.cck

A



ENGINEER OF RECORD:
JUSTIN M. OLDER
 8345 LENEXA DRIVE, SUITE 300
 LENEXA, KS 66214
 TEL 913.742.5000 FAX 913.742.5001
 20210103
 MD CORPORATE NUMBER: 07-6699 EXPRESS 10/1/2021

STORE NO:
1366



| REVISION | |
|----------|-----------------|
| DATE | DESCRIPTION |
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |

STATUS:
PERMIT / BID SET



05/03/2021

FIELD VERIFICATION:
 The contractor shall verify all signed dimensions and location at the project site and notify Zebra Architecture, LLC of any dimensional errors, omissions or omissions. Discrepancies shall be reported or rectified prior to work. Do not proceed until approved by the Engineer.

COPYRIGHT © 2021:
 Zebra Architecture, LLC, shall retain all common law, statutory and all other intellectual property rights. Neither the documents nor the inspection results to be reproduced, distributed, disclosed or otherwise used without the written consent of Zebra Architecture, LLC.

SHEET NAME:
MECHANICAL ENERGY CODE COMPLIANCE

| | |
|-------------------|---------------------------|
| DATE: 04/08/21 | PROJECT NO: 2050004103 |
| DRAWN: AJP | SCALE: AS NOTED |

SHEET NO:
M630

PROFESSIONAL CERTIFICATION
 I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A FULLY LICENSED ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
 PRINT NAME: JUSTIN M. OLDER
 LICENSE #: 62138
 EXPIRATION DATE: 1/8/2022

E

D

C

B






A

JUSTIN M. OLDER

ENGINEER OF RECORD:

TEL FAX

ANSUL R-102 FIRE SUPPRESSION SYSTEM
 FIRE SYSTEM IS INTEGRAL WITH FACTORY DESIGN/PIPING/FIELD CERTIFICATION






FLOW POINT CHART
 ANSUL R-102 FLOW POINT CALCULATION

| NOZZLE TYPE | NOZZLE FLOW PT. | NOZZLE QUANTITY | TOTAL FLOW PT. |
|-------------------------|-----------------|-----------------|----------------|
| 3K | 3 | 0 | 0 |
| 2B0 | 2 | 0 | 0 |
| 2B5 | 2 | 7 | 14 |
| 2B6 | 2 | 2 | 4 |
| 230 | 2 | 0 | 0 |
| 2W | 2 | 1 | 2 |
| 2120 | 2 | 0 | 0 |
| 1W | 1 | 1 | 1 |
| 1N | 1 | 0 | 0 |
| 1E | 1 | 0 | 0 |
| 12N | 12 | 0 | 0 |
| TOTAL FLOW POINTS USED | | | 23 |
| MAX. SYSTEM FLOW POINTS | | | 24 (12 GALLON) |

NOTE:
 HALTON COMPANY WILL SUPPLY ANSUL COMPONENTS AND PRE-PIPED HOODS PER PUBLISHED ANSUL GUIDELINES AND RECOMMENDATIONS. IT IS THE RESPONSIBILITY OF THE F.S.E.C. TO INFORM HALTON OF ANY SPECIAL REQUIREMENTS OF THE LOCAL JURISDICTION PRIOR TO RELEASE OF EQUIPMENT.

ANSUL NOTES
 GENERAL NOTES:
 1. THIS INSTALLATION IS TO BE MADE IN ACCORDANCE WITH THE R-102 INSTALLATION MANUAL AND IN ACCORDANCE WITH ALL STATE AND LOCAL CODES.
 2. THE WIRE ROPE FOR THE DETECTOR AND REMOTE PULL STATION IS TO BE INSTALLED BY AN AUTHORIZED AND FACTORY TRAINED DISTRIBUTOR OR SERVICE REPRESENTATIVE.
 3. THIS INSTALLATION IS TO BE INSPECTED, PUT INTO OPERATION AND CERTIFIED BY AN AUTHORIZED AND FACTORY TRAINED DISTRIBUTOR OR SERVICE REPRESENTATIVE.
 4. ELECTRICAL CONTACTS AND WIRING FOR APPLIANCE SHUT OFF TO BE PROVIDED BY THE ELECTRICAL CONTRACTOR.
 5. ANSUL R-102 RESTAURANT FIRE SUPPRESSION SYSTEMS HAVE BEEN TESTED AND ARE LISTED BY UNDERWRITERS LABORATORIES INC. AS PRE-ENGINEERED SYSTEMS. AND WHEN INSTALLED AS SHOWN ON THIS DRAWING SHALL COMPLY WITH ALL RELEVANT ANSUL INSTALLATION RECHARGE INSPECTION AND MAINTENANCE MANUALS AND SHALL COMPLY WITH NFPA 96 WHEN INSTALLED AND CERTIFIED BY AUTHORIZED TRAINED ANSUL DISTRIBUTORS IN ACCORDANCE WITH THE MANUAL.
 6. ALL AGENT DISTRIBUTION PIPING AND DETECTION CONDUIT HOOD PENETRATIONS MUST BE PROPERLY SEALED IN ACCORDANCE WITH NFPA 96.
 DISTRIBUTION PIPING REQUIREMENT NOTES:
 1. FIRE SHALL BE 3/8" SCHEDULE 40 BLACK IRON, CHROME PLATED OR STAINLESS STEEL UNLESS OTHERWISE NOTED.
 2. FINAL NOZZLE LOCATION MAY NOT VARY FROM LOCATION SHOWN.



NOTE:
 ALL PIPING FOR LOW PROXIMITY APPLIANCE PROTECTION SHALL BE PROVIDED & INSTALLED BY THE INSTALLING ANSUL DISTRIBUTOR & NOT BY HALTON.

NOTE:
 HAND HELD EXTINGUISHERS, IF REQUIRED, ARE TO BE PROVIDED BY OTHERS.

ALL APPLIANCE DROPS TO HAVE SWIVELS

****NOTE****
 ANSUL R-102
 OVERLAPPING SYSTEM

- 1) ANSUL R-102 FIRE SYSTEM
- 2) FOUR TANK SYSTEM (12 GALLON)
- 3) 3/8" BLACK IRON PIPING (CONCEALED)
- 3/8" S.S. APPLIANCE DROPS (EXPOSED)
- 4) MECHANICAL GAS VALVE = (ADVISE SIZE)

THIS DRAWING MUST BE CHECKED, SIGNED AND RETURNED TO THE APPROPRIATE FACTORY. PLEASE VERIFY THE FOLLOWING:

1. ALL DIMENSIONAL INFORMATION, MOUNTING POSITIONS
2. THE LOCATION AND TYPE OF COOKING EQUIPMENT

NOTE TO APPROVER:
 THE LOCATION AND TYPE OF COOKING EQUIPMENT MAY AFFECT EXHAUST AIR FLOW. HALTON MUST BE ADVISED IF ANY OF THESE CHANGES OCCUR. A RE-CALCULATION FOR EXHAUST AIR FLOW MAY BE REQUIRED.

APPROVED FOR FABRICATION: WITH NO CHANGES WITH CHANGES AS NOTED

APPROVED BY: _____ DATE: _____

MAIL APPROVED DRAWINGS TO APPROPRIATE FACTORY BELOW:

| | |
|--|---------------------------|
| HALTON CO. (USA) 1500 N. JEFFERSON AVE. SCOTTSDALE, KY 42166 1-270-237-5600 | DATE: 02/25/21 BY: SKM |
| HALTON CO. (CANADA) MISSISSAUGA, ON, L4W 1A7 1-905-624-0301 | NO CHANGE |

PROJECT: SHAKE SHACK GAITHERSBURG, MD
 LOCATION: GAITHERSBURG, MD
 DRAWN BY: SKM DATE: 02/08/21
 SCALE: NOT TO SCALE
 CONSULTANT: Halton

DRAWING TITLE: HOOD DETAILS
 DRAWING NO.: U21-101
 REV. NO.: 1 SHEET NO.: 2 OF 4

STORE NO: 1366

SHAKE SHACK
 KENTLANDS SQUARE
 158 MARKET PLACE
 GAITHERSBURG, MD 20878

REVISION

| DATE | DESCRIPTION |
|----------|-----------------|
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |

STATUS: PERMIT / BID SET



FIELD VERIFICATION:
 The contractor shall verify all signed dimensions and location of the project site and notify Zebra Architecture, LLC, of any dimensional errors, or omissions of any drawings, before beginning or resuming any work. Do not commence work until approved by the architect.

COPYRIGHT © 2021:
 Zebra Architecture, LLC, shall retain all common law, statutory and all other intellectual property rights. No documents for the imposition thereof is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.

SHEET NAME: HALTON DRAWINGS

DATE: 04/08/21 PROJECT NO: 205004103

DRAWN: AJP SCALE: AS NOTED





SHEET NO.: M702

NOTE:
 THE DOCUMENTATION CONTAINED ON THIS SHEET WAS NOT PREPARED BY HENDERSON ENGINEERS AND IS INCLUDED IN THIS SET FOR REFERENCE ONLY. HENDERSON ENGINEERS REVIEWED THE DOCUMENTATION ON THIS SHEET FOR GENERAL COMPLIANCE WITH DESIGN INTENT. SUPPLIER IS RESPONSIBLE THAT ALL FURNISHED EQUIPMENT ON THIS SHEET COMPLIES WITH APPLICABLE LOCAL, STATE, AND FEDERAL LAWS, CODES, AND REGULATIONS.



| MUA CHART | | |
|-----------------------|-----------------|--------|
| DATA | IMPERIAL | METRIC |
| Model | MUA-DG-2800 | |
| Max. Supply Air | 2800 CFM | - l/s |
| Design Supply Air | 2250 CFM | - l/s |
| Internal S.P. | 1.14" W.G. | - PA |
| External S.P. | 0.5" W.G. | - PA |
| Total S.P. | 1.64" W.G. | |
| Motor | 1.5 hp | |
| Power | 0.89 bhp | |
| Full Load AMPS | 6.6 | |
| Motor RPM | 1800 | |
| Voltage/Phase/Hz | 208/3/60 | |
| Fan RPM | 1745 | |
| Mounting | Exterior/Floor | |
| Blower Model | ANPA 14 | |
| Gas Type | Natural | |
| Min. Gas Pressure | 8" W.C. | |
| Max. Gas Pressure | 14" W.C. | |
| Gas Line Size | 1/2" | |
| Discharge Temperature | 70° | |
| Temperature Rise | 57.8° | |
| Input MBH | 153 | |
| Output MBH | 141 | |
| Material Type | G90 Galv. 20GA. | |
| Paint Color | Unpainted | |
| Weight | 804 lbs | - kg |

| STANDARD FEATURES | |
|--------------------------|---|
| <input type="checkbox"/> | Belt Drive Fan (Comefri ATLI) |
| <input type="checkbox"/> | 1" Duct Board Insulation Double Wall |
| <input type="checkbox"/> | Constant Volume |
| <input type="checkbox"/> | Unit Mounted Controls |
| <input type="checkbox"/> | Neoprene Fan Isolators |
| <input type="checkbox"/> | End Discharge |
| <input type="checkbox"/> | Gravity Intake Damper |
| <input type="checkbox"/> | Direct Spark Gas Train |
| OPTIONS | |
| <input type="checkbox"/> | Direct Drive Plenum Fan (Comefri ANPA) |
| <input type="checkbox"/> | No Insulation |
| <input type="checkbox"/> | Variable Speed (Powerflex 523 VFD) |
| <input type="checkbox"/> | Motorized Intake Damper |
| <input type="checkbox"/> | Intake Hood w/ 2" Alum. Mesh Filters & Birdscreen |
| <input type="checkbox"/> | MERV 8 Filtered Intake (Dust Filter) |
| <input type="checkbox"/> | Remote DAT (Discharge Air Temperature) Controls |
| <input type="checkbox"/> | Space Temp Control |
| <input type="checkbox"/> | Non Insulated Roof Curb |
| <input type="checkbox"/> | Insulated Roof Curb |
| <input type="checkbox"/> | Non Insulated Roof Curb w/ Wood Nailer |
| <input type="checkbox"/> | Insulated Roof Curb w/ Wood Nailer |
| <input type="checkbox"/> | Seismic Fan Isolators |
| <input type="checkbox"/> | Gas Train Pressure Gauges |
| <input type="checkbox"/> | High & Low Gas Pressure Switches |
| <input type="checkbox"/> | Freeze Stat |
| <input type="checkbox"/> | Remote Start/Stop Contact |
| <input type="checkbox"/> | Remote Call for Heat Contact |
| <input type="checkbox"/> | Down Discharge |

ITEM #MUA-01



| ELECTRICAL SCHEDULE | | | |
|---------------------|---------------------------------------|-----------------|----------|
| CONNECTION # | CONNECTION DESCRIPTION | FROM | TO |
| E1-MUA | 208/3/60 - FAN MOTOR POWER - 3 WIRES | BUILDING SOURCE | J-BOX |
| E2-MUA | DRY CONTACT CLOSURE FROM M.S.P. PANEL | M.S.P. PANEL | MUA UNIT |



ELECTRICAL CONNECTION WILL COME UP THROUGH CURB INTO BOTTOM OF UNIT

| SPECIFICATIONS | |
|---------------------------------|--|
| GAS INFORMATION | MIDCO 6" SS BURNER PRESSURE REGULATOR SUPPLIED RTC GAS CONTROLS DISCHARGE TEMPERATURE DIAL MOUNTED IN UNIT HIGH TEMP LIMIT SWITCH SET TO 140°F |
| ELECTRICAL INFORMATION | 230V/3PH/60HZ SUPPLY INTEGRAL NON-FUSED DISCONNECT SWITCH PREMIUM EFFICIENCY MOTOR INTEGRAL MOTOR STARTER WITH THERMAL OVERLOADS FIRE PROTECTION INTERLOCK REMOTE START/STOP 50% MUA TURN DOWN |
| EQUIPMENT SPECIFICATIONS | ENTERING AIR THERMOSTAT/LOW TEMPERATURE CUTOUT EXTERNAL PROFILE ADJUSTMENT WITH PRESSURE GAUGE GALVANIZED FINISH 0" CLEARANCE ON TOP & BOTTOM OF UNIT UNIT SHIPS ASSEMBLED IN ONE PIECE 1" CLEARANCE TO COMBUSTIBLE ON ENDS LISTED 18" FROM COMBUSTIBLE ON SIDES |

THIS DRAWING MUST BE CHECKED, SIGNED AND RETURNED TO THE APPROPRIATE FACTORY. PLEASE VERIFY THE FOLLOWING:

1. ALL DIMENSIONS
2. THE LOCATION AND TYPE OF COOKING EQUIPMENT.

ANY CHANGES TO COOKING EQUIPMENT SUCH AS INCREASED ENERGY INPUTS OR EQUIPMENT CHANGES OCCUR, A RECALCULATION MUST BE PROVIDED BY THE CLIENT. REVISE AND RESUBMIT APPROVED FOR FABRICATION WITH NO CHANGES AS NOTED

DATE: 02/28/21

BY: SKM

REVISION DESCRIPTION: REMOVED GRAVITY DAMPER, CHGD ROOF CURB HEIGHT

PROJECT: SHAKE SHACK GAITHERSBURG, MD

LOCATION: GAITHERSBURG, MD

DRAWING TITLE: MUA-DG 2800

DRAWING No.: U21-101


REV. NO.: 1 SHEET NO.: 3 of 4

STORE NO: 1366

SHAKE SHACK
KENTLANDS SQUARE
158 KENTLANDS SQUARE
GAITHERSBURG, MD 20878

| REVISION | | |
|----------|-----------------|---------------|
| DATE | DESCRIPTION | CITY COMMENTS |
| 04/08/21 | CITY COMMENTS | |
| 05/03/21 | OWNER REVISIONS | |

STATUS: PERMIT / BID SET



FIELD VERIFICATION: The contractor shall verify all signed dimensions and condition of the project site and notify Zebra Architecture, LLC of any dimensional errors, or omissions or work. Do not commence work until approved or inspected by work. Do not proceed with work until approved or inspected by work.

COPYRIGHT © 2021: Zebra Architecture, LLC. shall retain all common law, statutory and all other intellectual property rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.

SHEET NAME: HALTON DRAWINGS

| | |
|----------------|------------------------|
| DATE: 04/08/21 | PROJECT NO: 2050004103 |
| DRAWN: AJP | SCALE: AS NOTED |

SHEET NO: M703


NOTE: THE DOCUMENTATION CONTAINED ON THIS SHEET WAS NOT PREPARED BY HENDERSON ENGINEERS AND IS INCLUDED IN THIS SET FOR REFERENCE ONLY. HENDERSON ENGINEERS REVIEWED THE DOCUMENTATION ON THIS SHEET FOR GENERAL COMPLIANCE WITH DESIGN INTENT. SUPPLIER IS RESPONSIBLE THAT ALL FURNISHED EQUIPMENT ON THIS SHEET COMPLIES WITH APPLICABLE LOCAL, STATE, AND FEDERAL LAWS, CODES, AND REGULATIONS.

FAN INFORMATION TABLE

| FAN NO | MODEL | QTY | CFM | S.P. | H.P. | VOLTAGE | AMPS | ACCESSORIES |
|--------|-----------------|-----|------|-------|------|----------|------|---|
| EF-1 | HSTXDRHUL1475SC | 1 | 875 | 0.75" | 3/4 | 115/1/60 | 13.8 | MOUNT & WIRE DISCONNECT - SPEED CONTROL - 18-1/2" SQ GALV SF CURB, 24" HIGH VENTED - LABEL UL/CUL 762, LISTED RESTAURANT - GREASE CONTAINER - HINGE KIT |
| EF-2 | HSTXDRHUL1475SC | 1 | 1886 | 0.90" | 3/4 | 115/1/60 | 13.8 | MOUNT & WIRE DISCONNECT - SPEED CONTROL - 18-1/2" SQ GALV SF CURB 24" HIGH VENTED - LABEL UL/CUL 762, LISTED RESTAURANT - GREASE CONTAINER - HINGE KIT |


NOTE:
 ON ROOF UNITS, ANCHOR THE FAN SECURELY TO THE CURB. ANCHORING THROUGH THE VERTICAL PORTION OF THE CURB CAP FLANGE IS RECOMMENDED. USE A MINIMUM OF FOUR LAG BOLTS OR OTHER SUITABLE FASTENERS.

NOTE:
 ELECTRICAL CONNECTIONS TO BE MADE ON HINGE SIDE OF FAN.



DAMPER OD = "F"
 ROOF OPENING = "G"
 CURB OD = "H"


| TAG | SIZE | A | B | C | D | E | F | G | H | J | K | SHIP'G WT. - LESS MOTOR |
|------|------|-----|--------|--------|--------|----|-----|-------|-------|--------|--------|-------------------------|
| EF-1 | 14 | 20" | 26.94" | 31.31" | 21.94" | 2" | 14" | 15.5" | 18.5" | 15.50" | 19.75" | 118 |
| EF-2 | 14 | 20" | 26.94" | 31.31" | 21.94" | 2" | 14" | 15.5" | 18.5" | 15.50" | 19.75" | 118 |



CURB

CURB TYPE: GSFRC

- OPTIONS: (as noted below)
- 1) 4 VENTS
 - 2) NO DAMPER SHELF



| TAG | QTY | DESCRIPTION | MATERIAL GAUGE | A | B | C | D | ROOF OPENING | OPTIONS |
|------|-----|-------------|----------------|-------|-------|------|-----|---------------|---------|
| EF-1 | 1 | GSFRC | 18.5 | 18.5" | 18.5" | 1.5" | 24" | 15.5" x 15.5" | 1,2 |
| EF-2 | 1 | GSFRC | 18.5 | 18.5" | 18.5" | 1.5" | 24" | 15.5" x 15.5" | 1,2 |

THE DRAWING SHALL BE REVISIONED, SHARED AND RETURNED TO THE APPROPRIATE FACTORY. PLEASE VERIFY THE FOLLOWING:
 1. ALL DIMENSIONAL INFORMATION, MOUNTING POSITIONS
 2. THE LOCATION AND TYPE OF COILING EQUIPMENT.
 NOTE TO APPROVER: APPROVED FOR FABRICATION
 APPROVED FOR FABRICATION
 WITH CHANGES
 WITH NO CHANGES
 APPROVED BY: _____ DATE: _____

MAIL APPROVED DRAWINGS TO APPROPRIATE FACTORY BELOW:

| REV. | DATE | DESCRIPTION |
|------|----------|-------------|
| 1 | 02.08.21 | NO CHANGE |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |

WEBSITE: www.halton.com
 HALTON CO. (USA)
 101 INDUSTRIAL DRIVE
 SCOTTSDALE, AZ 85254
 1-480-237-4600
 BY: SKM DATE: 02.26.21
 SKM

PROJECT: SHAKE SHACK GAITHERSBURG, MD
 LOCATION: GAITHERSBURG, MD
 DRAWN BY: SKM DATE: 02.08.21
 SCALE: NOT TO SCALE
 CONSULTANT: Halton

DRAWING TITLE: FAN DETAILS
 DRAWING No.: U21-094
 REV. NO.: 1 SHEET NO.: 4 of 4

STORE NO: 1366

SHAKE SHACK
 KENTLANDS SQUARE
 158 MARKET PLACE
 GAITHERSBURG, MD 20878

REVISION

| DATE | DESCRIPTION |
|----------|-----------------|
| 04/08/21 | CITY COMMENTS |
| 05/03/21 | OWNER REVISIONS |

STATUS: PERMIT / BID SET



05/03/2021
 FIELD VERIFICATION:
 The contractor shall verify all signed dimensions and location of the project site and notify Zebra Architecture, LLC of any dimensional errors, or omissions on this sheet for general compliance with design intent. SUPPLIER IS RESPONSIBLE FOR THE IMPROPER HEALTH TO BE REPRODUCED. DISTRIBUTION OF THIS DRAWING WITHOUT THE WRITTEN CONSENT OF ZEBRA ARCHITECTURE, LLC.
 COPYRIGHT © 2021:
 Zebra Architecture, LLC, shall retain all common law, statutory and all other intellectual rights. Neither the documents nor the information herein is to be reproduced, distributed, disclosed or otherwise without the written consent of Zebra Architecture, LLC.

SHEET NAME: HALTON DRAWINGS

| | |
|----------------|------------------------|
| DATE: 04/08/21 | PROJECT NO: 2050004103 |
| DRAWN: AJP | SCALE: AS NOTED |

SHEET NO: M704

NOTE:
 PROFESSIONAL CERTIFICATION
 I HEREBY CERTIFY THAT THESE THE DOCUMENTATION CONTAINED ON THIS SHEET WAS NOT PREPARED BY HENDERSON ENGINEERS AND IS INCLUDED IN THIS SET FOR REFERENCE ONLY. HENDERSON ENGINEERS REVIEWED THE DOCUMENTATION ON THIS SHEET FOR GENERAL COMPLIANCE WITH DESIGN INTENT. SUPPLIER IS RESPONSIBLE THAT ALL FURNISHED EQUIPMENT ON THIS SHEET COMPLIES WITH APPLICABLE LOCAL, STATE, AND FEDERAL LAWS, CODES, AND OLDER REGULATIONS.
 LICENSE # 52138
 EXPIRATION DATE: 1/8/2022