

National TAB

Project: JP Morgan Chase (Pittsboro,NC)

System/Unit: FAN - Exhaust



Asset: EF-1

AREA:BUILDING EXHAUST

Unit Data

	Actual
MFG	GREENHECK
Model Num	G-090-D
Serial Num	301461
Type	CRE

Test Data

	Design	Actual
CFM	350	368
RL Voltage	120	120
RL Amperage	1.2	1.29
Total ESP	-	0.15"

Motor Data

	Actual
Motor MFG	McMillan electric
Horsepower	0.06
Motor Rpm	1550
Phase	1
Voltage (rated)	120
Amperage (rated)	1.2
Service Factor	1

Completed By: Alex Bauer on 11/24/2025

National TAB

Project: JP Morgan Chase (Pittsboro,NC)
 System/Unit: FAN - Exhaust



Asset: EF-2

AREA:DATA ROOM

Unit Data	
	Actual
MFG	GREENHECK
Model Num	SP-A510
Serial Num	27553932
Type	CEILING

Test Data		
	Design	Actual
CFM	500	478
RL Voltage	120	120
RL Amperage	3.3	3.0
Total ESP	-	0.10"

Motor Data	
	Actual
Motor MFG	GREENHECK
Horsepower	224W
Motor Rpm	1049
Phase	1
Voltage (rated)	115
Amperage (rated)	3.3
Service Factor	1.0

Completed By: Alex Bauer on 11/24/2025