

## Will Turnbough

---

**From:** Mitch Chvilicek <Mitchell.Chvilicek@RWDI.com>  
**Sent:** Thursday, October 6, 2022 9:51 AM  
**To:** Will Turnbough; Titus Mowry  
**Subject:** Nike Southlake

During the Cx testing yesterday it was discovered the outdoor air supply unit SF-1 was not the proper model and the back draft damper was stuck closed. Since this unit delivers 1300 CFM for maximum OSA volume to the FCUs it was no wonder the sales floor FCUs were under design volume (75%-85%). They are installing the proper SF-1 unit and also making some modifications (branch dampers on FCU-3 and FCU-5 and IT Room EF discharge ducting/grille) which will hopefully allow for proper TAB and design volumes. Who ever completes the TAB at the site will need to coordinate with CSUSA EMS to manipulate the controls/dampers/etc. Let me know if there are any questions.



**Mitch Chvilicek, P.E., LEED AP BD+C, CxA** | SENIOR COMMISSIONING CONSULTANT  
RWDI  
421 SW 6<sup>th</sup> Avenue, Suite 450, Portland, Oregon, USA 97204  
Tel: (503) 467-4710 ext 5714 | Mobile: (503) 250-4773  
[rwdi.com](http://rwdi.com) | [mitchell.chvilicek@rwdi.com](mailto:mitchell.chvilicek@rwdi.com)

---

*Celebrating 50 years of engineering for the environment*

---

**RWDI - A Platinum Member of Canada's 50 Best Managed Companies**

This communication is intended for the sole use of the party to whom it was addressed and may contain information that is privileged and/or confidential. Any other distribution, copying or disclosure is strictly prohibited. If you received this email in error, please notify us immediately by replying to this email and delete the message without retaining any hard or electronic copies of same. Outgoing emails are scanned for viruses, but no warranty is made to their absence in this email or attachments. If you require any information supplied by RWDI in a different format to facilitate accessibility, contact the sender of the email, email [solutions@rwdi.com](mailto:solutions@rwdi.com) or call +1.519.823.1311.

Please be aware that when you contact us with a business query we may collect and use your details for future communications.

---