

**Report By:**

National TAB  
1329 E. KEMPER ROAD  
SUITE 4210  
CINCINNATI, OH 45246



**Report: Prelim Report**  
**Function: Test, Adjust, & Balance**  
**Date: 01/20/2025**  
**Completed By: National TAB**

**PROJECT**  
**First Financial Bank (Kettering, OH)**

4391 Far Hills Ave

Kettering, OH 45429

**Client**

WAT-KEM Mechanical  
2755 S. County Road 25A

Troy, OH 45373

# National TAB

Project: First Financial Bank (Kettering, OH)

## Table Of Contents

Section	Page #
Diffuser Supply (GRD)	3

# National TAB

Project: First Financial Bank (Kettering, OH)



**Diffuser Supply (GRD)**

**AIR DEVICES/**

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	230	SD	10	180	163	163	90.6
SGRD3	135	8	100	100	97	97	97.0
SGRD4	134	SG	180	180	83	83	46.1
SGRD6	133	SD	8	160	153	153	95.6
SGRD7	132	SD	160	160	150	150	93.8
SGRD8	128	SD	10	310	234	234	75.5
SGRD9	131	SD	8	160	172	172	107.5
Total				1250	1052	1052	84.16%

Completed By: Jordan Best on 01/20/2025