


STACK THERMOSTATS VERTICAL
COORDINATE LOCATION W/ P.O.S.
SYSTEM COMPONENTS

4" DRYER EXHAUST TO HOODED
WALL CAP W/ BACKDRAFT
DAMPER. PAINT WALL CAP TO
MATCH EXTERIOR.

TRANSFER GRILLES CENTERED
ABOVE DOOR, AND BETWEEN
DOOR AND CEILING.

KEEP AREA CLEAR FOR
ACCESS ABOVE CEILING TO
SPACE OVER WALK-INS

E5 HVAC PLAN
SCALE: 1/4" = 1'-0"



NOTE: ALL DUCTWORK TO BE LOCATED IN TRUSS SPACE WHERE POSSIBLE.
SEE FRAMING PLAN.