



ENSURE NEAT AND CLEAN INSTALLATION OF ALL EXPOSED DUCTWORK AND AIR DEVICES AT THE TERMINATION OF WORK. CLEAN ALL EXPOSED DUCTWORK AND AIR DEVICES. EXPOSED DUCTS AND AIR DEVICES SHALL BE PROTECTED FROM STICKERS, WRITING, SCRATCHES, OR OTHER FOREIGN OBJECTS OR CONTAMINANTS.

INSTALL SUPPLY AND TRANSFER DUCTS ABOVE BEER CAVE CAP AS CLOSE TO INDICATED AIR DEVICE LOCATIONS AS POSSIBLE FOR FUTURE CONNECTION. DO NOT INSTALL AIR DEVICES IN BEER CAVE AND RETAIL WALL. SITE WILL NOT RECEIVE ALCOHOL LICENSING. VERIFY WITH WAMA IF BEER CAVE SHOULD BE CONVERTED TO ROOM TEMPERATURE SPACE OR REMAIN REFRIGERATED.

SELF SERVICE WALK-IN REFRIG.  
 INSTALL AIR DEVICES (IF REQUIRED) IN CENTER OF COOLER PANELS TO AVOID CUTTING OF COOLER STUDS TO ACCURATE TO CENTER OF PANEL BEFORE MAKING ANY CUTS (TYP).

PAINTABLE HD WALL WITH ARCH REQUIREMENTS FOR PAINTING

MOUNT 14'-0" AFF

250 CFM

RC-3

10x10

6'-7"

8'-9"

SD-5

250 CFM

EG-1

150 CFM

EF-1-2

PROVIDE WITH INTEGRAL OPPOSED BLADE DAMPER

8'0"

SD-5

175 CFM

EG-1

225 CFM

EF-1-1

PROVIDE WITH INTEGRAL OPPOSED BLADE DAMPER

8'0"

INSTALL SUPPLY AND TRANSFER DUCTS ABOVE BEER CAVE CAP AS CLOSE TO INDICATED AIR DEVICE LOCATIONS AS POSSIBLE FOR FUTURE CONNECTION. DO NOT INSTALL AIR DEVICES IN BEER CAVE AND RETAIL WALL. SITE WILL NOT RECEIVE ALCOHOL LICENSING. VERIFY WITH WAMA IF BEER CAVE SHOULD BE CONVERTED TO ROOM TEMPERATURE SPACE OR REMAIN REFRIGERATED.

SELF SERVICE WALK-IN REFRIG.  
 INSTALL AIR DEVICES (IF REQUIRED) IN CENTER OF COOLER PANELS TO AVOID CUTTING OF COOLER STUDS TO ACCURATE TO CENTER OF PANEL BEFORE MAKING ANY CUTS (TYP).

PAINTABLE HD WALL WITH ARCH REQUIREMENTS FOR PAINTING

MOUNT 14'-0" AFF

250 CFM

RC-3

10x10

6'-7"

8'-9"

SD-5

250 CFM

EG-1

150 CFM

EF-1-2

PROVIDE WITH INTEGRAL OPPOSED BLADE DAMPER

8'0"

SD-5

175 CFM

EG-1

225 CFM

EF-1-1

PROVIDE WITH INTEGRAL OPPOSED BLADE DAMPER

8'0"