

SIGNATURE DATE: 08/27/2025

**H & B**  
**HOSS & BROWN** ENGINEERS  
 15902 Midland Drive  
 Shawnee, Kansas 66217  
 913.262.9090 | mail@hb-engineers.com  
 © Hoss & Brown Engineers 2025

**QuikTrip No. 0585**  
 4720 HAMILTON STREET  
 OMAHA, NEBRASKA



© QUIKTRIP CORPORATION 2025  
 ALL INFORMATION IS UNCLASSIFIED AND PUBLICLY AVAILABLE. DISTRIBUTION OF THIS DOCUMENT IS UNRESTRICTED.


PROTOTYPE	Fryer
DIVISION	Des Moines
VERSION	4600
DATE	06-18-2025

REV	DATE	DESCRIPTION

ORIGINAL ISSUE DATE: 08/27/2025

- 1 REMOVE KITCHEN HOOD SYSTEM AND ALL ASSOCIATED GREASE DUCT BETWEEN HOOD AND EXHAUST FAN ON ROOF, RE: M102.
- 2 REMOVE ROOF-MOUNTED EXHAUST FAN AND ALL ASSOCIATED DUCT WORK, RE: M102.
- 3 EXISTING TEMPERATURE SENSOR AND HUMIDITY SENSOR FOR ROOFTOP UNIT SERVING KITCHEN SHALL REMAIN; SHOWN FOR REFERENCE.
- 4 EXISTING ROOF EQUIPMENT SHALL REMAIN; SHOWN FOR REFERENCE.
- 5 REMOVE DIFFUSER AND ASSOCIATED FLEX DUCT BACK TO LOCATION SHOWN AND RETAIN FOR RELOCATION, RE: M102.

**A1** MECHANICAL DUCTWORK CEILING PLAN - DEMO



**A13** PLAN NOTES

SHEET TITLE:  
 MECHANICAL DUCTWORK CEILING PLAN - DEMO

SHEET NUMBER:  
**M101**





