



# National TAB

Testing, Adjusting, and Balancing Equipment



| Function    |                                   | Range                     | Minimum Accuracy            | Instrument Information   | Calibration Date | Date Due   |
|-------------|-----------------------------------|---------------------------|-----------------------------|--|------------------|------------|
| AIR         | AIR PRESSURE                      | 0 in wg to 10 in wg       | 2% +/- 0.001 in wg          | Evergreen S-PVF-1<br>25D-00991                                 | 11/13/2025       | 11/13/2026 |
|             | AIR VELOCITY INSTRUMENT           | 50 fpm to 3900 fpm        | +/- 5 %<br>+/- 7 fpm        | Evergreen S-PVF-1<br>25D-00991                                 | 11/13/2025       | 11/13/2026 |
|             | DIRECT HOOD READING               | 100 cfm to 2000 cfm       | +/- 5 %<br>+/- 7 cfm        | Evergreen S-PVF-1<br>25D-00991                                 | 11/13/2025       | 11/13/2026 |
| TEMPERATURE | AIR METER                         | -20 F to 240 F            | +/- .5 %<br>2 F             | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
|             | AIR PROBE                         | -20 F to 240 F            | +/- .5 %<br>2 F             | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
|             | IMMERSION METER                   | -20 F to 240 F            | +/- .5 %<br>2 F             | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
|             | IMMERSION PROBE                   | -20 F to 240 F            | +/- .5 %<br>2 F             | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
|             | CONTACT METER                     | -20 F to 240 F            | +/- .5 %<br>2 F             | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
|             | CONTACT PROBE                     | -20 F to 240 F            | +/- .5 %<br>2 F             | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
| HUMIDITY    | HUMIDITY PROBE                    | 10 % RH to 90 % RH        | 3% of reading               | Cooper SRH77A S/N 100516003                                    | 9/30/2025        | 9/30/2026  |
| ELECTRICAL  | VOLTAGE MEASUREMENT               | 0 VAC to 600 VAC          | 2 % reading<br>+/- 5 digits | Klein Tools CL800<br>S/N 1220C-C1                              | 9/30/2025        | 9/30/2026  |
|             | AMPERAGE MEASUREMENT              | 0 Amperers to 100 Amperes | 2 % reading<br>+/- 5 digits | Klein Tools CL800<br>S/N 1220C-C1                              | 9/30/2025        | 9/30/2026  |
| ROTATION    | ROTATION MEASUREMENT              | 60 rpm to 5000 rpm        | 2 % reading<br>2 rpm        | Shimpo DT 207Lp<br>S/N D1690029R                               | 9/30/2025        | 9/30/2026  |
| HYDRONIC    | PRESSURE MEASUREMENT              | -30 in Hg to 200 psi      | ±2% of reading<br>+/- 1 psi | Hydronic Manometer - Dwyer 490W-6-HKIT<br>S/N: 359515093207912 | 10/23/2025       | 10/23/2026 |
|             | DIFFERENTIAL PRESSURE MEASUREMENT | 0 psi - 80 psi            | ±2% of reading<br>+/- 1 psi | Hydronic Manometer - Dwyer 490W-6-HKIT<br>S/N: 359515093207912 | 10/23/2025       | 10/23/2026 |