

# National TAB

Project: 02-23-26 WHATABURGER #1644 GARNER, NC

## Table Of Contents

Section	Page #
Issue Data	2

## Issue List

- HD-1 Not Wired/Connected
- HD-2 Not Wired/Connected
- Motion Sensors Not Installed in Restrooms




02-23-26 WHATABURGER #1644 GARNER, NC

Project Issue Information


**Issue Name :** HD-1 Not Wired/Connected  
**Description :** The on/off switch for HD-1 is not wired. The technician from Chisholm Service says the hoods are also not connected to the RTUs. The switch needs to be wired and the hood systems connected to the RTUs.

**Created By :** National TAB      **Assigned To :** National TAB - Brianna Biggs  
**Status :** Open  
**Priority :** Urgent      **Asset Tag :** HD1  
**Originated Date :** 02/23/2026 - Alex Bauer - National TAB

Project Issue File Details



02/23/2026



02/23/2026



02/23/2026



**02-23-26 WHATABURGER #1644 GARNER, NC**

**Project Issue Information**

**Issue Name :** HD-2 Not Wired/Connected  
**Description :** The on/off switch for HD-2 is not wired. The technician from Chisholm Service says the hoods are also not connected to the RTUs. The switch needs to be wired and the hood systems connected to the RTUs.  
**Created By :** National TAB                      **Assigned To :** National TAB - Brianna Biggs  
**Status :** Open  
**Priority :** Urgent                                      **Asset Tag :** HD2  
**Originated Date :** 02/23/2026 - Alex Bauer - National TAB


Project Issue File Details



02/23/2026



02/23/2026



02/23/2026



**02-23-26 WHATABURGER #1644 GARNER, NC**


**Project Issue Information**

**Issue Name :** Motion Sensors Not Installed in Restrooms  
**Description :** The motion sensors to activate the EF-1 fan damper and to turn on EF-1 are not present. Without these sensors the fan cannot turn on. It would be best to install the sensors so the fan can function.  
**Created By :** National TAB                      **Assigned To :** National TAB - Brianna Biggs  
**Status :** Open  
**Priority :** **Urgent**                                      **Asset Tag :** EF1  
**Originated Date :** 02/23/2026 - Alex Bauer - National TAB

Project Issue File Details



02/23/2026



02/23/2026