



KEEP THIS AREA CLEAR OF EQUIPMENT, DUCT WORK AND PIPING TO MAINTAIN CLEAR ACCESS TO ABOVE

- ER-1  
12"x12"  
75  
TYP. OF 3
- MAU-1  
600LBS
- BS-1  
TYP. OF 3

- CD-1  
8"  
150

- RG-1  
24"x6"

- PCU-1 (24)  
2100LBS

U/S OF LAY-IN CEILING @ 9'-0" AFF  
U/S OF LAY-IN CEILING @ 10'-0" AFF

11

U/S OF EXISTING STRUCTURE @ 17'-5" AFF  
U/S OF GWB CEILING @ 8'-0" AFF

- FC-GF-03F  
147LBS

- FC-03F-2

- FC-03F-3

- FC-03F-4

- EF2-1

- EF2-2

- EF2-3

- HAC-1  
MTD. MAXIMUM  
10'-6" AFF

THERMAL CERAMICS FIREMASTER FASTWRAP XL  
MEETS ZERO CLEARANCE TO COMBUSTIBLES. REF  
TO DETAIL 3/M700.

U/S OF SLAT CEILING @ 11'-6" AFF  
EXISTING 56"x17" LOUVRE (TYP.)

26"x16" KITCHEN EXHAUST.  
MAINTAIN MIN. 3" FROM LIMITED  
COMBUSTIBLE CEILING.

- RG-1  
24"x24"

- HD-1 MUA-1

- FC-A-1 ACPSP

- FC-03F-6

- FC-03G-6

- FC-03G-5

- FC-03G-4

- FC-03G-3

- FC-03G-2

- FC-03G-1

U/S OF LAY-IN CEILING @ 12'-6" AFF

- SF-1

- CD-1  
8"  
225  
TYP. OF 2

- RG-1  
24"x24"

U/S OF STONWOOD CEILING @ 9'-1 1/4" AFF  
U/S OF STONWOOD CEILING @ 9'-1 1/4" AFF

EXISTING E/A SHAFT SERVING BASE BUILDING

14" @ 0/A @ 15'-6" AFF

- EF-2

- FC-GF-03H  
147LBS  
MTD. 24" BELOW  
SLAB TO ALLOW  
MAINTENANCE

- SR-1  
8"  
20B  
TYP. OF 6

- HAC-2  
MTD. MAXIMUM  
10'-6" AFF

U/S OF GWB CEILING @ 9'-0" AFF

U/S OF SLAT CEILING @ 11'-6" AFF  
U/S OF EXISTING SLAB @ 17'-5 1/4" AFF

CHIPOTLE 4546

- SR-1  
10"  
312  
TYP. OF 4

1 M702

2 M702