

PlanGrid Task Report - Aug 16, 2024

Prepared by Ian Fuller

Aug 16, 2024

Description

2 tasks in this report.

Contents

#102 [UNIT 164] Equipment gas piping.	
#101 [UNIT 167] Condensate piping construction.....	

#102 [UNIT 164] Equipment gas piping.

Status

Open

Start Date

Aug 12, 2024

Type

Planned Work

Created

Aug 12, 2024 5:11 PM
ianf@nationaltab.com

Description

Equipment missing gas grommet, gas startups incomplete. Valves are not turned on. Gas piping is not painted.

Last Updated

Aug 12, 2024 5:23 PM

Photos

L05321 Newington (NH) FSU (NH)

2060 Woodbury Avenue, Newington, New Hampshire

L0111110200



IMG_8086

Ian Fuller

Aug 12, 2024 5:23 PM

#101 [UNIT 167] Condensate piping construction.

Status

Open

Start Date

Aug 12, 2024

Type

Planned Work

Created

Aug 12, 2024 5:11 PM
ianf@nationaltab.com

Description

Equipment condensate piping or p-trap is not constructed per normal CFA specifications as shown on P-250.

Last Updated

Aug 12, 2024 5:23 PM

Photos