







HALTON HOODS - ETL LISTED PER LATEST 710 STANDARD - BUILT PER NFPA 96 NSF LISTED

HALTON COMPANY, 101 INDUSTRIAL DR., SCOTTSVILLE, KY 42564  
MODEL NO. SERIAL NO. ITEM NO.  
KVL-2-1C

GENERAL REQUIREMENTS  
FILTER TYPE EXHAUST HOOD FOR COMMERCIAL AND INSTITUTIONAL KITCHENS  
THE FAN CIRCUIT IS RATED FOR 120V, 15A, 60HZ.  
THE LIGHTING CIRCUIT IS RATED FOR 120V, 15A, 60HZ.  
THE HOOD HAS BEEN CERTIFIED BY ETL FOR 3 INCH CLEARANCE TO COMBUSTIBLE MATERIALS (TOP, SIDES, FRONT AND REAR) IN COMPLIANCE WITH UL 710 WITH CONSIDERATIONS TO NFPA 96.  
REPLACE FILTERS ONLY WITH UL CLASSIFIED FILTER TYPE OF THE SAME MODEL AND MANUFACTURER.  
SUITABLE FOR USE TO HEAVY DUTY COOKING APPLIANCES.

DUTY LEVEL	MINIMUM OVERHANG	SPACING BETWEEN FRONT EDGE OF HOOD AND COOKING APPLIANCE		MIN. EXHAUST HOOD LENGTH
		FRONT, IN	SIDE, IN	
MEDIUM	6"	0	20	36"
MEDIUM	6"	0	20	36"
HEAVY	12"	0	20	36"
HEAVY	12"	0	20	36"

1" = 25.4 MILLIMETER DISTANCE  
JET SUPPLY AIR FLOW SHALL ONLY BE SET AT 520 IN HO3

NSF Halton INTERTEK BRIDGE

HALTON COMPANY, 101 INDUSTRIAL DR., SCOTTSVILLE, KY 42564  
MODEL NO. SERIAL NO. ITEM NO.  
KVL-2-1C

GENERAL REQUIREMENTS  
FILTER TYPE EXHAUST HOOD FOR COMMERCIAL AND INSTITUTIONAL KITCHENS  
THE FAN CIRCUIT IS RATED FOR 120V, 15A, 60HZ.  
THE LIGHTING CIRCUIT IS RATED FOR 120V, 15A, 60HZ.  
THE HOOD HAS BEEN CERTIFIED BY ETL FOR 3 INCH CLEARANCE TO COMBUSTIBLE MATERIALS (TOP, SIDES, FRONT AND REAR) IN COMPLIANCE WITH UL 710 WITH CONSIDERATIONS TO NFPA 96.  
REPLACE FILTERS ONLY WITH UL CLASSIFIED FILTER TYPE OF THE SAME MODEL AND MANUFACTURER.  
SUITABLE FOR USE TO HEAVY DUTY COOKING APPLIANCES.

DUTY LEVEL	MINIMUM OVERHANG	SPACING BETWEEN FRONT EDGE OF HOOD AND COOKING APPLIANCE		MIN. EXHAUST HOOD LENGTH
		FRONT, IN	SIDE, IN	
MEDIUM	6"	0	20	36"
MEDIUM	6"	0	20	36"
HEAVY	12"	0	20	36"
HEAVY	12"	0	20	36"

1" = 25.4 MILLIMETER DISTANCE  
JET SUPPLY AIR FLOW SHALL ONLY BE SET AT 520 IN HO3

THIS DRAWING MUST BE CHECKED, SIGNED AND RETURNED TO THE APPROPRIATE FACTORY. PLEASE VERIFY THE FOLLOWING:  
1. ALL DIMENSIONAL INFORMATION, MOUNTING POSITIONS  
2. THE LOCATION AND TYPE OF COOKING EQUIPMENT.

NOTE TO APPROVER  
ANY CHANGES IN COOKING EQUIPMENT SUCH AS INCREASED ENERGY INPUTS OR EQUIPMENT POSITION MAY AFFECT EXHAUST AIRFLOW. HALTON MUST BE NOTIFIED IF ANY OF THESE CHANGES OCCUR. A RE-CALCULATION SHOULD ALLOW FOR ANY CHANGES.  
 REVISION AND RESUBMIT  
 APPROVED FOR FABRICATION  
 WITH NO CHANGES  
 WITH CHANGES AS NOTED

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_



WEBSITE: www.halton.com  
HALTON CO. (USA)  
101 INDUSTRIAL DRIVE  
SCOTTSVILLE, KY 42564  
1-270-237-5600

BY: SKK DATE: 04.16.24

REVISION DESCRIPTION  
REV. 1 REMOVED H-2

MAIL APPROVED DRAWINGS TO APPROPRIATE FACTORY BELOW:  
HALTON CO. (USA)  
101 INDUSTRIAL DRIVE  
SCOTTSVILLE, KY 42564  
1-270-237-5600

HALTON CO. (CANADA)  
1021 BREVIK PLACE  
SCARBOROUGH, ONT. M1V 3R7  
1-905-624-0501

REVISION DESCRIPTION  
REV. 1 REMOVED H-2

PROJECT: CHICK-FIL-A #1918  
WINTER GARDEN

LOCATION: WINTER GARDEN, FL  
DRAWN BY: SKK DATE: 04.11.24  
SCALE: NOT TO SCALE

Halton

DRAWING NO.: U24-281-02  
SHEET NO.: H-1.2



Chick-fil-A  
5200 Buffington Road  
Atlanta, Georgia  
30349-2998

INTERPLAN  
INTERPLAN LLC  
AR99238  
CA 8660  
ARCHITECTURE  
ENGINEERING  
PERMITTING  
220 E. CENTRAL PKWY, STE 4000  
ALAMONTE SPRINGS, FL 32701  
407.645.5038

FOR INFORMATION ONLY

CHICK-FIL-A  
WINTER GARDEN  
3166 DANIELS ROAD  
WINTER GARDEN, FL 34787

FSR#01918

REVISION SCHEDULE	NO.	DATE	DESCRIPTION
CONSULTANT PROJECT #	2022.0766		
DATE	04/26/24		
DRAWN BY	SE		
CHECKED BY	DAK		
Information contained on this drawing and its digital file produced for above named project may not be reproduced in any manner without express written or verbal consent from authorized project representatives.			
SHEET	HOOD DETAILS		
SHEET NUMBER	MH1.2		













