

REGISTERS, GRILLES, AND DIFFUSERS												
MARK	MANUFACTURER	MODEL #	TYPE	GRILLE SIZE	PANEL SIZE	DUCT INLET SIZE	DUCT BRANCH SIZE	MAX CFM	P.D.	NOISE CRITERIA	THROW PATTERN	REMARKS
E-1	PRICE	630	ALUMINUM LOUVERED GRILLE	12"x12"	12"x12"	8"Ø	8"Ø	225	0.05	25	NA	1
R-1	PRICE	630	ALUMINUM LOUVERED GRILLE	24"x24"	24"x24"	NA	NA	400	0.05	25	NA	1
S-1	PRICE	ASPD	ALUMINUM SQUARE PLAQUE DIFFUSER	24"x24"	24"x24"	6"Ø	6"Ø	100	0.05	25	4-WAY	1
S-2	PRICE	ASPD	ALUMINUM SQUARE PLAQUE DIFFUSER	24"x24"	24"x24"	8"Ø	8"Ø	225	0.05	25	4-WAY	1

REMARKS:
1. WHITE IN COLOR.

SPLIT SYSTEM OUTDOOR UNIT SCHEDULE														
MARK	MANUFACTURER	MODEL #	DIMENSIONS (IN.)			WEIGHT (LBS)	TOTAL COOLING (MBH)	SENSIBLE COOLING (MBH)	MINIMUM SEER	ELECTRICAL			REMARKS	
			LENGTH	WIDTH	HEIGHT					MCA	MOC P	VOLTAGE		PHASE
CU-3	CARRIER	24ACB736A003	32	32	35	255	35.0	26.0	17	20 A	35	208	1	1,2,3
CU-4	CARRIER	24ACB748A003	35	35	39	318	47.8	36.4	17	28 A	40	208	1	1,2,3

REMARKS:
1. PROVIDE R-410A REFRIGERANT UNIT WITH ALL REFRIGERATION PIPING SPECIALTIES REQUIRED BY THE MANUFACTURER'S RECOMMENDATIONS. SIZE REFRIGERANT LINES AND PROVIDE INTERMEDIATE TRAPS PER MANUFACTURER'S INSTRUCTIONS.
2. UNIT SHALL BE UL LISTED.
3. PROVIDE SINGLE POINT POWER CONNECTION: INDOOR UNIT IS FED FROM OUTDOOR UNIT.


SPLIT SYSTEM INDOOR UNIT SCHEDULE																
MARK	MODEL #	MANUFACTURER	COIL DIMENSIONS (IN.)			WEIGHT (LBS)	AIRFLOW (CFM)	LENGTH (IN.)	WIDTH (IN.)	HEIGHT (IN.)	FURNACE #	EFFICIENCY	HEATING CAPACITY (MBH)	ELECTRICAL		REMARKS
			LENGTH	WIDTH	HEIGHT									VOLTAGE	PHASE	
FC-3	CNPVP3617ALA	CARRIER	21	18	17	49	1200	29.5	17.5	35	59TP	+96 AFUE	60	120	1	1,2
FC-4	CNPVP4821ALA	CARRIER	21	21	22	66	1600	29.5	21	35	59TP	+96 AFUE	80	120	1	1,2

REMARKS:
1. PROVIDE WITH WALL MOUNTED THERMOSTAT.
2. UNIT IS POWERED BY OUTDOOR UNIT.
3. PROVIDE UNIT WITH PROGRAMMABLE THERMOSTAT. THERMOSTAT SCHEDULE TO BE PROGRAMMED TO MATCH TIME CLOCK SCHEDULE FOR SF-1.


SUPPLY/EXHAUST FAN SCHEDULE													
MARK	MANUFACTURER	MODEL #	SERVICE	TYPE	AIRFLOW (CFM)	E.S.P.	DRIVE	RPM	FAN HP	ELECTRICAL DATA			REMARKS
										VOLTAGE	PHASE	HZ	
EF-1	GREENHECK	SQ-80-VG	RESTROOM EXHAUST	CENTRIFUGAL INLINE FAN	300	0.25	DIRECT	1725	0.1	120	1	60	
EF-2	GREENHECK	SP-A70	RESTROOM EXHAUST	CEILING FAN	50	0.25	DIRECT	850		120	1	60	
EF-3	GREENHECK	SP-A70	RESTROOM EXHAUST	CEILING FAN	50	0.25	DIRECT	850		120	1	60	
SF-1	GREENHECK	SQ-90-VG	OUTSIDE AIR INTAKE	CENTRIFUGAL INLINE FAN	450	0.25	DIRECT	1725	0.1	120	1	60	1,2

REMARKS:
1. PROVIDE FAN WITH PROGRAMMABLE TIME CLOCK.
A. CONTRACTOR SHALL PROGRAM SCHEDULE PROVIDED BY OWNER.
B. TIME CLOCK WILL OPERATE THE SUPPLY FAN AND OPEN THE MOTORIZED DAMPER WHEN THE SPACE IS SCHEDULED TO BE OCCUPIED.
C. CONTRACTOR TO PROVIDE TRAINING TO OWNER ON TIME CLOCK.
2. FAN SHALL HAVE AN ECM MOTOR.

GRAVITY HOOD SCHEDULE										
MARK	MANUFACTURER	MODEL	SERVICE	MAXIMUM CFM	THROAT LENGTH (IN)	THROAT WIDTH (IN)	THROAT VELOCITY (FPM)	PRESSURE DROP (IN WC)	WEIGHT (LBS.)	REMARKS
GH-1	GREENHECK	GRSI	OUTSIDE AIR INTAKE	450	12	12	500	0.25	10	



2 TYPICAL ROUND SUPPLY, RETURN, & EXHAUST BRANCH DUCT DETAIL
M-300 NOT TO SCALE



1 DUCTED RETURN/EXHAUST/RELIEF AIR GRILLE DETAIL
M-300 NOT TO SCALE



720 E Pete Rose Way, Suite 140
Cincinnati, OH 45202
T 513.241.4474 F 513.241.0081
thinkchamplin.com

THINK CREATE REALIZE



**Sheakley
Renovation +
Expansion**

5050 Madison Rd
Cincinnati, OH 45227

ISSUANCES

No.	Description	Date
1	BID + PERMIT	09/07/22

Drawn By	CRH
Checked By	BKR
Client Number	
Project Number	6531

DRAWING TITLE
DETAILS AND SCHEDULES

SHEET NO.
M-300

VENTILATION CALCULATIONS												
EQUIPMENT TAG	ROOM NAME	SPACE TYPE	AREA (SF)	PEOPLE	OA CFM REQ'D / PERSON	OA CFM REQ'D / SF	Ez	OA REQ'D (CFM)	BIPOLAR OA (CFM)	%OA	SA TO SPACE	ACTUAL OA (CFM)
BC-1	01 LOBBY	LOBBIES	134	0	5	0.06	0.8	10	30	15%	180	27
	02 PRIVATE OFFICE #2	OFFICE	91	1	5.0	0.06	0.8	13	25	15%	150	23
	03 PRIVATE OFFICE #1	OFFICE	113	1	5.0	0.06	0.8	15	15	15%	100	15
	04 CLASSROOM #11	LECTURE CLASSROOM	360	12	7.5	0.06	0.8	140	60	15%	400	60
	13 CLASSROOM #3	LECTURE CLASSROOM	368	12	7.5	0.06	0.8	140	60	15%	400	60
	14 COMFORT	BREAKROOM	56	1	5	0.06	1	10	10	15%	65	10

VENTILATION CALCULATIONS												
EQUIPMENT TAG	ROOM NAME	SPACE TYPE	AREA (SF)	PEOPLE	OA CFM REQ'D / PERSON	OA CFM REQ'D / SF	Ez	OA REQ'D (CFM)	BIPOLAR OA (CFM)	%OA	SA TO SPACE	ACTUAL OA (CFM)
BC-2	05 CLASSROOM #10	LECTURE CLASSROOM	360	12	7.5	0.06	0.8	140	60	15%	400	60
	18 CLASSROOM #2	LECTURE CLASSROOM	364	12	7.5	0.06	0.8	140	60	15%	400	60
	19 CLASSROOM #1	LECTURE CLASSROOM	360	12	7.5	0.06	0.8	140	45	15%	300	45
	20 STORAGE	STORAGE	72	0	0.0	0.06	0.8	5	10	15%	50	8
	21 COMFORT	BREAKROOM	158	3	5.0	0.06	0.8	31	35	15%	205	31
	22 CONFERENCE	CONFERENCE	231	10	5	0.06	0.8	80	45	15%	300	45
23 SHARED OFFICE	OFFICE	486	8	5.0	0.06	0.8	86	60	15%	400	60	

VENTILATION CALCULATIONS												
EQUIPMENT TAG	ROOM NAME	SPACE TYPE	AREA (SF)	PEOPLE	OA CFM REQ'D / PERSON	OA CFM REQ'D / SF	Ez	OA REQ'D (CFM)	BIPOLAR OA (CFM)	%OA	SA TO SPACE	ACTUAL OA (CFM)
FC-3	05 CLASSROOM #10	LECTURE CLASSROOM	360	12	7.5	0.06	0.8	140	60	15%	400	60
	07 CLASSROOM #9	LECTURE CLASSROOM	354	12	7.5	0.06	0.8	139	60	15%	400	60
	08 CLASSROOM #8	LECTURE CLASSROOM	356	12	7.5	0.06	0.8	139	60	15%	400	60

VENTILATION CALCULATIONS												
EQUIPMENT TAG	ROOM NAME	SPACE TYPE	AREA (SF)	PEOPLE	OA CFM REQ'D / PERSON	OA CFM REQ'D / SF	Ez	OA REQ'D (CFM)	BIPOLAR OA (CFM)	%OA	SA TO SPACE	ACTUAL OA (CFM)
FC-4	09 CLASSROOM #7	LECTURE CLASSROOM	369	12	7.5	0.06	0.8	140	60	15%	400	60
	10 CLASSROOM #6	LECTURE CLASSROOM	369	12	7.5	0.06	0.8	140	60	15%	400	60
	11 CLASSROOM #5	LECTURE CLASSROOM	368	12	7.5	0.06	0.8	140	60	15%	400	60
	12 CLASSROOM #4	LECTURE CLASSROOM	368	12	7.5	0.06	0.8	140	60	15%	400	60
	WEST CORRIDOR	CORRIDOR	460	0	0	0	1	35	15	15%	100	15

BC-1 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft)	Zone Max Occupancy	Table 6.1 OA per Occupant	Table 6.1 cfm/ft2	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness	Outdoor Air to Zone (CFM) with Ez correction
CLASSROOM #3	Educational Facilities	Lecture Classroom	361.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP

Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CF)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant

Air Changes Per Hour	7.8	VRP OA CFM per person	11.6
Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	80 CFM	Winter Heating Savings	
OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer**	0.5		

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP*	Steady State (lb/ft3) Using the IAQ Method (Reduced OA)	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.5357E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4151E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.6001E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6192E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.5000E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7609E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1674E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1996E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6319E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.8128E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4512E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1249E-05	2.8116E-05	Yes	3.8318E-04	50%	OSHA
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA

1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
2 = CO2 Level at Ventilation Rate OA Flow Rate
3 = CO2 Level at IAQ Procedure OA Flow Rate

Building materials and furnishings assumed to have no VOCs and off-gassing is complete. All yellow shaded boxes require user input or review. Is IAQ acceptable at reduced outside air levels? Yes

**Carbon dioxide has been provided for reference only for gathering demand control ventilation (DCV) setpoints. The National Research Council was commissioned by the US Navy to prove CO2 is not a contaminant of concern when using air purification to control the other contaminants of concern, as found on submarines.

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

BC-1 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft)	Zone Max Occupancy	Table 6.1 OA per Occupant	Table 6.1 cfm/ft2	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness	Outdoor Air to Zone (CFM) with Ez correction
CLASSROOM #11	Educational Facilities	Lecture Classroom	360.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP

Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CF)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant

Air Changes Per Hour	7.8	VRP OA CFM per person	11.6
Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	80 CFM	Winter Heating Savings	
OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer**	0.5		


Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP*	Steady State (lb/ft3) Using the IAQ Method (Reduced OA)	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.5357E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4151E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.6001E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6201E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.5051E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7611E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1676E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.2003E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6366E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.8181E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4525E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1271E-05	2.8116E-05	Yes	3.8318E-04	50%	OSHA
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA

1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
2 = CO2 Level at Ventilation Rate OA Flow Rate
3 = CO2 Level at IAQ Procedure OA Flow Rate

Building materials and furnishings assumed to have no VOCs and off-gassing is complete. All yellow shaded boxes require user input or review. Is IAQ acceptable at reduced outside air levels? Yes

**Carbon dioxide has been provided for reference only for gathering demand control ventilation (DCV) setpoints. The National Research Council was commissioned by the US Navy to prove CO2 is not a contaminant of concern when using air purification to control the other contaminants of concern, as found on submarines.

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2



720 E Pete Rose Way, Suite 140
Cincinnati, OH 45202
T 513.241.4474 F 513.241.0081
thinkchamplin.com

THINK CREATE REALIZE



Sheakley Renovation + Expansion

5050 Madison Rd
Cincinnati, OH 45227

ISSUANCES

No.	Description	Date
1	BID + PERMIT	09/07/22

Drawn By	CRH
Checked By	BKR
Client Number	
Project Number	6531

DRAWING TITLE

MECHANICAL VENTILATION CALCULATIONS

SHEET NO.

M-400

BC-2 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/f2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #1	Educational Facilities	Lecture Classroom	360.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP


Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CF)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant

Air Changes Per Hour	7.8	VRP OA CFM per person	11.6
Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	80 CFM		

OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer*	0.5		

Contaminant Generation	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	50%	OSHA
Acetone	50%	NIOSH
Ammonia	50%	NIOSH
Benzene	50%	OSHA
2- Butanone (MEK)	50%	NIOSH
Carbon dioxide**	0%	NIOSH
Chloroform	50%	NIOSH
Dioxane	50%	OSHA
Hydrogen Sulfide	50%	NIOSH
Methane	0%	NA
Methanol	0%	NIOSH
Methylene Chloride	50%	OSHA
Propane	0%	NIOSH
Tetrachloroethane	50%	OSHA
Tetrachloroethylene	50%	OSHA
Toluene	50%	NIOSH
1,1,1 - Trichloroethane	50%	NIOSH
Xylene	50%	OSHA

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/f3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/f3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.835E-09	1.1297E-09	Yes	1.2933E-08	50%	OSHA
Acetone	250.0	1.4159E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.6053E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6201E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.5051E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7611E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1676E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.2491E-09	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6366E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.8181E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4525E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1271E-05	2.8118E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
 2 = CO2 Level at Ventilation Rate OA Flow Rate
 3 = CO2 Level at IAQ Procedure OA Flow Rate

**Carbon dioxide has been provided for reference only for gathering demand control ventilation (DCV) setpoints. The National Research Council was commissioned by the US Navy to prove CO2 is not a contaminant of concern when using air purification to control the other contaminants of concern, as found on submarines.

Building materials and furnishings assumed to have no VOCs and off-gassing is complete
 All yellow shaded boxes require user input or review

Is IAQ acceptable at reduced outside air levels? **Yes**

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

BC-2 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/f2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #2	Educational Facilities	Lecture Classroom	364.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP


Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CF)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant

Air Changes Per Hour	7.8	VRP OA CFM per person	11.7
Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	80 CFM		

OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer*	0.5		

Contaminant Generation	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	50%	OSHA
Acetone	50%	NIOSH
Ammonia	50%	NIOSH
Benzene	50%	OSHA
2- Butanone (MEK)	50%	NIOSH
Carbon dioxide**	0%	NIOSH
Chloroform	50%	NIOSH
Dioxane	50%	OSHA
Hydrogen Sulfide	50%	NIOSH
Methane	0%	NA
Methanol	0%	NIOSH
Methylene Chloride	50%	OSHA
Propane	0%	NIOSH
Tetrachloroethane	50%	OSHA
Tetrachloroethylene	50%	OSHA
Toluene	50%	NIOSH
1,1,1 - Trichloroethane	50%	NIOSH
Xylene	50%	OSHA

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/f3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/f3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.835E-09	1.1297E-09	Yes	1.2933E-08	50%	OSHA
Acetone	250.0	1.4129E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5847E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6167E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4847E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7605E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1670E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1977E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6180E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.7917E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4473E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1182E-05	2.8118E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
 2 = CO2 Level at Ventilation Rate OA Flow Rate
 3 = CO2 Level at IAQ Procedure OA Flow Rate

**Carbon dioxide has been provided for reference only for gathering demand control ventilation (DCV) setpoints. The National Research Council was commissioned by the US Navy to prove CO2 is not a contaminant of concern when using air purification to control the other contaminants of concern, as found on submarines.

Building materials and furnishings assumed to have no VOCs and off-gassing is complete
 All yellow shaded boxes require user input or review

Is IAQ acceptable at reduced outside air levels? **Yes**

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

BC-2 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/f2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CONFERENCE #22	Educational Facilities	Conference/meeting	231.0	10.0	5.0	0.06	50	14	0.8	80 OA required per VRP


Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CF)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant

Air Changes Per Hour	12.2	VRP OA CFM per person	8.0
Outside Air Per VRP	80 CFM	IAQ OA CFM per person	6.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	20 CFM		

OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	1.6
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	0.5
OA MBH Saved Summer*	1.4		
OA Tons Saved Summer*	0.1		

Contaminant Generation	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	50%	OSHA
Acetone	50%	NIOSH
Ammonia	50%	NIOSH
Benzene	50%	OSHA
2- Butanone (MEK)	50%	NIOSH
Carbon dioxide**	0%	NIOSH
Chloroform	50%	NIOSH
Dioxane	50%	OSHA
Hydrogen Sulfide	50%	NIOSH
Methane	0%	NA
Methanol	0%	NIOSH
Methylene Chloride	50%	OSHA
Propane	0%	NIOSH
Tetrachloroethane	50%	OSHA
Tetrachloroethylene	50%	OSHA
Toluene	50%	NIOSH
1,1,1 - Trichloroethane	50%	NIOSH
Xylene	50%	OSHA

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/f3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/f3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	3.2696E-09	9.7194E-10	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	2.0534E-08	7.9695E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	1.3988E-06	5.4599E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	2.3365E-08	8.9987E-09	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	1.3842E-06	4.9322E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.8822E-05	5.0100E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.3017E-07	4.4198E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.7480E-08	2.3256E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	1.2355E-06	4.9398E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	1.4290E-06	5.5736E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	3.5715E-09	1.3940E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	6.0072E-05	2.3432E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA




1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
 2 = CO2 Level at Ventilation Rate OA Flow Rate
 3 = CO

FC-3 VENTILATION


Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #8	Educational Facilities	Lecture Classroom	359.0	12.0	7.5	0.06	90	22	0.8	139

Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CFM)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr) (CFM)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant



Air Changes Per Hour	7.9	VRP OA CFM per person	11.6
Outside Air Per VRP	139 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	79 CFM	Winter Heating Savings	
OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer*	0.5		

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP*	Steady State (lb/ft3) Using the IAQ Method	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
		(Prescribed OA) Plasma Off	(Reduced OA) Plasma On				
Acetaldehyde	100.0	2.6372E-09	1.1297E-09	Yes	1.293E-08	50%	OSHA
Acetone	250.0	1.4166E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.6104E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6209E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.5102E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7612E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1677E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.2003E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6412E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.8234E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4538E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1293E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
 2 = CO2 Level at Ventilation Rate OA Flow Rate
 3 = CO2 Level at IAQ Procedure OA Flow Rate


Building materials and furnishings assumed to have no VOCs and off-gassing is complete	Is IAQ acceptable at reduced outside air levels?	Yes
--	--	-----

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

FC-3 VENTILATION


Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #9	Educational Facilities	Lecture Classroom	355.0	12.0	7.5	0.06	90	21	0.8	139

Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CFM)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr) (CFM)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant



Air Changes Per Hour	8.0	VRP OA CFM per person	11.6
Outside Air Per VRP	139 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	79 CFM	Winter Heating Savings	
OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.4
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer*	0.5		

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP*	Steady State (lb/ft3) Using the IAQ Method	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
		(Prescribed OA) Plasma Off	(Reduced OA) Plasma On				
Acetaldehyde	100.0	2.6402E-09	1.1297E-09	Yes	1.293E-08	50%	OSHA
Acetone	250.0	1.4196E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.6312E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6243E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.5398E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7618E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1684E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.2035E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6598E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.8445E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4591E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1382E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
 2 = CO2 Level at Ventilation Rate OA Flow Rate
 3 = CO2 Level at IAQ Procedure OA Flow Rate


Building materials and furnishings assumed to have no VOCs and off-gassing is complete	Is IAQ acceptable at reduced outside air levels?	Yes
--	--	-----

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

FC-3 VENTILATION


Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #10	Educational Facilities	Lecture Classroom	360.0	12.0	7.5	0.06	90	22	0.8	140

Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CFM)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr) (CFM)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant



Air Changes Per Hour	7.8	VRP OA CFM per person	11.6
Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	80 CFM	Winter Heating Savings	
OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.8		
OA Tons Saved Summer*	0.5		

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP*	Steady State (lb/ft3) Using the IAQ Method	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
		(Prescribed OA) Plasma Off	(Reduced OA) Plasma On				
Acetaldehyde	100.0	2.6365E-09	1.1297E-09	Yes	1.293E-08	50%	OSHA
Acetone	250.0	1.4159E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.6053E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6201E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.5015E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7611E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1676E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.2003E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.6366E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.8181E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4525E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1271E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



1 = ASHRAE IAQP & NIOSH CO2 Limit is 5,000 PPM
 2 = CO2 Level at Ventilation Rate OA Flow Rate
 3 = CO2 Level at IAQ Procedure OA Flow Rate


Building materials and furnishings assumed to have no VOCs and off-gassing is complete	Is IAQ acceptable at reduced outside air levels?	Yes
--	--	-----

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

FC-4 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #4	Educational Facilities	Lecture Classroom	369.0	12.0	7.5	0.06	90	22	0.8	140

Zone Height (feet)	8.5
Desired Outside Air (Vo) IAQP (CFM)	60
Supply Air (Vs) (CFM)	400
Return Air (Vr) (CFM)	340
Recirc. Flow Factor (R)	0.85
Ventilation Effectiveness (Ez)	0.8
Level of Physical Activity	Sedentary
Filter Location	B
HVAC Flow Type	Constant
Outdoor Air Flow Type	Constant




Air Changes Per Hour	7.7	VRP OA CFM per person	11.7
Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Outside Air Per IAQ	60 CFM		
Outside Air Savings	80 CFM	Winter Heating Savings	
OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
OA MBH Saved Summer*	5.9		
OA Tons Saved Summer*	0.5		

Indoor Contaminants Generated By People & From Outdoors	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP*	Steady State (lb/ft3) Using the IAQ Method	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
		(Prescribed OA) Plasma Off	(Reduced OA) Plasma On				
Acetaldehyde	100.0	2.6298E-09	1.1297E-09	Yes	1.293E-08	50%	OSHA
Acetone	250.0	1.4091E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5590E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6125E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4544E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7598E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1662E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1945E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.5990E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.					

FC-4 VENTILATION


Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #5	Educational Facilities	Lecture Classroom	369.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP

Zone Height (feet)	8.5	Air Changes Per Hour	7.7	VRP OA CFM per person	11.7
Desired Outside Air (Vo) IAQP (CF)	60	Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Supply Air (Vs) (CFM)	400	Outside Air Per IAQ	60 CFM		
Return Air (Vr)	340	Outside Air Savings	80 CFM	Winter Heating Savings	
Recirc. Flow Factor (R)	0.85	OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
Ventilation Effectiveness (Ez)	0.8	OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Level of Physical Activity	Sedentary	Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Filter Location	B	Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
HVAC Flow Type	Constant	OA MBH Saved Summer*	5.9		
Outdoor Air Flow Type	Constant	OA Tons Saved Summer*	0.5		



Indoor Contaminants	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/ft3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.6283E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4076E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5488E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6125E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4594E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7598E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1662E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1945E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.5950E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.7709E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	1.6728E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1072E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA

Indoor Contaminants	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/ft3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.6283E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4091E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5590E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6125E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4594E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7598E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1662E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1945E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.5950E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.7709E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	1.6728E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1072E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



Building materials and furnishings assumed to have no VOCs and off-gassing is complete
 All yellow shaded boxes require user input or review


Is IAQ acceptable at reduced outside air levels? **Yes**

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

FC-4 VENTILATION


Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #7	Educational Facilities	Lecture Classroom	371.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP

Zone Height (feet)	8.5	Air Changes Per Hour	7.6	VRP OA CFM per person	11.7
Desired Outside Air (Vo) IAQP (CF)	60	Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Supply Air (Vs) (CFM)	400	Outside Air Per IAQ	60 CFM		
Return Air (Vr)	340	Outside Air Savings	80 CFM	Winter Heating Savings	
Recirc. Flow Factor (R)	0.85	OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
Ventilation Effectiveness (Ez)	0.8	OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Level of Physical Activity	Sedentary	Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Filter Location	B	Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
HVAC Flow Type	Constant	OA MBH Saved Summer*	5.9		
Outdoor Air Flow Type	Constant	OA Tons Saved Summer*	0.5		



Indoor Contaminants	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/ft3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.6283E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4076E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5488E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6108E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4496E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7595E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1659E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1932E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.5858E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.7605E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	2.4381E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1029E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA

Indoor Contaminants	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/ft3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.6283E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4091E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5590E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6125E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4594E-07	6.4838E-07	Yes	8.8396E-06	50%	NIOSH
Carbon dioxide**	5000	4.7598E-05	5.1129E-05	Yes	2.4692E-05	0%	NIOSH
Chloroform	2.0	2.1662E-07	4.7541E-08	Yes	2.7342E-07	50%	NIOSH
Dioxane	100.0	1.9360E-08	2.8402E-09	Yes	0.0000E+00	50%	OSHA
Hydrogen Sulfide	10.0	1.2491E-10	1.8324E-11	Yes	0.0000E+00	50%	NIOSH
Methane	NA	6.2453E-11	6.2453E-11	Yes	0.0000E+00	0%	NA
Methanol	200.0	1.1945E-08	2.7907E-08	Yes	1.1163E-07	0%	NIOSH
Methylene Chloride	25.0	8.5950E-07	5.8881E-07	Yes	8.0262E-06	50%	OSHA
Propane	1000.0	1.2491E-09	1.2491E-09	Yes	0.0000E+00	0%	NIOSH
Tetrachloroethane	5.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA
Tetrachloroethylene	100.0	9.7709E-07	6.6877E-07	Yes	9.1140E-06	50%	OSHA
Toluene	100.0	1.6728E-09	1.6728E-09	Yes	2.2806E-08	50%	NIOSH
1,1,1 - Trichloroethane	350.0	4.1072E-05	2.8116E-05	Yes	3.8318E-04	50%	NIOSH
Xylene	100.0	0.0000E+00	0.0000E+00	Yes	0.0000E+00	50%	OSHA



Building materials and furnishings assumed to have no VOCs and off-gassing is complete
 All yellow shaded boxes require user input or review


Is IAQ acceptable at reduced outside air levels? **Yes**

* IMC 2006 & later allows for ASHRAE 62 IAQP through the engineered exception found in Section 403.2

FC-4 VENTILATION

Zone Tag	Facility Type	Zone Use	Zone Floor Area (square ft) Az	Zone Max Occupancy Pz	Table 6.1 OA per Occupant Rp	Table 6.1 cfm/ft2 Ra	Pz * Rp	Az * Ra	Table 6.2 Ventilation Effectiveness Ez	Outdoor Air to Zone (CFM) with Ez correction (Vbz/Ez)
CLASSROOM #6	Educational Facilities	Lecture Classroom	369.0	12.0	7.5	0.06	90	22	0.8	140 OA required per VRP

Zone Height (feet)	8.5	Air Changes Per Hour	7.7	VRP OA CFM per person	11.7
Desired Outside Air (Vo) IAQP (CF)	60	Outside Air Per VRP	140 CFM	IAQ OA CFM per person	5.0
Supply Air (Vs) (CFM)	400	Outside Air Per IAQ	60 CFM		
Return Air (Vr)	340	Outside Air Savings	80 CFM	Winter Heating Savings	
Recirc. Flow Factor (R)	0.85	OA Summer Drybulb	95.0	OA Winter Design DB (F)	10
Ventilation Effectiveness (Ez)	0.8	OA Summer Wetbulb	76.0	Supply Air DB Setpoint (F)	85
Level of Physical Activity	Sedentary	Coil Leaving Air Drybulb (F)	55.0	MBH Saved Winter	6.5
Filter Location	B	Coil Leaving Air Wetbulb (F)	55.0	KW Saved Winter	1.9
HVAC Flow Type	Constant	OA MBH Saved Summer*	5.9		
Outdoor Air Flow Type	Constant	OA Tons Saved Summer*	0.5		



Indoor Contaminants	Maximum Threshold Value Based on OSHA or NIOSH (PPM)	Steady State (lb/ft3) Using the VRP* (Prescribed OA) Plasma Off	Steady State (lb/ft3) Using the IAQ Method (Reduced OA) Plasma On	Is Steady State Level Acceptable at Reduced OA Levels?	Contaminant Generation Rate lb/person/min	Filtration Effectiveness	Cognizant Authority***
Acetaldehyde	100.0	2.6283E-09	1.1297E-09	Yes	1.2903E-08	50%	OSHA
Acetone	250.0	1.4091E-08	9.5579E-09	Yes	1.2993E-07	50%	NIOSH
Ammonia	25.00	9.5590E-07	6.5519E-07	Yes	8.9322E-06	50%	NIOSH
Benzene	1.0	1.6125E-08	1.0784E-08	Yes	1.4602E-07	50%	OSHA
2- Butanone (MEK)	200.0	9.4594E-07	6.4838E-07	Yes	8.8396E-0		