

# **SWEETGREEN NJ147**

---

Tuesday, June 14, 2022

7 Remarks Identified



**STOREFRONT**




**RTU-1**  
Kitchen




**RTU-2**  
DINING



**TX1**  
Restrooms



**GX-1**  
Kitchen exhaust



### **RTU1/2 NOTE**

OCC was not wired so temporary jumper is installed.  
Recommend connecting OCC to proper terminal on the thermostat



### **RTU1-2 FILTERS ARE HEAVILY LOADED**

Need 4 per unit 20X25X2

8 Total