



Comfort. Under control.

**05-09 CHICK-FIL-A #01991 - SMYRNA, TN (SMYRNA TN FSU) REINVEST**

**Project Issue Information**

**Issue Name :** AC-1 no turning Vanes  
**Description :** See M4.1 section 4 AC-1 Duct drop does not have turning vanes installed. Or the 45 degree transition  
**Created By :** National TAB **Assigned To :** National TAB - Tyler Youells  
**Status :** Open  
**Originated Date :** 05/10/2022 - Tyler Youells - National TAB

**Project Issue File Details**



**FuseIT2eae2bbc220c475987  
78aee4a94c25d4.jpeg**