



2999 Olympus-Cypress Waters

Project RFI Information

Issue Name :	Exhaust Fan Submittal Review	Organization :	Exhaust Fan Submittal Review
Status :	Open	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Scott Springer
Open :	05/05/2021	Description:	Fan Submittals and drawing schedule for EPF-11 -1, 2 and 3 list a design cfm of 20,000 for each. The riser diagram for each shaft shows EPF 11-1 grille total of 30,000 cfm, EPF 11-2 grille total of 20,000 cfm and EPF 11-3 grille total of 10,000 cfm.

Project RFI Response Details

- **05/05/2021** **National TAB - Scott Springer**
 - All fans should have VFD or volume control device (speed controller) per schedule