



Comfort. Under control.

Project Issue Information

**Project Name :** 2999 Olympus-Cypress Waters    **Organization :** National TAB  
**Issue Name :** Test Issue 042021                      **Assigned To :** National TAB - Brian Irwin  
**Status :** Open    **Created :** JOE HERTENSTEIN  
**Shared To :**    **Open :** 04/20/2021 - JOE HERTENSTEIN - National TAB  
**Description:** No turning vanes in installed in main supply duct going to VAV's on 1st floor. Need to discuss with Mechanical Contractors.

Project Issue File Details

- 1. [Open](#) 2999cw\_issue1.pdf

Project Issue Response Details

- **04/20/2021 National TAB - Brian Irwin**
  - MC will install this afternoon

---

- **04/20/2021 National TAB - JOE HERTENSTEIN**
  - Please see attached picture to provide to Mechanical
    - 1. [Open](#) PHI\_Indoor\_AHU\_24v.jpg

---

- **04/20/2021 National TAB - Brian Irwin**
  - please provide picture