



Shake Shack (Lee's Summit) - Commissioning

Project Issue Information

Issue Name : LUTRON - DIM WIRE MISSING
Description : Dim wire not landed on: Kitchen work area (4) & Utility Room - Work Room (3)
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Originated Date : 11/11/2021 - Dan Hertenstein - National TAB