



## Shake Shack (Lee's Summit) - Commissioning

### Project Issue Information

**Issue Name :** LUTRON - INTERIOR MENU BOARD NOT INSTALLED

**Description :** Interior menu board not installed - could not be visually verified for correct operation during Cx process

**Created By :** National TAB **Assigned To :** National TAB - Dan Hertenstein

**Status :** Open

**Originated Date :** 11/11/2021 - Dan Hertenstein - National TAB