



Shake Shack (Lee's Summit) - Commissioning

Project Issue Information

Issue Name :	exhaust fan hinge - electrical clearance	Organization :	National TAB
Status :	Open	Assigned To :	National TAB - Dan Hertenstein
Shared To :		Created :	Dan Hertenstein
Open :	09/14/2021 - Dan Hertenstein - National TAB	Description:	Electrical box positioned at the rear end of exhaust fan. Installer needs to ensure the hinges provide adequate clearance so that's the electrical box does not wedge against the roof curb.

Project Issue File Details

1. [Open](#) E-box_mounting.jpg
2. [Open](#) Eboxdistancetocurb.jpg
3. [Open](#) Top-view.jpg
4. [Open](#) Frontdrainview.jpg