



10 EXISTING EXHAUST FAN TO REMAIN (FIELD VERIFY MIN CAPACITY OF 70 CFM) WITH 6" DIA. EXHAUST DUCT. VERIFY EXHAUST FAN IS WIRED TO OPERATE WITH LIGHT CONTROL. INSPECT AND PROVIDE GENERAL MAINTENANCE FOR FAN, DUCT, AND TERMINATION. REPAIR IF REQUIRED.

11 PROVIDE NEW JANITOR'S CLOSET EXHAUST FAN: BROAN MODEL #AE80 SERIES VENTILATION FAN MOUNTED IN SIDEWALL @ 3'-6" A.F.F., 30 CFM @ 0.39 SP, 120/1/60, 0.3 AMPS(26.9 W), 1.12 EFFICACY, 3" DIA. EXHAUST DUCT. COORDINATE WITH ELECTRICAL CONTRACTOR AND G.C. EXHAUST FAN TO BE WIRED FOR CONTINUOUS OPERATION DURING OCCUPIED HOURS. ROUTE TO EXISTING TOILET EXHAUST OUTLET DUCT, SEE NOTE 10.

1 MECHANICAL PLAN  
SCALE: 3/16" = 1'-0"

