


**02 HVAC DUCTWORK DETAIL**  
SCALE: NOT TO SCALE



**01 TYPICAL ROOF-TOP UNIT DETAIL**  
SCALE: NOT TO SCALE

- NOTES:**
1. SET ROOF CURB ON STRUCTURAL STEEL - SHIM DEAD LEVEL. SECURE ROOF CURB TO METAL DECK AND A/C UNIT TO ROOF CURB.
  2. TRANSITION TO CONNECTION SIZES IN DUCT RISE, REFER TO PLANS FOR SIZES.
  3. 1" ACOUSTIC LINING IN SUPPLY AND RETURN DUCTS FROM FAN DISCHARGE TO POINT INDICATED ON MECHANICAL DRAWINGS (10'-0" MIN.). DUCT SIZES INDICATED ON PLAN ARE INTERIOR. PAINT EXPOSED DUCTWORK TO MATCH CEILING. REFER TO ARCHITECTURAL DRAWINGS FOR COLOR SCHEME.
  4. THE MECHANICAL ENGINEER DOES NOT PROVIDE STRUCTURAL ENGINEERING SERVICES, AND RECOMMENDS TO THE OWNER THAT ANY ADDITIONS LOAD PLACED ON THE ROOF BE APPROVED BY A STRUCTURAL ENGINEER.
  5. INSULATED ROOF CURB.
  6. FLEXIBLE CONNECTION - TYPICAL.

HVAC Load Calc - Fitness Center		4/22/2025	Bodybar - Centerville, OH	25.116
Cooling Load Analysis:	ASHRAE DESIGN:	DB =	90.3	
Sensible Heat:	Basis of Design: Dayton, OH	WB =	73.6	
	Design Indoor Temp		68 F	
H_sensible, O.A. = 1.08 * cfm * delta T	H_sensible_OA =	14932.08 dT =	22.3	
H_sensible, lighting = watts * 3.413	H_sens_lgtg =	7000.063		
H_sensible, people = 305 * # people	H_sens_ppl =	5490		
H_sensible, walls = A*u*dT	H_sens_wall =	2584.615 (dT = 40F)		
H_sensible, floor = A*u*dT	H_sens_floor =	2051 (dT = 1F)		
H_sensible, roof = A*u*dT	H_sens_roof =	5397.368 (dT=50F)		
H_sensible, window conductance = A_glass*U*dT	H_sens_glass =	7260		
H_sensible, window transmittance = A_glass*SHGC*Et	H_sens_solar gain =	20064		
H_latent, O.A. = 0.68 * q*delta w_grains	H_latent_OA =	10750.8		
H_latent, people = 545 * # people	H_latent_ppl =	9810		
Lighting Load (watts)	2051 (from Comcheck/ T-24 / FlaCom)			
Occupant Load	18 (Auto Populate - from ASHRAE calculation)			
Grains O.A. =	97.7 <----- update per site			
Grains I.A. =	72.2 (72.2 is for saturated air at 58F)			
Outside Air, Ventilation =	620 (Auto Populate - from ASHRAE calculation)			
Roof / Floor Area =	2051 (Auto Populate - from ASHRAE calculation)			
Wall Height - Average	20 <----- update per site			
Perimeter (unconditioned)	42 <----- update per site			
Wall Area =	840			
Window Length =	22 <----- update per site			
Window Height =	10 <----- update per site			
Window Area =	220			
Shading Factor =	0.4 (0 = none, 1.0 = fully shaded)			
R-value Walls = (R_net) =	13 Existing Wall			
U-value Walls =	0.076923 Average Wall			
R-floor = (R_net) =	1			
U-floor =	1			
R-roof = (R_net) =	19 Existing Roof			
U-roof =	0.052632 Average Roof			
U-glass =	1.1 (use 1.1 for 1-pane glass; use 0.55 for double pane glass, energy star windows can be 0.55 max.)			
SHGC =	0.76 (use 0.76 for ordinary windows)			
Et = incident solar radiation	200 (assume peak daily, btu/hr p.s.f. Solar constant is 442 BTUH/hr at top of atm, 317 at sfc.)			
<b>Total Cooling Load:</b>			<b>85339.93</b>	
<b>Space Load - Tonnage Required</b>			<b>7.111661 tons</b>	
<b>Safety Factor (10%)</b>			<b>93873.92</b>	
<b>Space Load - Recommended Tonnage</b>			<b>7.822827 tons</b>	

HVAC Load Calc - Fitness Center		4/22/2025	Bodybar - Centerville, OH
Heating Load Analysis:	ASHRAE DESIGN:	DB =	0.6
Sensible Heat Loss:	Design Temp		70
H_sensible, O.A. = 1.08 * cfm * delta T	H_sensible_OA =	-46470.2 (dT = 57F)	
H_sensible, O.A. = 1.08 * cfm * delta T	H_sensible_OA =	-22485.6 (dT = 57F)	
H_sensible, walls = A*u*dT	H_sens_wall =	-4484.31 (dT = 57F)	
H_sensible, floor = A*u*dT	H_sens_floor =	6153 (dT = 3F)	
H_sensible, roof = A*u*dT	H_sens_roof =	-7491.55 (dT = 57F)	
H_sensible, window conductance = A_glass*U*dT	H_sens_glass =	-16794.8	
Outside Air, ventilation =	620 (from ASHRAE calculation)		
Outside Air, intrusion =	300 (from open doors on windy winter days)		
Outside Air =	920		
Roof / Floor Area =	2051 <----- update per site		
Wall Height - Average	20 <----- update per site		
Perimeter (unconditioned)	42 <----- update per site		
Wall Area =	840		
Window length =	22 <----- update per site		
Window height =	10 <----- update per site		
Window Area =	220		
Shading Factor =	0.4 (0 = none, 1.0 = fully shaded)		
R-value Walls = (R_net) =	13 New Wall		
U-value Walls =	0.076923077 Average Wall		
R-floor = (R_net) =	1		
U-floor =	1		
R-roof = (R_net) =	19 New Roof		
U-roof =	0.052631579 Average Roof		
U-glass =	1.1 (use 1.1 for 1-pane glass; use 0.55 for double pane glass, energy star windows can be 0.55 max.)		
<b>Total Heating Load:</b>			<b>-91573.5</b>
<b>Safety Factor (25%)</b>			<b>-114467 MBH</b>
<b>Space Load - Tonnage Required</b>			<b>33.53849 KW</b>
<b>Mechanical contractor shall verify Existing HVAC Equipment meets the above minimum requirement. Provide 180 mbh heat for quick heat-up in the mornings.</b>			

MEP DRAWINGS ARE NOT STRUCTURAL ENGINEERING DRAWINGS. VERIFY WITH STRUCTURAL DESIGN, WHICH TAKES PRECEDENCE OVER THE M.E.P. SHEETS IN TERMS OF MOUNTING AND PLACEMENT.

VERIFY WITH STRUCTURAL DESIGN, WHICH TAKES PRECEDENCE OVER THE M.E.P. SHEETS IN TERMS OF MOUNTING AND PLACEMENT.

UNIT	SUPPLY AIR	RETURN AIR	OUTSIDE AIR	EXHAUST	PRESSURE	AREA SERVED
RTU-1	2,000	1,600	400	--	+400	STUDIO
RTU-2	1,200	980	220	--	+220	LOBBY
EF-1	--	--	--	80	-80	RR
EF-2	--	--	--	80	-80	RR
EF-3	--	--	--	80	-80	UTILITY
TOTAL	3,200	2,580	620	240	+370	--

HVAC SYSTEMS SHALL BE PROVIDED WITH BAROMETRIC RELIEF.

2024 OMC Ventilation Comparison		4/22/2025										Bodybar - Centerville, OH				
Zone Identification		Standard Case: 2024 Ohio Mechanical Code - Table 403.3.1.1 Min. Ventilation Rates										Design Case				
Zone	Occupancy Category	Area (sf)	People Outdoor (Rp)	Area outdoor (Ra)	Expected Occupant Density (#/1000 sf)	Zone Population (Pz)	Breathing Zone Air Flow (CFM)	Zone Distribution Effectiveness (Ez)	Zone Outdoor Air Flow (Voz)	Factor Zp=	System Ventilation Efficiency (Ev)	Outdoor Air Intake Flow (CFM)	Total Outdoor provided by HVAC equip. (CFM)	Total Airflow provided by HVAC equip. (CFM)	Design % by which Outside Air Design Flow Exceeds Standard	
Studio (Health Club/Aerobics Room)	Sports & Amusement	1,402	20	0.06	40	16	404.1	0.8	505.2	1	505.2	1	505.2	510	2000	1.0%
Restroom	Restroom	106	0	0.06	0	0	6.4	0.8	8.0	1	8.0	1	8.0	10	100	25.8%
Utility (Storage)	Retail Stores, Sales..	63	0	0.12	0	0	7.6	0.8	9.5	1	9.5	1	9.5	10	50	5.8%
Retail Lobby (Sales)	Retail Stores, Sales..	420	7.5	0.12	15	1	57.9	0.8	72.4	1	72.4	1	72.4	75	950	3.6%
Office (Office Spaces)	Offices	60	5	0.06	5	1	8.6	0.8	10.8	1	10.8	1	10.8	15	100	39.5%
<b>Total</b>		<b>2,051</b>				<b>18</b>						<b>606</b>	<b>620</b>	<b>3200</b>		

$V_{oz} = R_p * P_z + R_a * A_z$   
 $V_{pz} = \text{Total airflow provided by the HVAC equipment (Outdoor + Recirculated)}$   
 $V_{oz} = V_{oz} / E_z$   
 $Z_p = V_{oz} / V_{pz}$


\*Occupancy is counted by # of stretch boards plus instructor of class, which is the actual peak anticipated occupancy for this area  
 \*Terminology has been adopted from IMC 2021, refer to section 403 of that code for additional terminology, equations, etc.



PLANS, MAPS, SPECIFICATIONS, STUDIES AND REPORTS NOT CONTAINING A SEAL IMPRINT ACCOMPANIED BY AN ORIGINAL SIGNATURE BY THE LICENSED PROFESSIONAL MAY HAVE BEEN FRAUDULENTLY ALTERED AND SHALL NOT BE CONSIDERED AN ORIGINAL COPY. ALL INFORMATION SHOULD BE DISREGARDED UNLESS VERIFIED BY THE PROFESSIONAL WHOSE SIGNATURE APPEARS BELOW. COPYRIGHT PROTECTED © 2025

**ISSUE RECORD**  
DATE DESCRIPTION

**REVISION RECORD**



**REMODEL**

**PROJECT NAME**

**BODYBAR**

**THE VILLAGE AT CORNERSTONE SHOPPES IV**

**CENTERVILLE OHIO**

**5268 CORNERSTONE NORTH BLVD CENTERVILLE, OH 45440**



**PROJECT NUMBER**  
25-0030

**MECHANICAL DETAILS**

**SHEET NUMBER**

**M2.0**







