



RELOCATE EXISTING REMOTE TEMP SENSOR FOR ASK TO LOCATION SHOWN AT 8' NECK. ROUTE WIRING TO MECHANICAL LOCATED IN C-14-500/100 PANEL.

AIR CURTAIN REMOTE WALL SWITCHES BY MECHANICAL. REFER TO AIR DOOR SCHEDULE AND AIR CURTAIN WIRING DIAGRAM FOR FURTHER INFORMATION. COORDINATE EXACT LOCATION FOR SWITCHES WITH KITCHEN EQUIPMENT AND PLANS.

NEW AIR CURTAIN, ACH#1, INSTALLED IN CEILING GRID CENTERED ON THE DOOR AT 1' OFF THE EXTERIOR WALL. MECHANICAL CONTRACTOR SHALL ADJUST WALL DEFLECTORS TOWARD AIR DIVERTER BOX.

F-16-425
TRANSFER GRILLES, NO
BALANCING DAMPER.

RISIN MODEL, MD8325
OR EQUIVALENT MANUAL
VOLUME DAMPER WITH
LOCKING QUADRANT
HANDLE, TYPICAL OF 5.