

Issue List

- Faded RTU Label
- RTU-1 Duct Leakage



03-02-26 QT #0739 TUCKER, GA

Project Issue Information

Issue Name : Faded RTU Label
Description : RTU-1 label is faded and is not readable. All data inputted is directly from the motor.
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Priority : InfoOnly **Asset Tag :**
Originated Date : 03/04/2026 - Anthony Taylor - National TAB



03-02-26 QT #0739 TUCKER, GA

Project Issue Information

Issue Name : RTU-1 Duct Leakage
Description : At the supply drop of RTU-1 there is a duct leakage causing the unit to be unable to be balanced.
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 03/04/2026 - Anthony Taylor - National TAB

Project Issue File Details



03/04/2026