

Wills Sports Bar

CheckList Information

Name :	Quality Site Verification	Status :	NotSubmitted
Assigned Organization :	Air Solutions, Inc	Asset :	
Requesting Organization :	Air Solutions, Inc		

CheckList Item Details

BELOW IS AN INSTALLATION CHECKLIST DONE TOWARDS THE END OF JOB. CLICK ON LINKS BELOW TO VIEW PICTURES IF VISUAL REQUIRED.

DATE OF WALK-THRU

Hood System

Hoods level & hanging height off floor(front leading edge)?

Hood accessories installed (End Panels, Filters, etc)?

Remote pull station & gas valve installed & connected to fire system? Field piping completed if wall mounted?

Review Wiring Diagram, Verify wire connections

Additional Hood requirements/comments:

Ductwork

Grease Duct installed & cleanouts if applicable?

Fire wrap installed if required for grease duct?

Supply ductwork to hoods & fans completed

Additional ductwork requirements/comments:

Exhaust Fans

Hinge Kit & Fan Grease Cup installed

Electric does not impede the exhaust fan from being hinged back for cleaning

Vibration isolators installed properly for fans if applicable?

Make-Up-Air Systems

Gas piping installed w/shutoff & regulator (7"-14")

If MUA has Cooling option, is electric supplied?

Fan(s) additional requirements/Comments: