



### AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	400	380	400	380				
RTU-2	SALES	700	751	700	751				
RTU-3	BOH/KITCHEN	1350	1350	0	0				
EF-1	RESTROOM					625	0	625	0
EF-2	HOOD					1350	1385	0	0
EF-3	COMBI-OVEN					150	0	150	0
<b>TOTALS</b>		<b>2450</b>	<b>2481</b>	<b>1100</b>	<b>1131</b>	<b>2125</b>	<b>1385</b>	<b>775</b>	<b>0</b>

### HOODS ON

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2450	2481
TOTAL EXHAUST	2125	1385
<b>NET AIRFLOW</b>	<b>325</b>	<b>1096</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.007"
SIDE	N/A
REAR	N/A
<b>AVERAGE</b>	<b>0.007"</b>

### HOODS OFF

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	1100	1131
TOTAL EXHAUST	775	0
<b>NET AIRFLOW</b>	<b>325</b>	<b>1131</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.01"
SIDE	N/A
REAR	N/A
<b>AVERAGE</b>	<b>0.01"</b>

NOTES: