

MOUNT AC#1 MAIN TRUNK LINE AS TIGHT TO STRUCTURE AS POSSIBLE.

FROM OUTSIDE FACE OF EXTERIOR WALL FRAMING

MOUNT AIR DOOR IN CEILING, CENTERED ON DOOR OPENING. AT 18" OFF WALL. PROVIDE WITH FACTORY MICROSWITCH CONTROL.

TO AC#3 SENSOR#2, SEE ZIM-501.

COORD. EXACT LOCATION OF SENSORS WITH SIGNAGE.

TO AC#3 SENSOR#3, SEE ZIM-501.

TO AC#3 SENSOR#4, SEE ZIM-501.

