



National TAB

Project: Connor Group Office
Address: 10510 Springboro Pike Miamisburg, OH

Asset: CH2

UNIT DATA		
Unit Description	AIR-COOLED SCROLL	
Manufacturer	TRANE	
Model Number	CGAM070F2	
Serial Number	U22B01127	
EVAPORATOR DATA	Design	Actual
Flow GPM	139.9	137.4
Pressure Drop	16.1 ft	15.4 ft