



08-11-25 CAVA BURLINGTON, MA

CheckList Information

Name : PLAN REVIEW **Status :** Not Completed

Assigned Organization : National TAB **Asset :**

Requesting Organization : National TAB

Created Date : 07/28/2025 - Natasha Louw - National TAB

CheckList Item Details

Asset Requirements

We have the latest set of construction drawings and are not working off the Bid or Permit Set:	No
Comment:	
Diffuser totals equal the scheduled airflow of each piece of equipment	Yes
Comment:	
Scheduled Hood airflow match scheduled EF and MAU airflows	Yes
Comment:	
Files to Upload	
A PDF summary is uploaded and matches the equipment/scope of the project	Yes
Comment:	
Balance schedule is uploaded?	Yes
Comment:	
Required account checklists are created	Yes
Comment:	
Mechanical drawings are uploaded	Yes
Comment:	

Comment:

If job is a Revive, Pre-design, or Remodel. Check if we have an old report on sharepoint or the old FaciliBuild and upload to files section.

N/A

Comment:

GRD Layout is uploaded

Yes

Comment:

Jurisdiction Requirements

Is job in Orlando, FL metro area or Phoenix metro area? If yes, a smoke detector checklist needs to be created for each RTU or AHU

No

Comment:

Is job in Broward County, FL? If so, is Broward County on the permit (Ask the GC)? If Broward County is on the permit, then we CANNOT perform the balance.

No

Comment:

Notes/Comments :

NET AIRFLOW -291

Date :07/28/2025