

MECHANICAL PLAN SCALE: 1/8" = 1'-0"

GENERAL NOTES:

- 1. ROOMS OR AREAS SHOWN SHADED ON THIS PLAN, WITH THE FOLLOWING SHADING TYPE [ ] ARE DEDICATED FOR A SPECIFIC USE... 2. THESE DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL EXTENT OF THE WORK... 3. THE CONTRACTOR SHALL PROVIDE ALL MISCELLANEOUS SUPPORTING STEEL, ETC. FOR THE PROPER INSTALLATION OF ALL MECHANICAL SYSTEMS...

CODED NOTES:

- 1. EXHAUST DUCT UP, CONNECT TO EXHAUST FAN AND TRANSITION AS REQUIRED. 2. MOUNT THERMOSTAT ON LIGHTS/TAP PANEL. 3. UNDERCUT DOOR 1" FOR AIRFLOW. 4. PROVIDE 1/2" X 1/2" WIRE SCREEN OVER RETURN AIR DUCT OPENING, TYPICAL FOR ALL RTUs...

- PROVIDE TYPICAL HURRICANE ANCHOR & UNIT SUPPORT. CONTRACTOR SHALL FIELD VERIFY ALL EXISTING FIELD CONDITIONS PRIOR TO BEGINNING WORK. HOLD ALL NEW DUCTWORK AS TIGHT TO STRUCTURE ABOVE AS POSSIBLE. MAINTAIN MINIMUM 12'-0" FROM ALL BUILDING INTAKES AND EXHAUST. COORDINATE ALL THERMOSTAT REQUIREMENTS WITH LIGHTS/TAP.



ARCHITECT HOWELL BERANGER CASTELLI ARCHITECTS, P.C. 122 West 27th Street, 4th Floor New York, New York 10001 212-647-0011 FAX: 647-0022

M E P ENGINEERING CONSULTANT Thorson Baker + Associates 3030 W Shrewsbury Rd. Richmond, OH 44286 613-679-8200 FAX: 623-6713

STRUCTURAL ENGINEERING CONSULTANT Thorson Baker + Associates 3030 W Shrewsbury Rd. Richmond, OH 44286 613-679-8200 FAX: 623-6713


Barnes & Noble Booksellers University Town Center Sarasota, FL

Tenant Fit Out

Revision Log table with columns: Date, Description, No.

These plans are an instrument of service and the property of the Architect. Infringements will be prosecuted.

General Contractor to verify all conditions and dimensions at the premises. Discrepancies shall be reported to the Architect prior to the commencement of any work.



Project Number: 18087 Drawing Description: MECHANICAL HVAC PLAN

Drawing Number: M-101



