

AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HVAC SUPPLY		HVAC RETURN		HVAC OUTDOOR		OA %		HOOD MAKE-UP		HOOD EXHAUST		GENERAL EXH.	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU-1			2235	0	2235		0	#DIV/0!	0.0%						
RTU-2			21450	0	21450		0	#DIV/0!	0.0%						
RTU-3			1942	0	1447		495	#DIV/0!	25.5%						
MUA-1											0				
EF-1												3021			
EF-2												0			
EF-3															0
EF-4															0
EF-5															266
EF-6															0
EF-7															0
EF-8															0
EF-9															0
EF-10															27
EF-11															46
TOTALS		0	25627	0	25132	0	495			0	0	0	3021	0	339

NET BUILDING AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	0	495
TOTAL EXHAUST	0	3360
NET AIRFLOW	0	-2865

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS (IN. H2O)
FRONT	NA
SIDE	NA
REAR	NA
AVERAGE	#DIV/0!

FINAL CHECKS

ACTUAL NET AIRFLOW COINCIDES WITH DESIGN: !

MEASURED PRESSURES COINCIDES WITH ACTUAL NET AIRFLOW:

PRESSURE FALLS WITHIN IMC TOLERANCE OF +/-0.02" W.C.

NOTES: