

**Report By:**

National TAB  
1329 E. KEMPER ROAD  
SUITE 4210  
CINCINNATI, OH 45246

**NATIONAL**

**TAB**

Comfort. Under control.

**Report: DEFICIENCY LIST**  
**Function: Test, Adjust, & Balance**  
**Date: 6/3/2022**

**PROJECT**  
**05-30 CULVERS - WILDWOOD, FL**

5327 SUNDANCE TRAIL

WILDWOOD, FL

**Client**

Accurex

400 Ross Ave

Schofield, WI 54476



# National TAB

Project: 05-30 CULVERS - WILDWOOD, FL

## Table Of Contents

Section	Page #
Issue Data	3





Comfort. Under control.

## 05-30 CULVERS - WILDWOOD, FL

### Project Issue Information

**Issue Name :** ALL RTU CONSTRUCTION FILTERS INSTALLED

**Description :** ALL ROOFTOP UNITS HAVE BLUE CONSTRUCTION FILTERS INSTALLED. NTAB RECOMMENDS A MERV 8 FILTER TO BE INSTALLED FOR IMPROVED FILTRATION.

**Created By :** National TAB

**Assigned To :** National TAB - Will Turnbough

**Status :** Open

**Originated Date :** 06/01/2022 - Stephen Tassinaro - National TAB

#### Project Issue Response Details

- **06/03/2022** National TAB - Stephen Tassinaro



FuseITf7b2c4a86c9a468abe9  
4797e6ffce5b5.jpeg

