

Report By:

National TAB  
1329 E. KEMPER ROAD  
SUITE 4210  
CINCINNATI, OH 45246



**Report: Issues**  
**Function: Test, Adjust, & Balance**  
**Date: 08/20/2024**

# PROJECT

**08-19-24 JERSTAD-AGERHOLM MIDDLE  
SCHOOL - RACINE, WI**

3535 LASALLE ST

RACINE, WI 53402

Client

Accurex  
PO Box 410  
Schofield, WI 54476

# National TAB

Project: 08-19-24 JERSTAD-AGERHOLM MIDDLE SCHOOL - RACINE, WI

## Table Of Contents

Section	Page #
Issue Data	3

## Issue List

- Exhaust Fans Not Powered / Controls Not Run
- INFO ONLY: KH-2: Exhaust Fan Serves Multiple Areas
- KH-1: User Interface Missing / Not Found




**08-19-24 JERSTAD-AGERHOLM MIDDLE SCHOOL - RACINE, WI**

**Project Issue Information**

**Issue Name :** Exhaust Fans Not Powered / Controls Not Run  
**Description :** Neither Exhaust Hood Fan was powered at time of certification. Unable to complete TAB/Startup. Additionally, Controls have not been landed in control panel, and user interface could not be located.  
**Created By :** National TAB                      **Assigned To :** National TAB - Michael McDonnell  
**Status :** Open  
**Priority :** High                                      **Asset Tag :**  
**Originated Date :** 08/20/2024 - Michael McDonnell - National TAB

Project Issue File Details



08/20/2024




08/20/2024



08/20/2024

Project Issue Response Details

- **08/20/2024 National TAB - Michael McDonnell**
  - KH-1 to be controlled by VFD by others. VFD has not yet been powered/started up.



08/20/2024



**08-19-24 JERSTAD-AGERHOLM MIDDLE SCHOOL - RACINE, WI**

**Project Issue Information**

**Issue Name :** INFO ONLY: KH-2: Exhaust Fan Serves Multiple Areas  
**Description :** Exhaust Fan ducted to KH-2 is also ducted to additional building space. Unsure what it serves.  
**Created By :** National TAB                      **Assigned To :** National TAB - Michael McDonnell  
**Status :** Open  
**Priority :** InfoOnly                                      **Asset Tag :**  
**Originated Date :** 08/20/2024 - Michael McDonnell - National TAB

Project Issue File Details



08/20/2024



08/20/2024



**08-19-24 JERSTAD-AGERHOLM MIDDLE SCHOOL - RACINE, WI**


**Project Issue Information**

**Issue Name :** KH-1: User Interface Missing / Not Found  
**Description :** User interface for Hood controls could not be located.  
**Created By :** National TAB                      **Assigned To :** National TAB - Michael McDonnell  
**Status :** Open  
**Priority :** High                                      **Asset Tag :**  
**Originated Date :** 08/20/2024 - Michael McDonnell - National TAB

Project Issue File Details



08/20/2024



08/20/2024