## 07-31-23 SHAKE SHACK #1377 - LYNWOOD, WA (ALDERWOOD MALL) TAB, IAQ

### Project Issue Information

**Issue Name :** REF-1 airflow

**Description :** REF-1 (Relief Fan) is 1505 CFM out of 2600 CFM design with the fan speed maximized. There is flex ductwork used at the inlet of the fan which appears to be restricting the performance. Fan only runs when the RTU's are economizing. Low airflow may not be an issue. Recommend consulting with the MEP Engineer.

**Created By :** National TAB **Assigned To :** National TAB - Will Turnbough

**Status :** Pending

**Originated Date :** 10/12/2023 - Will Turnbough - National TAB