



Comfort. Under control.

07-11 CULVERS - ELLISVILLE, MO

**Project Issue Information**

**Issue Name :** RTU1 dining room no Economizer  
**Description :** Economizer is not yet here for RTU1. GC is still waiting on ETA for Economizer  
**Created By :** National TAB **Assigned To :** National TAB - Will Turnbough  
**Status :** Pending  
**Originated Date :** 07/11/2022 - Jacob Davidson - National TAB

Project Issue File Details



FuseIT021a0aabe82840.jpeg

Project Issue Response Details

- 07/13/2022 National TAB - Jacob Davidson
  - Economizer has been installed, but hood and OA filters have not arrived. GC opened a makeshift hood that will allow us to set OA on the unit



FuseIT9c481f94bb6144bd8949bbfdb6c03c01.jpg