


FIRST FLOOR HVAC - WING B
SCALE: 1/8" = 1'-0"

GENERAL NOTES:


1. REFER TO PART PLANS ON SHEET M3.1 FOR ADDITIONAL INFORMATION.
2. REFER TO AIR DEVICE SCHEDULE ON SHEET M3.1 FOR ADDITIONAL DUCT SIZES.
3. SIZE AND ROUTE REFRIGERANT PIPING PER MANUFACTURER RECOMMENDATIONS.

DRAWING NOTES:

1. 8" Ø FLUE DN TO FIREPLACE. COORDINATE W/ FINAL EQUIPMENT SELECTIONS.
2. 10" Ø FIREPLACE FLUE TERMINATION W/ EXTERIOR POWER VENT. INSTALL PER MANUFACTURER'S REQUIREMENTS.
3. 6" Ø OA INTAKE TERMINATIONS AND LOUVER. LOCATE AND INSTALL PER MANUFACTURER'S INSTALLATION REQUIREMENTS.
4. 18"x12" OA INTAKE LOUVER W/ BIRDSCREEN AND 12" DEEP PLENUM.
5. 8" WATER HEATER EXHAUST OUTLETS. LOCATE AND INSTALL PER MANUFACTURER'S REQUIREMENTS.
6. ECOSPAN PENETRATIONS.
7. 4" Ø DRYER EXHAUST DN TO EQUIPMENT CONNECTION.
8. 4" Ø DRYER EXHAUST CAP W/ BACKDRAFT DAMPER.
9. 8" Ø COMBUSTION AIR INTAKE AND 8" Ø FLUE DN TO WH-1. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
10. 8" Ø COMBUSTION AIR INTAKE AND 8" Ø FLUE DN TO WH-2. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
11. 8" Ø COMBUSTION AIR INTAKE AND 8" Ø FLUE DN TO WH-3. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
12. 8x4 EXHAUST DN TO TYPE B GRILLE AND 6x4 EXHAUST DN TO PEDICURE CHAIR CONNECTION. COORDINATE MOUNTING HEIGHT W/ MANICURE TABLE ELEVATION.
13. 144"x69" GENERATOR EXHAUST LOUVER W/ BIRDSCREEN.
14. 6" Ø OA INTAKES DN TO FIREPLACE. COORDINATE W/ FINAL EQUIPMENT SELECTIONS.
15. 8" WATER HEATER OA INTAKES W/ GOOSE NECKS. LOCATE AND INSTALL PER MANUFACTURER'S REQUIREMENTS.
16. 52"x14" OA INTAKE LOUVER W/ BIRDSCREEN AND 12" DEEP PLENUM.



KEY PLAN
SCALE: NONE



ARCHITECT
Hord Coplan Macht, Inc.
700 E. Pratt St., Suite 1200
Baltimore, MD 21202
p. 410. 837. 7311 f. 410. 837. 6530

STRUCTURAL ENGINEER
Morabito Consultants, Inc.
Ridgely Road, Suite 1700
Sparks, MD 21155
p. 410. 467. 2377 f. 410. 467. 4132

M/E/P ENGINEER
Kibart Consulting Engineers, Inc.
901 Dulany Valley Rd., Suite 301
Towson, MD 21286
p. 410. 494. 1111 f. 410. 828. 0787

CIVIL ENGINEERS
Dynamic Engineering
1904 Main Street
Lake Como, NJ 07719
p. 732. 974. 0198 f. 732. 974. 3521

BRIGHTVIEW SENIOR LIVING

BRIGHTVIEW EATONTOWN
201 WYCKOFF ROAD
EATONTOWN, NJ 07724

hord coplan macht

ARCHITECTURE
LANDSCAPE ARCHITECTURE
PLANNING
INTERIOR DESIGN

PROFESSIONAL CERTIFICATION THESE BY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF NEW JERSEY. LICENSE NUMBER: CE0393 EXPIRATION DATE: 06/30/2022

no.	date	revision
1	08/24/21	ASH001
F	03/09/21	VE REVISIONS

Project Name
BRIGHTVIEW EATONTOWN
Project Number
19094.00
Date
08/24/2021
Scale
1/8" = 1'-0"
Drawing
LEVEL 1 - WING B - MECHANICAL

M2.1B

100% CDS - ISSUED FOR CONSTRUCTION

