

Issue List

- RTU 1 - OA Filters Incorrectly Installed



05-20-24 CARMAX #7110 - DORAL, FL

Project Issue Information

Issue Name : RTU 1 - OA Filters Incorrectly Installed
Description : The outside air filters were not correctly installed on RTU-1. All filters fell out of the unit and onto the rooftop when unit was tested in high speed.
Created By : National TAB **Assigned To :** National TAB - Stephen Tassinaro
Status : Open
Priority : High **Asset Tag :**
Originated Date : 05/22/2024 - Stephen Tassinaro - National TAB

Project Issue File Details



IMG_3058
05/22/2024



IMG_3057
05/22/2024