

# CFA Parham Issue Report - Apr 16, 2024

Prepared by David Annan

Apr 16, 2024

## Description

1 task in this report.

## #24 Kitchen Exhaust do not have hinge kit installed

### Status

Open

### Type

Issue

### Location

Rooftop

### Root Cause

Quality >  
Incomplete work

### Description

All kitchen exhaust fans are spec'd to have a hinge kit installed for all the fans.

### Assignees

bryan.mayfield@getsterling.com

### Watchers

bryan.mayfield@getsterling.com

### Start Date

Apr 9, 2024

### Created


Apr 9, 2024 10:54 AM  
david@nationaltab.com

### Last Updated

Apr 16, 2024 8:37 AM

### Sheet

M4.1



### Photos



IMG\_1850

David Annan

Apr 9, 2024 10:59 AM